

MANHOLE SCHEDULE

Manhole Number	Cover Level	Depth To Soffit	Connections	Pipe			Manhole Size	Types	
				Code	Inverts	Diams Inv-soff		Manhole	Cover
F1	E 438613.725	56.700		0	54.732	150	1200	B	D400
	N 411331.582	1.818		1	1.000	54.822			
F2	E 438614.507	55.400		1	54.822	150	BRICK	S	D400
	N 411348.910	0.628							
S1	E 438628.512	56.00		0	54.900	225	BRICK	S	D400
	N 411307.316	0.875		1	1.000	54.835			
S2	E 438616.563	55.800		0	54.760	300	BRICK	S	D400
	N 411321.038	0.740		1	1.001	54.710			
S3	E 438605.257	56.200		0	54.710	300	1500	B	D400
	N 411321.564	1.19		1	1.002	54.260			
S4	E 438612.203	56.000		0	54.210	225	2100	B	D400
	N 411328.426	1.565		1	1.003	54.100			
S5	E 438613.885	56.000		1	54.100	225	1200	B	D400
	N 411356.210	1.675							

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION	
RISKS LISTED HERE ARE NOT EXHAUSTIVE.	
DEMOLITION	
CONSTRUCTION	
DEPTH OF DRAINAGE, EXISTING DRAINAGE DITCH, SERVICES	
ALL WORKS WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WORKING TO AN APPROVED METHOD STATEMENT.	

YORKSHIRE WATER NOTES:-

- 1) ALL ADAPTABLE SEWER WORKS AND MATERIAL TO BE IN ACCORDANCE WITH "SEWERS FOR ADOPTION" 6TH EDITION, THE RELEVANT BRITISH/EUROPEAN AND YORKSHIRE WATER'S STANDARDS/REQUIREMENTS/ADDENDUM TO THE MECHANICAL AND ELECTRICAL SPECIFICATION AND KITEMARKED.
- 2) MANHOLE COVERS SHALL HAVE A CLEAR OPENING OF 600mm AND SHALL BE CLASS D400 TO BS EN 124 WITH 150mm DEEP FRAMES IN HIGHWAY.
- 3) FILLED GROUND MUST BE FILLED AND CONSOLIDATED UNDER THE SUPERVISION AND TO THE SATISFACTION OF YORKSHIRE WATER BEFORE ANY SEWER WORKS ARE CARRIED OUT.
- 4) YORKSHIRE WATER IS NOT OBLIGED TO ACCEPT FILTER DRAIN/LAND DRAINAGE RUNOFF INTO PUBLIC SEWER NETWORK OR ADAPTABLE DRAINAGE SYSTEM (DIRECTLY OR INDIRECTLY). AN ALTERNATIVE METHOD OF DISPOSAL OF THE LAND DRAINAGE RUNOFF WILL THEREFORE BE REQUIRED AND YOU WILL HAVE TO LIAISE WITH LOCAL AUTHORITY, LAND DRAINAGE SECTION WITH REGARD TO THE DISPOSAL OF THE FILTER DRAIN/LAND DRAINAGE RUNOFF.
- 5) COVER SLABS MUST CARRY THE BS1 KITEMARK OR WILL BE REJECTED BY YORKSHIRE WATER INSPECTOR, WHERE THE CLEAR OPENING OF THE KITEMARKED PRODUCT IS DIFFERENT TO THAT OF THE COVER AND FRAME, A LOADING BEARING SLAB SHOULD BE FITTED ABOVE THE COVER SLAB TO BRING TO SIZE DOWN TO 600mm x 600mm FOR YORKSHIRE WATER SPECIFIED COVER SIZE. PLEASE REFER TO CONCRETE PIPE SYSTEMS ASSOCIATION (CPSA) TECHNICAL BULLETIN ISSUED AUTUMN 2004 FOR KITEMARKED COVER SLAB OPENING SIZES.
- 6) SULPHATE RESISTANT CEMENT (SR0-002) AND PRECAST CONCRETE PRODUCTS MUST BE USED OR LABORATORY REPORT PROVIDED PROVING SUCH PRECAUTIONS ARE NOT NECESSARY.
- 7) THE ADAPTABLE SEWERS SHOULD BE A MINIMUM OF 1m AND MANHOLES 0.5M FORW KERB FACES AND SERVICE MARGINS.
- 8) "SEWERS MUST HAVE 5 METRES CLEARANCE FROM TREES AND HEDGES (PLEASE ALSO REFER TO FIGURE 2.3 ON PAGE 33 IN "SEWERS FOR ADOPTION" 6TH EDITION FOR RESTRICTIONS ON TREE PLANTING ADJACENT TO SEWERS)".
- 9) SEWERS TO BE Laid IN CLASS "S" BEDDING (150mm GRANULAR BEDDING AND SURROUND), WHERE DEPTH OF COVER TO TOP OF SEWER IS LESS THAN 1.2m IN HIGHWAYS AND VERGES (OR LESS THAN 900mm IN NONE VEHICULAR ACCESS AREAS) THEN A CONCRETE SLAB SHOULD BE PROVIDED ABOVE GRANULAR BED AND SURROUND.
- 10) BEDDING AND BACKFILL MATERIAL TO CONFORM TO REQUIREMENT OF WATER INDUSTRY SPECIFICATION 4-08-02 (TABLE A2).
- 11) THE CHAMBER SIZE OF MANHOLES WITH MORE THAN ONE CONNECTION IN THEM MAY NEED TO BE INCREASED AN INCREMENT TO ACCOMMODATE THE CONNECTIONS AND BENDS.
- 12) YORKSHIRE WATER POLICY IS NOT TO ACCEPT TYPE "C" BRICK MANHOLES AND 1050mm DIA MANHOLE RINGS, INSTEAD IT IS PREFERRED THAT YOU USE A TYPE "B" MANHOLE WITH 1200mm DIA OR 1500mm DIA RINGS, WITH THE OPENING SITED OVER THE CHANNEL WHERE DEPTH OF COVER TO PIPE SOFFIT IS 1-1.5m.

3D INFRASTRUCT

D Noble Limited
Proposed Housing Development Park Avenue, Royston, Barnsley, S71 4AD

MANHOLE SCHEDULE

MNS FT 22/01/2017

1000 11