



e3p

Noise Impact Assessment

Hunshelf BESS

Reference: 50-626-R1-5

Date: March 2023



# **NOISE IMPACT ASSESSMENT**

Hunshelf BESS

Prepared for:

**Harmony Energy**

**Report Ref: 50-626-R1-5**

**Date Issued: 27th March 2023**

## E3P

Taylor Road  
Trafford Park  
Urmston  
Manchester  
M41 7JQ

+ 44 (0) 161 707 9612  
<https://e3p.co.uk>

Registered in England  
CRN: 807255262

## QUALITY ASSURANCE

PROJECT NUMBER	50-626		
VERSION	Version 1	Version 4	Version 5
REMARKS	Draft for Comment	Final	Final
DATE	15th July 2022	22nd March 2023	27th March 2023
PREPARED BY	L Faulkner	L Faulkner	L Faulkner
QUALIFICATIONS	BSc (Hons), PGDip, MIOA	BSc (Hons), PGDip, MIOA	BSc (Hons), PGDip, MIOA
POSITION	Associate Director	Associate Director	Associate Director
CHECKED BY	Scott Boughton	Scott Boughton	Scott Boughton
QUALIFICATIONS	BEng (Hons), AIMOA	BEng (Hons), IMOA	BEng (Hons), IMOA
POSITION	Consultant	Senior Consultant	Senior Consultant
AUTHORISED BY	L Faulkner	L Faulkner	L Faulkner
QUALIFICATIONS	BSc (Hons), PGDip, MIOA	BSc (Hons), PGDip, MIOA	BSc (Hons), PGDip, MIOA
POSITION	Associate Director	Associate Director	Associate Director

## EXECUTIVE SUMMARY

### BACKGROUND

<b>Site Address</b>	Land off Tofts Lane, Sheffield S6 5SL
<b>National Grid Reference</b>	E 426251 N 400022
<b>Proposed Development</b>	Construction of Battery Storage Site along with landscaping and access.
<b>Report Objectives</b>	<p>The objectives of this report are to:</p> <ul style="list-style-type: none"><li>Identify, measure and assess the potential impact of any proposed sound sources associated with the development upon existing receptors in the immediate vicinity of the Site.</li></ul> <p>The report follows current and relevant British Standards to provide a robust assessment.</p>

### ASSESSMENT

<b>Surveys Completed</b>	E3P have undertaken an unattended background and ambient sound survey in a position considered representative of the closest existing receptors over a 4-day period including for weekend.
<b>Assessments</b>	<p>A 3D noise model has been constructed to assess potential commercial sound impact associated with the battery storage site.</p> <p>The model has been used to predict the Rating Level at the receptors which has been compared with the lowest typical background sound level, accounting for any acoustic characteristics associated with the sound in accordance with BS 4142:2014+A1:2019.</p>
<b>Mitigation Requirements</b>	The assessment determined that the predicted rating levels would fall well below the existing typical measured background sound level, during daytime and night-time periods, at all receptors. Furthermore, suitably low levels are predicted at night. As such no adverse impact is predicted and no mitigation measures are required.

### CONCLUSIONS

This assessment has shown that no adverse impact is predicted during the day at the receptors due to the proposed plant items.

As such, sufficient information has been provided in order to consider potential noise impact and found no adverse impact is expected.

## TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>2</b>
Background .....	2
Assessment.....	2
Conclusions.....	2
<b>1. INTRODUCTION .....</b>	<b>4</b>
1.1. Background.....	4
1.2. Proposed Development.....	4
1.3. Limitations .....	4
<b>2. ASSESSMENT METHODOLOGY .....</b>	<b>5</b>
2.1. National Planning Policy Framework .....	5
2.2. National Planning Practice Guidance.....	5
2.3. BS 4142: 2014+A1:2019 'Methods for rating and assessing industrial and commercial sound' 7	
<b>3. SURVEY RESULTS.....</b>	<b>9</b>
3.1. Unattended Background and Ambient Sound Survey .....	9
<b>4. NOISE IMPACT ASSESSMENT .....</b>	<b>11</b>
4.1. Daytime Assessment – 07:00-23:00 .....	11
4.2. Night-time Assessment – 23:00-07:00 .....	12
<b>5. CONCLUSION AND RECOMMENDATIONS.....</b>	<b>13</b>
<b>APPENDIX I GLOSSARY OF ACOUSTIC TERMINOLOGY.....</b>	<b>14</b>
<b>APPENDIX II MEASURED BACKGROUND SOUND LEVELS.....</b>	<b>17</b>
<b>APPENDIX III FIGURES .....</b>	<b>22</b>

## **1. INTRODUCTION**

### **1.1. BACKGROUND**

E3P were commissioned by Harmony Energy Limited to undertake a Noise Impact Assessment for a planning application for a proposed battery storage site on a site off Tofts Lane in Hunshelf, Sheffield, to be referred to hereafter as '*the Site*'.

This assessment looks to determine the key noise sources associated with the proposed development and to assess their impact, if any, upon existing residential receptors and to specify mitigation measures, where required.

### **1.2. PROPOSED DEVELOPMENT**

The client is looking to construct a battery storage site, including eight battery units and associated battery and grid transformers.

The key sources of sound associated with the proposed development is the steady state sound from the plant items impacting upon existing receptors.

### **1.3. LIMITATIONS**

Where a noise or vibration survey is required to inform an assessment, E3P will endeavour to ensure that all noise and vibration measurements taken are robust, representative and reliable in order to inform an accurate assessment at the time.

E3P will endeavour to capture all existing and proposed sources of sound and vibration at the time of the surveys and/or assessments. However, should new sources of sound be introduced, existing sources modified/changed, or characteristics of the sound be altered following completion of such, E3P cannot be held accountable for this.

Where mitigation measures are specified in this report, it should be noted that these measures are relative to a specific sound or vibration source, both in terms of the measured sound pressure and vibration level and the character of the sound source. Where either the sound pressure level or the character of the sound varies following completion of the sound survey, E3P cannot be held responsible for any subsequent variations in the proposed mitigation performance, for either absolute levels or frequency content.

## 2. ASSESSMENT METHODOLOGY

### 2.1. NATIONAL PLANNING POLICY FRAMEWORK

To prevent unacceptable risks from pollution, planning policies and decisions should ensure that new development is appropriate for its location. The effects (including cumulative effects) of pollution on health, the natural environment or general amenity, and the potential sensitivity of the area or proposed development to adverse effects from pollution, should be considered.

The national planning policy framework states that planning policies and decisions should aim to:

- ✿ Avoid noise from giving rise to significant adverse impacts on health and quality of life as a result of new development.
- ✿ Mitigate and reduce to a minimum, other adverse impacts on health and quality of life arising from noise from new development, including through the use of conditions.
- ✿ Recognise that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them because of changes in nearby land uses since they were established.
- ✿ Identify and protect areas of tranquillity which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.

### 2.2. NATIONAL PLANNING PRACTICE GUIDANCE

Noise needs to be considered when new developments may create additional noise and when new developments would be sensitive to the prevailing acoustic environment. When preparing local or neighbourhood plans, or taking decisions about new development, there may also be opportunities to consider improvements to the acoustic environment.

Local planning authorities' plan-making and decision-making should take account of the acoustic environment and in doing so consider:

- ✿ Whether or not a significant adverse effect is occurring or is likely to occur.
- ✿ Whether or not an adverse effect is occurring or is likely to occur.
- ✿ Whether or not a good standard of amenity can be achieved.

In line with the explanatory note of the NPSE, this would include identifying whether the overall effect of the noise exposure (including the impact during the construction phase, where applicable) is, or would be, above or below the significant observed adverse effect level and the lowest observed adverse effect level for the given situation.

The “observed effect levels” are as follows:

- 🔊 **Significant observed adverse effect level:** This is the level of noise exposure above which significant adverse effects on health and quality of life occur.
- 🔊 **Lowest observed adverse effect level:** This is the level of noise exposure above which adverse effects on health and quality of life can be detected.
- 🔊 **No observed effect level:** This is the level of noise exposure below which no effect at all on health or quality of life can be detected.

Table 2.1 summarises the noise exposure hierarchy, based on the likely average response.

TABLE 2.1 NOISE EXPOSURE HIERARCHY

PERCEPTION	EXAMPLES OF OUTCOMES	INCREASING EFFECT LEVEL	ACTION
<b>Not Noticeable</b>	No effect.	No observed effect	No specific measures required
<b>Noticeable and Not Intrusive</b>	Noise can be heard but does not cause any change in behaviour or attitude. Can slightly affect the acoustic character of the area but not such that there is a perceived change in the quality of life.	No observed adverse effect	No specific measures required
<b>Lowest Observed Adverse Effect Level</b>			
<b>Noticeable and Intrusive</b>	Noise can be heard and causes small changes in behaviour and/or attitude, e.g. turning up volume of television, speaking more loudly, or having to close windows for some of the time because of the noise where there is no alternative ventilation. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life.	Observed adverse effect	Mitigate and reduce to a minimum
<b>Significant Observed Adverse Effect Level</b>			
<b>Noticeable and Disruptive</b>	The noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion, having to keep windows closed most of the time because of the noise where there is no alternative ventilation. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area.	Significant observed effect	Avoid
<b>Noticeable and Very Disruptive</b>	Extensive and regular changes in behaviour and/or an inability to mitigate effect of noise leading to psychological stress or physiological effects, e.g. regular sleep deprivation/awakening, loss of appetite, significant/medically definable harm (auditory and non-auditory).	Unacceptable adverse effect	Prevent

The subjective nature of noise means that there is not a simple relationship between noise levels and the impact on those affected. This will depend on how various factors combine in any situation.

These factors include the following:

- ✿ The source and absolute level of the noise together with the time of day it occurs. Some types and level of noise will cause a greater adverse effect at night than if they occurred during the day. The adverse effect can also be greater simply because there is less background noise at night.
- ✿ For non-continuous sources of noise, the number of noise events, and the frequency and pattern of occurrence of the noise can be important.
- ✿ The spectral content of the noise and the general character of the noise. The local topology and topography should also be considered along with the existing and, where appropriate, the planned character of the area.

More specific factors to consider when relevant:

- ✿ Where applicable, the cumulative impacts of more than one source should be considered along with the extent to which the source of noise is intermittent and of limited duration.
- ✿ Consideration should also be given to whether adverse internal effects can be completely removed by closing windows and, in the case of new residential development, if the proposed mitigation relies on windows being kept closed most of the time. In both cases, a suitable alternative means of ventilation is likely to be necessary.
- ✿ If external amenity spaces are an intrinsic part of the overall design, then the acoustic environment of those spaces should be considered so that they can be enjoyed as intended.

### **2.3. BS 4142: 2014+A1:2019 'METHODS FOR RATING AND ASSESSING INDUSTRIAL AND COMMERCIAL SOUND'**

This standard describes methods for rating and assessing sound of an industrial or commercial nature which includes:

- ✿ Sound from industrial and manufacturing processes.
- ✿ Sound from fixed installations which comprise mechanical and electrical plant and equipment.
- ✿ Sound from the loading and unloading of goods and materials at industrial and / or commercial premises; and
- ✿ Sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from processes or premises, such as that from forklift trucks, or that from train or ship movements on or around an industrial or commercial Site.

The procedure detailed in the standard compares the measured or predicted specific noise level from any of the above with the background sound level at a residential dwelling. The measured background sound level at a receptor should be reliable and should not necessarily ascertain a lowest measured background sound level, but rather to quantify what is typical.

The specific noise level also acknowledges the reference time intervals depending upon whether the noise source operates during daytime (1-hour) or night-time (15-minute) periods.



There are several 'penalties' which can be attributed to the specific sound level depending upon the 'acoustic features' of the sound level under investigation as follows:

### **Tonality**

- ✳ +2 dB: where the tonality is just perceptible.
- ✳ +4 dB: where the tonality is clearly perceptible; and
- ✳ +6 dB: where the tonality is highly perceptible.

### **Impulsivity**

- ✳ +3 dB: where the impulsivity is just perceptible.
- ✳ +6 dB: where the impulsivity is clearly perceptible; and
- ✳ +9 dB: where the impulsivity is highly perceptible.

### **Intermittency**

- ✳ +3 dB: where the intermittency is readily distinctive against the acoustic environment.

In addition to the above, there is a penalty for 'other sound characteristics' of +3 dB where a sound exhibits characteristics that are neither tonal nor impulsive, though are readily distinctive against the acoustic environment. BS 4142 goes on to state that the rating level is equal to the specific sound level if there are no such features present or expected to be present.

Assessment of the rating level relative to the background sound level can yield the following commentary:

- ✳ Typically, the greater this difference (between the rating level and the background sound level), the greater the magnitude of impact.
- ✳ A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.
- ✳ A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context; and
- ✳ The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact.

### 3. SURVEY RESULTS

The measurement position is detailed in Figure 1 of Appendix III.

#### 3.1. UNATTENDED BACKGROUND AND AMBIENT SOUND SURVEY

E3P has undertaken an unattended background and ambient sound survey in a position considered representative of the existing residential receptors in the vicinity of the development site. The survey was carried out over the following period:

- 📍 17:00 Thursday 9th June to 12:00 Tuesday 14th June 2022.

The following noise measurement position was chosen for the Background and Ambient Sound Survey:

- 📍 Noise Measurement Position 1 (NMP1): Located in the south west corner of the site as far from the existing National Grid Site as possible. The microphone was installed in free-field conditions and at a height of 1.5 m. The sound climate was dominated by road traffic along the local road network and low level noise from the National Grid Site.

Weather conditions during the survey were noted to be acceptable and were monitored daily to ensure compliance. Table 3.1 details the modal measured values for each respective period following statistical analysis. Hourly data is shown in Appendix II and full datasets are available upon request. Levels highlighted in bold represent those to be used in the assessment.

TABLE 3.1 STATISTICAL VALUES FOR EACH DAYTIME AND NIGHT-TIME PERIOD

DATE	ASSESSMENT PERIOD	MODAL BACKGROUND SOUND LEVEL, $L_{A90,T}$ (dB)	RANGE OF MEASURED BACKGROUND SOUND LEVEL, $L_{A90,T}$ (dB)
Thursday 9th June 2022	Daytime	N/A	32.0-41.3
	Night-time	35	30.0-41.2
Friday 10th June 2022	Daytime	39	32.2-41.7
	Night-time	31	29.4-39.9
Saturday 11th June 2022	Daytime	42	35.1-44.4
	Night-time	33	31.1-39.4
Sunday 12th June 2022	Daytime	41	35.0-42.2
	Night-time	31	26.3-36.3
Monday 13th June 2022	Daytime	33	24.1-36.5
	Night-time	<b>25</b>	24.7-30.0

There was concern that, even though not audible during the visits, that the National Grid Site may influence noise levels. However, as shown above the background sound levels were wide ranging across the day and night periods and the lowest modal daytime (33 dB) and night-time (25 dB) are very low and representative of a rural area with no significant sources of sound.

The equipment outlined in Table 3.2 was used for the noise survey.

**Hunshelf BESS**

Noise Impact Assessment

March 2023

---

TABLE 3.2 NOISE MEASUREMENT EQUIPMENT AND CALIBRATION DATES

MEASUREMENT POSITION	EQUIPMENT DESCRIPTION	MANUFACTURER & TYPE NUMBER	SERIAL NUMBER	CALIBRATION DUE DATE
<b>NMP1</b>	Sound Level Meter	Cirrus CR:171B	G301925	27th November 2022
	Pre-amplifier	Cirrus MV:200F	10730F	
	Microphone	Cirrus MK:224	213437D	
	Calibrator	Cirrus CR:515	93700	

The sound level meter was field calibrated on site using the above-mentioned calibrator prior to and after noise measurements were taken. No significant drift was witnessed as noted above. Calibration certificates are available upon request.



## 4. NOISE IMPACT ASSESSMENT

For the purposes of this assessment, E3P has used noise modelling software, CadnaA 2022 MR1, to determine the impact of noise from the proposed plant items.

The following noise level data has been provided by the client:

- ✳ Battery unit, 60% duty cycle (daytime) = 88 dB  $L_{WA}$ .
- ✳ Battery unit, 5 fans 40% duty cycle, 4 fans 20% duty cycle (night-time) = 82 dB  $L_{WA}$ .
- ✳ Battery transformer = 60 dB  $L_{WA}$ .
- ✳ Grid transformer = 75 dB  $L_{WA}$ .

The above have input into the noise model as point sources. The operational periods for the plant are considered to be 24/7.

The following inputs have been included in the model:

- ✳ Proposed Site plan (Operational) HS-PSP-Rev M.
- ✳ Ground elevations have been taken as existing by way of a 2 m grid Digital Terrain Model (DTM) which contains public sector information licensed under the Open Government License v3.0.
- ✳ Existing buildings have been included in the model and assumed to have a structured façade.
- ✳ With regards commercial/industrial sound, corrections have been applied to the inputted sound power levels to account for acoustic characteristics, as per BS 4142:2014+A1:2019. As such, the model output is the Rating Level,  $L_{A,r}$ .
- ✳ A reflection order of 2 has been used in all calculations.
- ✳ Noise levels generated using ISO 9613-1 and ISO 9613-2 "Acoustics – Attenuation of sound during propagation outdoors" as incorporated into CadnaA software.

For the BS 4142:2014 assessments, penalties are applied to the specific sound level to provide the rating level. These penalties relate to the acoustic features of the sound source. Given the distance to the nearest receptors, no features are likely to be audible, however, to inform a worst-case assessment, just perceptible tonality is applied with a correction of +2 dB.

### 4.1. DAYTIME ASSESSMENT – 07:00-23:00

Figure 2 should be used to view the daytime specific noise level,  $L_{Aeq,1hr}$ , at the existing receptors. To inform the assessment, the lowest typical background sound level, 33 dB  $L_{A90,1hr}$  has been used for the assessment.

This assessment considers the operation of all plant during typical daytime periods, Monday to Sunday.

As can be seen, the highest predicted specific noise level is 27 dB at the receptors to the north west of the Site. This results in a maximum predicted rating level of 29 dB at existing receptors. This falls below the background sound level by 4 dB. As such, no adverse impact is predicted during daytime periods.



## **4.2. NIGHT-TIME ASSESSMENT – 23:00-07:00**

Figure 3 should be used to view the night-time specific noise level,  $L_{Aeq,15mins}$ , at the existing receptors. To inform the assessment, the lowest typical background sound level, 25 dB  $L_{A90,15mins}$  has been used for the assessment.

This assessment considers the operation of all plant during typical night-time periods, Monday to Sunday.

As can be seen, the highest predicted specific noise level is 21 dB. This results in a predicted rating level of 23 dB at existing receptors. This falls below the background sound level by 2 dB. Furthermore, the predicted rating level and background sound level are considered low and BS 4142 recommends:

*Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night.*

As such, it is considered prudent to assess internal habitable rooms. Therefore, an assessment is made against the internal criterion given in BS 8233:2014.

The predicted specific noise levels at the facades of the closest plot are 21 dB, this would equate to an internal noise level of 8 dB with windows open, 22 dB below the relevant criterion.

Considering the above assessments, no adverse impact is predicted.



## **5. CONCLUSION AND RECOMMENDATIONS**

E3P were commissioned by Harmony Energy Limited to undertake a Noise Impact Assessment for a proposed battery storage site at Tofts Lane in Hunshelf.

An unattended background and ambient sound survey has been undertaken to be representative of the closest residential receptors to the site.

A 3D noise model has been constructed to assess commercial sound impact associated with the proposed plant items. The model has been used to predict the specific noise level at the existing facades and rear gardens to determine whether the new plant will exceed the existing background sound level.

The assessment has shown the rating level will fall well below the lowest measured background sound level and result in suitably low internal noise levels within the closest dwellings. This is a positive indication of no adverse impact. As such, no mitigation measures are required.

As such, sufficient information has been provided in order to consider potential noise impact and found no adverse impact is expected.

**END OF REPORT**



# **APPENDIX I GLOSSARY OF ACOUSTIC TERMINOLOGY**

## NOISE

Noise is defined as unwanted sound. Human ears are able to respond to sound in the frequency range 20 Hz (deep bass) to 20,000 Hz (high treble) and over the audible range of 0 dB (the threshold of perception) to 140 dB (the threshold of pain). The ear does not respond equally to different frequencies of the same magnitude but is more responsive to mid-frequencies than to lower or higher frequencies. To quantify noise in a manner that approximates the response of the human ear, a weighting mechanism is used. This reduces the importance of lower and higher frequencies, in a similar manner to the human ear.

Furthermore, the perception of noise may be determined by a number of other factors, which may not necessarily be acoustic. In general, the impact of noise depends upon its level, the margin by which it exceeds the background level, its character and its variation over a given period of time. In some cases, the time of day and other acoustic features such as tonality or impulsiveness may be important, as may the disposition of the affected individual. Any assessment of noise should give due consideration to all of these factors when assessing the significance of a noise source. The most widely used weighting mechanism that best corresponds to the response of the human ear is the "A"-weighting scale. This is widely used for environmental noise measurement, and the levels are denoted as dB(A) or  $L_{Aeq}$ ,  $L_{A90}$  etc., according to the parameter being measured.

The decibel scale is logarithmic rather than linear, and hence a 3 dB increase in sound level represents a doubling of the sound energy present. Judgement of sound is subjective but, as a general guide, a 10 dB(A) increase can be taken to represent a doubling of loudness, whilst an increase in the order of 3 dB(A) is generally regarded as the minimum difference needed to perceive a change under normal listening conditions. An indication of the range of sound levels commonly found in the environment is given in the following table.

TABLE A1 TYPICAL SOUND PRESSURE LEVELS

SOUND PRESSURE LEVEL	LOCATION/EXAMPLE
0	Threshold of hearing
20–30	Quiet bedroom at night
30–40	Living room during the day
40–50	Typical office
50–60	Inside a car
60–70	Typical high street
70–90	Inside a factory
100–110	Burglar alarm at 1 m away
110–130	Jet aircraft on take off
140	Threshold of pain



## ACOUSTIC TERMINOLOGY

TABLE A2 TERMINOLOGY

DESCRIPTOR	EXPLANATION
<b>dB (decibel)</b>	The scale on which sound pressure level is expressed. It is defined as 20 times the logarithm of the ratio between the root-mean-square pressure of the sound field and a reference pressure (2E-05 Pa).
<b>dB(A)</b>	A-weighted decibel. This is a measure of the overall level of sound across the audible spectrum with a frequency weighting (i.e. "A" weighting) to compensate for the varying sensitivity of the human ear to sound at different frequencies.
<b>L<sub>Aeq, T</sub></b>	L <sub>Aeq</sub> is defined as the notional steady sound level which, over a stated period of time (T), would contain the same amount of acoustical energy as the A-weighted fluctuating sound measured over that period.
<b>L<sub>Amax</sub></b>	L <sub>Amax</sub> is the maximum A-weighted sound pressure level recorded over the period stated. L <sub>Amax</sub> is sometimes used in assessing environmental noise where occasional loud noises occur, which may have little effect on the overall L <sub>eq</sub> noise level but will still affect the noise environment. Unless described otherwise, it is measured using the "fast" sound level meter response.
<b>L<sub>10</sub> and L<sub>90</sub></b>	If a non-steady noise is to be described, it is necessary to know both its level and the degree of fluctuation. The L <sub>n</sub> indices are used for this purpose, and the term refers to the level exceeded for n% of the time. Hence L <sub>10</sub> is the level exceeded for 10% of the time and as such can be regarded as the "average maximum level". Similarly, L <sub>90</sub> is the "average minimum level" and is often used to describe the background noise. It is common practice to use the L <sub>10</sub> index to describe traffic noise.
<b>Free-field Level</b>	A sound field determined at a point away from reflective surfaces other than the ground with no significant contributions due to sound from other reflective surfaces. Generally, as measured outside and away from buildings.
<b>Fast</b>	A time weighting used in the root-mean-square section of a sound level meter with a 125-millisecond time constant.
<b>Slow</b>	A time weighting used in the root-mean-square section of a sound level meter with a 1000-millisecond time constant.



**APPENDIX II  
MEASURED BACKGROUND  
SOUND LEVELS**

TABLE A1: HOURLY AMBIENT AND BACKGROUND SOUND LEVEL DATA

PERIOD START	AMBIENT SOUND LEVEL, $L_{Aeq,1hr}$ (dB)	BACKGROUND SOUND LEVEL, $L_{A90,1hr}$ (dB)
09/06/2022 17:00:00	44.1	39.6
09/06/2022 18:00:00	44.8	41.3
09/06/2022 19:00:00	43.4	36.7
09/06/2022 20:00:00	40.3	33.9
09/06/2022 21:00:00	39.7	34.7
09/06/2022 22:00:00	38.8	32.0
09/06/2022 23:00:00	36.5	30.7
10/06/2022 00:00:00	40.1	32.5
10/06/2022 01:00:00	45.2	38.5
10/06/2022 02:00:00	43.8	37.3
10/06/2022 03:00:00	40.8	34.0
10/06/2022 04:00:00	41.3	32.1
10/06/2022 05:00:00	41.8	36.8
10/06/2022 06:00:00	39.6	35.3
10/06/2022 07:00:00	41.1	36.2
10/06/2022 08:00:00	44.3	36.9
10/06/2022 09:00:00	46.2	39.6
10/06/2022 10:00:00	45.1	39.2
10/06/2022 11:00:00	45.4	39.4
10/06/2022 12:00:00	46.3	39.4
10/06/2022 13:00:00	46.4	40.2
10/06/2022 14:00:00	45.6	39.5
10/06/2022 15:00:00	47.4	40.4
10/06/2022 16:00:00	49.3	41.7
10/06/2022 17:00:00	48.4	40.7
10/06/2022 18:00:00	47.9	40.6
10/06/2022 19:00:00	45.4	38.6
10/06/2022 20:00:00	45.2	38.2
10/06/2022 21:00:00	43.9	36.6
10/06/2022 22:00:00	41.7	32.2
10/06/2022 23:00:00	41.8	32.8
11/06/2022 00:00:00	39.0	31.7



<b>PERIOD START</b>	<b>AMBIENT SOUND LEVEL, <math>L_{Aeq,1hr}</math></b> <b>(dB)</b>	<b>BACKGROUND SOUND LEVEL, <math>L_{A90,1hr}</math></b> <b>(dB)</b>
11/06/2022 01:00:00	38.8	30.8
11/06/2022 02:00:00	40.0	32.2
11/06/2022 03:00:00	37.9	30.1
11/06/2022 04:00:00	35.8	30.0
11/06/2022 05:00:00	38.2	31.7
11/06/2022 06:00:00	45.2	38.4
11/06/2022 07:00:00	47.7	39.5
11/06/2022 08:00:00	47.6	41.2
11/06/2022 09:00:00	50.2	42.6
11/06/2022 10:00:00	47.7	41.3
11/06/2022 11:00:00	47.9	41.5
11/06/2022 12:00:00	48.0	40.8
11/06/2022 13:00:00	47.3	40.6
11/06/2022 14:00:00	49.7	42.3
11/06/2022 15:00:00	50.7	42.2
11/06/2022 16:00:00	52.3	43.3
11/06/2022 17:00:00	55.6	44.4
11/06/2022 18:00:00	50.6	42.2
11/06/2022 19:00:00	52.5	42.1
11/06/2022 20:00:00	46.2	38.2
11/06/2022 21:00:00	43.3	35.7
11/06/2022 22:00:00	41.7	35.1
11/06/2022 23:00:00	41.4	34.0
12/06/2022 00:00:00	37.4	33.1
12/06/2022 01:00:00	39.6	33.8
12/06/2022 02:00:00	37.3	31.5
12/06/2022 03:00:00	39.9	32.7
12/06/2022 04:00:00	41.2	32.5
12/06/2022 05:00:00	39.5	32.0
12/06/2022 06:00:00	44.3	35.5
12/06/2022 07:00:00	43.6	36.9
12/06/2022 08:00:00	45.7	38.5
12/06/2022 09:00:00	48.2	39.1



<b>PERIOD START</b>	<b>AMBIENT SOUND LEVEL, <math>L_{Aeq,1hr}</math></b> <b>(dB)</b>	<b>BACKGROUND SOUND LEVEL, <math>L_{A90,1hr}</math></b> <b>(dB)</b>
12/06/2022 10:00:00	48.5	41.1
12/06/2022 11:00:00	47.3	40.5
12/06/2022 12:00:00	47.3	40.9
12/06/2022 13:00:00	50.9	42.2
12/06/2022 14:00:00	49.7	41.6
12/06/2022 15:00:00	47.8	41.0
12/06/2022 16:00:00	48.3	40.6
12/06/2022 17:00:00	45.0	38.2
12/06/2022 18:00:00	45.8	39.4
12/06/2022 19:00:00	43.3	36.2
12/06/2022 20:00:00	43.6	36.4
12/06/2022 21:00:00	41.8	35.0
12/06/2022 22:00:00	40.9	35.1
12/06/2022 23:00:00	39.0	31.7
13/06/2022 00:00:00	37.6	31.2
13/06/2022 01:00:00	32.7	27.0
13/06/2022 02:00:00	34.0	27.0
13/06/2022 03:00:00	35.8	29.0
13/06/2022 04:00:00	36.1	30.3
13/06/2022 05:00:00	39.3	33.9
13/06/2022 06:00:00	40.4	35.6
13/06/2022 07:00:00	39.8	35.1
13/06/2022 08:00:00	40.5	34.4
13/06/2022 09:00:00	40.7	33.8
13/06/2022 10:00:00	40.0	33.4
13/06/2022 11:00:00	39.0	33.6
13/06/2022 12:00:00	41.7	34.1
13/06/2022 13:00:00	41.2	35.3
13/06/2022 14:00:00	40.9	34.9
13/06/2022 15:00:00	42.2	36.5
13/06/2022 16:00:00	41.7	34.2
13/06/2022 17:00:00	38.8	33.4
13/06/2022 18:00:00	37.4	32.3




<b>PERIOD START</b>	<b>AMBIENT SOUND LEVEL, <math>L_{Aeq,1hr}</math></b> <b>(dB)</b>	<b>BACKGROUND SOUND LEVEL, <math>L_{A90,1hr}</math></b> <b>(dB)</b>
13/06/2022 19:00:00	34.7	30.1
13/06/2022 20:00:00	35.7	29.4
13/06/2022 21:00:00	35.7	26.3
13/06/2022 22:00:00	28.9	24.1
13/06/2022 23:00:00	29.4	24.9
14/06/2022 00:00:00	31.9	25.6
14/06/2022 01:00:00	29.1	25.9
14/06/2022 02:00:00	32.3	25.9
14/06/2022 03:00:00	30.7	25.3
14/06/2022 04:00:00	32.5	27.8
14/06/2022 05:00:00	32.8	28.9
14/06/2022 06:00:00	33.7	28.3
14/06/2022 07:00:00	35.4	28.2
14/06/2022 08:00:00	33.5	26.0
14/06/2022 09:00:00	44.2	26.9
14/06/2022 10:00:00	41.3	28.6



# APPENDIX III

## FIGURES


Figure 1 - Noise Survey Measurement Positions



**Project:**  
Hunshelf BESS


**Project-No:**  
50-626

**Client:**  
Harmony Energy



Project Engineer: L Faulkner  
Date: 27/03/2023

Figure 2 - Daytime Grid Noise Map - Calculation at 1.5 m above ground level



**Project:**  
Hunshelf BESS

**Project-No:**  
50-626

**Client:**  
Harmony Energy

**Specific Noise Level,  
LAeq,T (dB)**

Dark Green	... ≤ 38
Light Green	38 < ... ≤ 40
Yellow-Green	40 < ... ≤ 42
Yellow	42 < ... ≤ 45
Light Yellow	45 < ... ≤ 48
Light Blue	48 < ... ≤ 50
Blue	50 < ... ≤ 52
Dark Blue	52 < ... ≤ 55
Very Dark Blue	55 < ...


**Noise Map Objects**

- + Point Source
- Road
- Building
- Barrier
- ∇ Contour Line
- ⊗ Receiver
- Calculation Area



Project Engineer: L Faulkner  
Date: 27/03/2023

Figure 3 - Night-time Grid Noise Map - Calculation at 4 m above ground level












**Project:**  
Hunshelf BESS








**Project-No:**  
50-626

**Client:**  
Harmony Energy

**Specific Noise Level,  
LAeq,T (dB)**

	... $\leq 38$
	38 < ... $\leq 40$
	40 < ... $\leq 42$
	42 < ... $\leq 45$
	45 < ... $\leq 48$
	48 < ... $\leq 50$
	50 < ... $\leq 52$
	52 < ... $\leq 55$
	55 < ...

**Noise Map Objects**

-  Point Source
-  Road
-  Building
-  Barrier
-  Contour Line
-  Receiver
-  Calculation Area



Project Engineer: L Faulkner  
Date: 27/03/2023