



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES(EXEMPTION)(ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: NORTHERN POWERGRID (YORKSHIRE) PLC
Contact person: Robert Hancott
Address: Northumbria Works
Mill Street East
Dewsbury
WF12 9AH

Applicant's reference: ENQ23177964

Date: 29th August 2024

To: Planning & Building Control, Barnsley Metropolitan Borough Council,
PO Box 634, Barnsley, S70 9GG

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

Electricity Supply –

1. Erect a 9 metre wooden H-pole
2. Install a 200kva transformer

This apparatus is required to provide a supply of electricity to combined sewage overflow equipment at the above location.

The location of the new H-Pole and transformer has been chosen so as to cause minimum disruption and is considered to be the most acceptable.

Yours faithfully

Robert Hancott

For and on behalf of the Applicant