



PLANNING CONSULTATION RESPONSE

Application No	<u>2026/0327</u>
Proposal	Installation of black metal archway
Address	Armed Services Walkway, Westgate, Barnsley
Date of Consultation Reply	25/06/26
Consultee	Highways Development Control

Consultation Assessment and Justification

Further to the request for detailed information as to how the archway will be secured, we were provided with the following information;

- The structure will be secured to the concrete plinth at the top of the staircase.
- Metal brackets will then be installed, passing through the timber cladding and fixing into the concrete behind (several sections of cladding have already been removed to confirm this is feasible).
- If additional structural support is required, a concrete base plate can be installed to anchor the archway into the ground. Provision has been made within the budget should this be necessary.

This has been reviewed by our structures team who have no objections to the proposal.

As such, there are no further outstanding issues and no objections to the application from a Highways point of view.

Many thanks,

Sarah Sharp
Senior Engineer
Highways Development Control

NO OBJECTION*

Defer for amends/further information*

OBJECT

Consultation Condition(s):

Consultation Informative(s):

Planning Obligations required