



FLOW CONTROL DETAILS

Hydrobrake control
 SHE-0102-4400-0800-4400
 800mm head
 4.4 l/s pass on flow

TENDER

Rev	Details	Date	Drwn	Chk.
Barnsley MBC				
Cooperative Street Goldthorpe				
Flow control manhole 1				
Dwg No. : STE/24/10/06/01				
Date : 19-7-24				
Scale : Not to scale Copyright © Shaun Tonge Engineering				