

FOUNDATIONS: Foundations to be constructed at 600x225mm to all cavity walls off good ground with at least 600mm cover subject to depth of existing to be linked and below all adjacent drainage. All foundations and excavation works to be subject to the approval of LA Building Control Officer.

GLAZING:-
 All glazing to comply with Approved Document N of Building Regs and to BS 5713:1979.
 All glazing to critical areas to be Kitemarked safety glass as follows:-
 Windows with sill height less than 800mm from internal floor level.

Standard foundation blockwork, solid, with strength 7N/mm². All cavity walls to have GEN 1 designated mix concrete filling up to 150mm below lowest DPC.

In doors and adjacent side screens to all areas below 1500mm from finished floor level.

above external ground level. Tray DPC to be installed above any lintols.

meter boxes and air bricks with perpendicular weep holes at max 450mm c/c. Tray DPC's to rise min 150mm across cavity. All DPC's to be min 2000 Gauge.

Internal leaf of 100mm 4.2N/mm² solid lightweight conc blk/wk. Generally

Internal leak of 100mm x 24mm² rigid lightweight foam block. Generally provide 100mm structural cavity with 50mm partial fill cavity insulation built-in as work proceeds. GBA certified, to achieve overall U-value of m^2K/W 0.28/m² such as Celotex GCS500 or equivalent. Stainless steel U-value of m^2K/W wall safety film at 750mm horiz. x 450mm vert. close every block course vertically at reveals within 150mm of reveal. Close cavity around all openings with reveal blocks to jambs in conjunction with proprietary insulated dips and proprietary insulated combination dip-closer at sills/thresholds to prevent cold bridging. Cavity to be closed at head of cavity. Wall, before and install, all necessary dips as specified above.



All new windows and doors to the high performance cream PVCu to match existing in every respect, double glazed with HP DG units incorporating 16mm gas filled cavity, & low-E glass to ensure max 1,6 w/m²·K U-Value, fully draft sealed, with opening lights as indicated giving min 1200h floor area natural ventilation. Trickle vents to be provided to give at least 5000mm².

improved to suit by a "GAS-SAFE" plumbing contractor.

Heating system to be controlled by independent thermostatic rad valves.
Any non-room sealed heating appliances to have permanent ventilation to relevant rooms in accordance with manufacturers requirements.
Space heating control system to comply with regulation G3, British Standards and Codes of Practice.
No combustible material to be installed within 40mm of any flue.

INTERNAL LIGHTING/ELECTRICS:-


and to incorporate in at least 1 in 4 positions or at the ratio of 1 per 25m² floor area whichever the greater high efficacy lighting fittings with lamps giving him luminous efficacy of 40 lumens/circuit-watt. All new electrical work to be undertaken in accordance with latest edition of 'Wiring Regulations' (BS6761), by qualified certified electrician operating under an approved 'competent persons' scheme.





SIDE (ENE) ELEVATION



REAR (NNW) ELEVATION



SIDE (MSW) ELEVATION



TYPICAL SECTION

-		==/==/==	=
Revision	Date	Description	

**PROPOSED ORANGERY
5 LITTLE STUBBING,
WOMBWELL.**

DETAILED PROPOSALS

PLANS, SECTION AND ELEVATIONS

Miss A Scargill



Building Design Services

JE Architectural Ltd,
Windmill Road, Wombwell,

Tel: 07944 711 439
 Email: jearchitectural@virginmedia.com

Scale: 1:50@A1 Date: AUG 2011

1113

Ref: 201113		Drwg No: 02	
0 cm	2 cm	4 cm	6 cm

This drawing and the copyright is the Architectural Company's property and may be used or reproduced only by agreement. All Dimensions in Millimetres Unless specified otherwise and subject to verification on site.