




CLEARANCES FOR BUSBARS AND CONNECTIONS (REFER ALSO TO NGTS 2.04 TABLES 1 AND 2 AND TGN(E) 186)			
VOLTAGE BETWEEN PHASES	400kV		
MINIMUM CLEARANCE BETWEEN LIVE METAL & EARTH	3100 mm	EC	
MINIMUM CLEARANCE BETWEEN LIVE METAL OF DIFFERENT PHASES	4800 mm	PC	
MINIMUM SAFETY CLEARANCES			
SAFETY CLEARANCE	3100 mm		
DESIGN CLEARANCE FOR MWP OPERATION (VERTICAL)	7500 mm	De	
DESIGN CLEARANCE FOR MWP OPERATION (HORIZONTAL)	6600 mm	De	
CLEARANCE TO GROUND	7900 mm		

NOTES:--
1. ALL DIMENSIONS ARE IN METRES.
2. FOR LOCATION OF ELEVATIONS SEE DRG No PDD-33492-LAY-002
3. - - - - - INDICATES A 3D MEASUREMENT AND CANNOT BE SCALED

ASSOCIATED DRAWINGS:
PDD-33492-LAY-002A - LAYOUT SHOWING PROPOSED NEW
CABLE SEALING END COMPOUND ADJACENT
TO TOWER 4Z0157R

P9	MODIFIED IN LINE WITH NG COMMENTS	MAC	CN	CN	15/07/19
P8	MODIFIED IN LINE WITH NG COMMENTS	MAC	CN	CN	12/06/19
P7	MODIFIED IN LINE WITH NG COMMENTS	SPS	VB	CN	24/05/19
P6	MODIFIED IN LINE WITH NG COMMENTS	MAC	VB	CN	01/04/19
P5	CLEARANCE TABLE MODIFIED, 3D MEASUREMENT, NOTE 3 AND VERTICAL DIMENSION ADDED, TOWER LEGS REDUCED BY 3M	MAC	SF	DM	12/09/18
P4	MODIFIED LINE TO MATCH NEW CSE COMPOUND LAYOUT	MAC	SF	DM	24/05/19
P3	NOTES REFERRING TO REQUIRED CLEARANCES ADDED	CPR	MMR	IE	27/09/16
P2	REPLACEMENT TOWER TYPE AND SEALING END COMPOUND FENCE LINE REVISED	CPR	DGC	IE	03/06/16
P1	FIRST ISSUE	CPR	DGC	IE	18/05/16
Rev	Description	Drawn	Checked	Revised	Date

nationalgrid

Master Scheme No: 33492	Sub-Scheme No:	Site:
Scheme Name: VISUAL IMPACT PROVISION WORK PACKAGE 1 PEAK DISTRICT NATIONAL PARK		
Document Title: ELEVATIONS SHOWING PROPOSED NEW CABLE SEALING END COMPOUND ADJACENT TO TOWER 4Z0157R		
Created by: C. Russell	Date: 18/05/2016	Checked by: J. Evans
Development Eng: D. Spurr	Document Type: LAY	Scale: 1:200
Format: A0	Sheet(s): 1 OF 1	Rev: P9
National Grid Document Number: PDD-33492-LAY-003		
FEED Document Number:		