
 10m Galvanised steel column with Philips City Soul Gen2 20Klm Led lantern complete with electronic PEC

 125mm Ø ducting to NPG requirements with 600mm cover. Sand surround and NPG duct tape cover.

All material to comply fully with current BMBC Street lighting specification.

All lighting columns are to be provided with an immetered single phase electrical supply via the REC cable network. It is expected that the contractor will coordinate with the REC regarding the installation of any cable ducts they may require.

This map is reproduced from Ordnance Survey material with the permission of Ordnance Survey on behalf of the Controller of Her Majesty's Stationery Office © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. 10002264 (2009).

| Rev. | By | Amendments | Date |
|------|----|-------------------------|--------|
| A | NL | Title amended | Oct 19 |
| B | NL | Scheme layout amended | Apr 20 |
| C | NL | Kerb Alignment taxi bay | Apr 21 |



| | | | |
|--|-------------|---------|------------------|
| Project Market Gate Bridge Project | | | |
| Drawing title Highway Alignment Street Lighting (WEST) | | | |
| Scale 1:500 | Drawn NL | Checked | Date Apr 2019 |
| Drawing No. BGW2_BMB_PB_XX_PN_C_G100_0010 | | | File |

Paul Castle Service Director, Place Directorate Environment & Transportation (Business Unit 6)
P.O. Box 601, Westgate Plaza One, Westgate Barnsley. S70 9FA
Tel. (01226) 770770 Fax. (01226) 772222