

NO	TPO	TREE SPECIES		HEIGHT m	SPREAD m	Clear stem (m)	DIA mm	N	CAT.	Life		NOTES
	ref	Common Name	Scientific Name							Stage	exp yrs	
H1		Cherry Laurel	Prunus laurocerasus	1.5	1	-	100		C2	Early-Mature	40+	
T2		Hazel	Corylus	6	8	-	300		C2	Semi-Mature	40+	Offsite, Coppiced
T3		Pussy Willow	Salix caprea	8	8	-	400	N	C2	Semi-Mature	40+	Multi-stemmed, 1.5m below embankment
T4		Sycamore	Acer pseudoplatanus	8	4	4	250		C2	Semi-Mature	40+	1.5m below embankment
T5		Hornbeam	Carpinus betulus	8	8	4	250		C2	Semi-Mature	0-10	Very late leafing out, 1.5m below embankment
T6		Silver Birch	Betula pendula	6	3	1	110	N	C2	Young	40+	Twinstem, 1m below embankment
T7		Silver Birch	Betula pendula	7	3	3	75		C2	Young	40+	1.5m below embankment
G8		Lawson Cypress	Chamaecyparis lawsoniana	5	4	-	150		C2	Early-Mature	40+	Offsite, Group 3No.
T9		Hazel	Corylus	6	8	-	400		C2	Semi-Mature	40+	Offsite, Coppiced, 3m below embankment
T10	BMBC TPO33, T1	Sycamore	Acer pseudoplatanus	12	12	-	650		B2	Mature	40+	Leaning north west, 1.2m below embankment
G11		Hawthorn	Crataegus monogyna	6	3	-	150		C2	Early-Mature	40+	Offsite, Group 3No.
T12		Ash	Fraxinus excelsior	12	5	4	250		U	Early-Mature	0	Offsite, Dead
T13	BMBC TPO33, T8	Ash	Fraxinus excelsior	14	10	5	800		B2	Mature	40+	Offsite, Ivy covered stem, Cavity at 3m and at base
T14	BMBC TPO33, T3	Alder	Alnus glutinosa	10	10	3	550		C2	Mature	0-10	Offsite, Major dieback (75%)
T15	BMBC TPO33, T4	Ash	Alnus glutinosa	12	13	4	700		B2	Mature	40+	Some dead wood, Minor dieback



TREE SURVEY TO BS5837:2012

KEY

COLOUR

QUALITY

DESCRIPTION

GREEN

A: HIGH

Vigorous healthy good form, visually important, historic or rare

BLUE

B: MODERATE

Slightly impaired condition, numerous immature, 'A' potential

GREY

C: LOW

Adequate condition requiring minimal surgery

RED

U: FELL

Dead dying, dangerous insecure rooting, significant fungal disease

GREEN

SHRUBS

SUB-CATEGORY:

1 ARBORICULTURAL

2 LANDSCAPE

3 CULTURAL/CONSERVATION

In accordance with BS5837:2012 'Trees in relation to design, demolition and construction', offsite trees within a distance equal to 12x stem diameter from boundary should be surveyed. In accordance with good working practice, all trees within 12m of the site boundary have been surveyed.

The original of this drawing is produced in colour - a monochrome copy should not be relied upon.

LIMITATION OF THIS SURVEY
 This survey records amenity quality and desirability of tree retention in relation to proposed construction by visual inspection from ground level where accessible.

It does not constitute a Tree Inspection or detailed report on condition.

Tree heights and spread approximate. The diameter of single stem trees is taken at 1.5m above ground level. For the diameter of multistemmed trees, each multistem is measured at 1.5m above ground level and calculated to give a notional diameter as if all multistems were fused into one stem.

The branch spread is an accurate representation of the crown as clause 4.4.2.5 (e)

Tree inspections should take place annually in September/October when trees are in leaf.

Tree positions are approximate and are to be verified by topographic survey.

Based on CODA Studios Ltd. layout no. 3015-001, dated 19/04/2021

Weddle Landscape Design

LANDSCAPE ARCHITECTURE

ENVIRONMENTAL PLANNING

Mews Studio, Charnwood House,

8 Kenwood Bank, Sheffield S7 1NU

www.weddles.co.uk

Tel (0114) 250 1181

Fax (0114) 250 1188

mail@weddles.co.uk

Job STATION HOUSE, TANKERSLEY

Title
 TREE SURVEY

scale@A3	drawn	date	job number	number	revision
1:250	EH	JUN 21	1269	SHT 01	-