



YorkshireWater

**Head of Planning and Transportation Service
Barnsley Metropolitan Borough Council
PO Box 604
Barnsley
S70 9FE**

**Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY**

Tel: 0345 120 8482

**Email:
planningconsultation@yorkshirewater.co.uk**

**Your Ref: 2025/1065
Our Ref: A/03601**

16th January 2026

Dear Sir/Madam,

West Green Recycling, West Green Way, Monk Bretton, Barnsley - (BARN) Erection of store, erection of enclosure for external pipework, erection of aggregate wash plant and associated infrastructure; laying of concrete slab, installation of vertical tanks (retrospective), proposed construction, relocation and increase in height of boundary treatment, proposed erection of filter presses, for use in association with the existing treatment and management of non-hazardous waste

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

Yorkshire Water objects to the application due to lack of submitted drainage information.

- 1.) The developer is proposing to discharge surface water to SUDS but the eventual outfall has not been stated.
 - a.) Previous applications for the site stated surface water outfall to watercourse. Can this be confirmed?
 - b.) Yorkshire Water promote the surface water disposal hierarchy and the developer must provide evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical before considering disposal to public sewer.
 - c.) The developer and LPA are strongly advised to seek comments on surface water disposal from other drainage bodies as further restrictions may be imposed.

Yours faithfully

**Reuben Thornton
Town Planning Team**

