Scaled @ 1:500

0 10m 20m 50m



Typical Front Elevation
(when parking is directly in front of the dwelling)
Scale 1:25

Ⓔ = Electric Vehicle Charging Point Location (EVCP) (Mode 3)

Notes

1) Mode 3 charging point to be Installed within garages or adjacent driveways & parking spaces.
2) Positioning of charging point to be a minimum of 1000mm from Ground Level
3) FOG's and plots with integral garages to receive charger within garage only.

Rev	Details	Date	By	Chk
D	EVCP Changed to be mode 3 units	07/02/23	OF	
B	As previously agreed with Chris Shields (Technical Officer (Pollution Control), Regulatory Services) at BMBC, the EVCP has been updated to a 32amp socket. Therefore allowing an occupant to upgrade the to a charging pod at a later date if needed.	06/01/2021	JP	
A	External sockets added to the following plots, 15, 16,17,21,33,45,56,61,62,63,64,68,69,72,73,74,75, 88,89 & 91 also lockable sockets added for parking spaces that are remote & spec updated to a standard 13amp IP rated socket	10/11/2020	JP	

DATE	13/07/2020	DRAWN	JP
SCALE	NTS	CHK	DC

Electric Vehicle Charging Points

Carlton Road
Carlton, Barnsley

Dwg No	2028-Y2-04-02	Rev D

Keepmoat, The Waterfront, Lakeside Boulevard, Doncaster, DN4 5PL.
Tel: 01302 346620 www.keepmoat.com

Keepmoat® Homes