



TOP OF DITCH = 54.840
 INVERT OF 450Ø = 54.040

SAFETY HEALTH AND ENVIRONMENTAL INFORMATION	
RISKS LISTED HERE ARE NOT EXHAUSTIVE.	
DEMOLITION	
CONSTRUCTION DEPTH OF DRAINAGE, EXISTING DRAINAGE DITCH, SERVICES	
ALL WORKS WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WORKING, TO AN APPROVED METHOD STATEMENT.	

KEY:-	
	PROPOSED S104 FOUL SEWER
	PROPOSED S104 SURFACE WATER SEWER
	ABANDON SEWER
	EXISTING SURFACE WATER SEWER
	EXISTING COMBINED SEWER
	PROPOSED BIOSWALE
	PROPOSED GULLY
	SURFACE WATER RISING MAIN
	FOUL WATER RISING MAIN

- YORKSHIRE WATER NOTES:-
- 1) ALL ADOPTABLE SEWER WORKS AND MATERIAL TO BE IN ACCORDANCE WITH "SEWERS FOR ADOPTION" 6TH EDITION, THE RELEVANT BRITISH/EUROPEAN AND YORKSHIRE WATER'S STANDARDS/REQUIREMENTS/ADDENDUM TO THE MECHANICAL AND ELECTRICAL SPECIFICATION AND KITEMARKED.
 - 2) MANHOLE COVERS SHALL/MUST HAVE A CLEAR OPENING OF 600mm AND SHALL BE CLASS D400 TO BS EN 124 WITH 150mm DEEP FRAMES IN HIGHWAY.
 - 3) FILLED GROUND MUST BE FILLED AND CONSOLIDATED UNDER THE SUPERVISION AND TO THE SATISFACTION OF YORKSHIRE WATER BEFORE ANY SEWER WORKS ARE CARRIED OUT.
 - 4) YORKSHIRE WATER IS NOT OBLIGED TO ACCEPT FILTER DRAIN/LAND DRAINAGE RUNOFF INTO PUBLIC SEWER NETWORK OR ADOPTABLE DRAINAGE SYSTEM (DIRECTLY OR INDIRECTLY). AN ALTERNATIVE METHOD OF DISPOSAL OF THE LAND DRAINAGE RUNOFF WILL THEREFORE BE REQUIRED AND YOU WILL HAVE TO LIAISE WITH LOCAL AUTHORITY, LAND DRAINAGE SECTION WITH REGARD TO THE DISPOSAL OF THE FILTER DRAIN/LAND DRAINAGE RUNOFF.
 - 5) COVER SLABS MUST CARRY THE BSI KITEMARK OR WILL BE REJECTED BY YORKSHIRE WATER INSPECTOR. WHERE THE CLEAR OPENING OF THE KITEMARKED PRODUCT IS DIFFERENT TO THAT OF THE COVER AND FRAME, A LOADING BEARING SLAB SHOULD BE FITTED ABOVE THE COVER SLAB TO BRING TO SIZE DOWN TO 600mm x 600mm FOR YORKSHIRE WATER SPECIFIED COVER SIZE. PLEASE REFER TO CONCRETE PIPE SYSTEMS ASSOCIATION (CPSA), "TECHNICAL BULLETIN" ISSUED AUTUMN 2004 FOR KITEMARKED COVER SLAB OPENING SIZES.
 - 6) SULPHATE RESISTANT CEMENT (C20-DC2) AND PRECAST CONCRETE PRODUCTS MUST BE USED OR A LABORATORY REPORT PROVIDED PROVING SUCH PRECAUTIONS ARE NOT NECESSARY.
 - 7) THE ADOPTABLE SEWERS SHOULD BE A MINIMUM OF 1m AND MANHOLES 0.5M FORM KERB FACES AND SERVICE MARGINS.
 - 8) "SEWERS MUST HAVE 5 METRES CLEARANCE FROM TREES AND HEDGES (PLEASE ALSO REFER TO FIGURE 2.3 ON PAGE 33 IN "SEWERS FOR ADOPTION" 6TH EDITION FOR RESTRICTIONS ON TREE PLANTING ADJACENT TO SEWERS)".
 - 9) SEWERS TO BE LAID IN CLASS "S" BEDDING (150mm GRANULAR BEDDING AND SURROUND), WHERE DEPTH OF COVER TO TOP OF SEWER IS LESS THAN 1.2m IN HIGHWAYS AND VERGES (OR LESS THAN 900mm IN NONE VEHICULAR ACCESS AREAS) THEN A CONCRETE SLAB SHOULD BE PROVIDED ABOVE GRANULAR BED AND SURROUND.
 - 10) BEDDING AND BACKFILL MATERIAL TO CONFORM TO REQUIREMENT OF WATER INDUSTRY SPECIFICATION 4-08-02 (TABLE A2).
 - 11) THE CHAMBER SIZE OF MANHOLES WITH MORE THAN ONE CONNECTION IN THEM MAY NEED TO BE INCREASED AN INCREMENT TO ACCOMMODATE THE CONNECTIONS AND BENDS.
 - 12) YORKSHIRE WATER POLICY IS NOT TO ACCEPT TYPE "C" BRICK MANHOLES AND 1050mm DIA MANHOLE RINGS. INSTEAD IT IS PREFERRED THAT YOU USE A TYPE "B" MANHOLE WITH 1200mm DIA OR 1500mm DIA RINGS, WITH THE OPENING SITED OVER THE CHANNEL WHERE DEPTH OF COVER TO PIPE SOFFIT IS 1-1.5m.

Site Plan - (PROPOSED S104 PLAN)
 1 : 200

REV C:- GULLIES AMENDED ROAD CONTOURS
 REV B:- PIPE SIZES ADJUSTED
 REV A:- STORAGE TANK SIZE ADJUSTED

3D INFRASTRUCT	D Noble Limited
	Proposed Housing Development Park Avenue, Royston, Barnsley, S71 4AD
	SECTION 104 PLAN
	1 : 200 FT 22/01/2017 1000 02 REV C