


Summary of Results for 100 year Return Period (+40%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Overflow (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Overflow Volume (m ³)	Maximum Volume (m ³)	Status
15 Summer	5.0	0.0	5.0	195.6057	0.2657	0.0	27.9	O K
30 Summer	5.0	0.0	5.0	195.6942	0.3542	0.0	37.2	O K
60 Summer	5.0	0.0	5.0	195.7772	0.4372	0.0	45.9	O K
120 Summer	5.0	0.0	5.0	195.8127	0.4727	0.0	49.6	O K
180 Summer	5.0	0.0	5.0	195.8117	0.4717	0.0	49.5	O K
240 Summer	5.0	0.0	5.0	195.8012	0.4612	0.0	48.4	O K
360 Summer	5.0	0.0	5.0	195.7727	0.4327	0.0	45.4	O K
480 Summer	5.0	0.0	5.0	195.7382	0.3982	0.0	41.8	O K
600 Summer	5.0	0.0	5.0	195.7002	0.3602	0.0	37.8	O K
720 Summer	5.0	0.0	5.0	195.6632	0.3232	0.0	33.9	O K
960 Summer	5.0	0.0	5.0	195.5983	0.2582	0.0	27.1	O K
1440 Summer	4.8	0.0	4.8	195.5152	0.1752	0.0	18.4	O K
2160 Summer	4.2	0.0	4.2	195.4532	0.1133	0.0	11.9	O K
2880 Summer	3.7	0.0	3.7	195.4247	0.0848	0.0	8.9	O K
4320 Summer	2.8	0.0	2.8	195.4017	0.0617	0.0	6.5	O K
5760 Summer	2.3	0.0	2.3	195.3882	0.0482	0.0	5.1	O K
7200 Summer	1.9	0.0	1.9	195.3792	0.0392	0.0	4.1	O K
8640 Summer	1.7	0.0	1.7	195.3732	0.0332	0.0	3.5	O K
10080 Summer	1.5	0.0	1.5	195.3687	0.0287	0.0	3.0	O K
15 Winter	5.0	0.0	5.0	195.6497	0.3097	0.0	32.5	O K
30 Winter	5.0	0.0	5.0	195.7527	0.4127	0.0	43.3	O K
60 Winter	5.0	0.0	5.0	195.8407	0.5007	0.0	52.6	O K
120 Winter	5.0	0.0	5.0	195.8817	0.5417	0.0	56.9	O K
180 Winter	5.0	0.0	5.0	195.8777	0.5377	0.0	56.5	O K
240 Winter	5.0	0.0	5.0	195.8617	0.5217	0.0	54.8	O K


Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
15 Summer	89.23	17
30 Summer	61.54	32
60 Summer	40.51	62
120 Summer	25.63	98
180 Summer	19.23	132
240 Summer	15.63	166
360 Summer	11.65	236
480 Summer	9.44	304
600 Summer	8.01	370
720 Summer	7.00	434
960 Summer	5.65	550
1440 Summer	4.17	780
2160 Summer	3.07	1128
2880 Summer	2.46	1472
4320 Summer	1.81	2204
5760 Summer	1.45	2936
7200 Summer	1.23	3672
8640 Summer	1.07	4400
10080 Summer	0.95	5128
15 Winter	89.23	18
30 Winter	61.54	32
60 Winter	40.51	60
120 Winter	25.63	112
180 Winter	19.23	140
240 Winter	15.63	180

T J Booth Associates		Page 2
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+40% treck group stocksbridge car park	
Date april 2021 - revision 0 File CALC-T~4.SRC	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Summary of Results for 100 year Return Period (+40%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Overflow (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Overflow Volume (m ³)	Maximum Volume (m ³)	Status
360 Winter	5.0	0.0	5.0	195.8157	0.4757	0.0	50.0	O K
480 Winter	5.0	0.0	5.0	195.7617	0.4217	0.0	44.3	O K
600 Winter	5.0	0.0	5.0	195.7007	0.3607	0.0	37.9	O K
720 Winter	5.0	0.0	5.0	195.6407	0.3007	0.0	31.6	O K
960 Winter	5.0	0.0	5.0	195.5492	0.2092	0.0	22.0	O K
1440 Winter	4.3	0.0	4.3	195.4652	0.1253	0.0	13.1	O K
2160 Winter	3.4	0.0	3.4	195.4182	0.0783	0.0	8.2	O K
2880 Winter	2.8	0.0	2.8	195.4012	0.0612	0.0	6.4	O K
4320 Winter	2.1	0.0	2.1	195.3828	0.0427	0.0	4.5	O K
5760 Winter	1.6	0.0	1.6	195.3723	0.0322	0.0	3.4	O K
7200 Winter	1.4	0.0	1.4	195.3658	0.0257	0.0	2.7	O K
8640 Winter	1.2	0.0	1.2	195.3613	0.0212	0.0	2.2	O K
10080 Winter	1.1	0.0	1.1	195.3577	0.0178	0.0	1.9	O K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
360 Winter	11.65	256
480 Winter	9.44	330
600 Winter	8.01	398
720 Winter	7.00	456
960 Winter	5.65	568
1440 Winter	4.17	794
2160 Winter	3.07	1124
2880 Winter	2.46	1476
4320 Winter	1.81	2204
5760 Winter	1.45	2928
7200 Winter	1.23	3664
8640 Winter	1.07	4360
10080 Winter	0.95	5136

T J Booth Associates		Page 3
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+40% treck group stocksbridge car park	
Date april 2021 - revision 0 File CALC-T~4.SRC	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Rainfall Details

Region	ENG+WAL	Shortest Storm (mins)	15
Return Period (years)	100	Longest Storm (mins)	10080
M5-60 (mm)	20.000	Summer Storms	Yes
Ratio-R	0.300	Winter Storms	Yes
Cv (Summer)	0.750	Climate Change %	+40
Cv (Winter)	0.840		

Pipe Network

Volume in Pipe Network (m ³)	1	Dia of Outfall Pipe (m)	0.200
Slope of Outfall Pipe (1:x)	100.0	Roughness of Outfall Pipe	0.600

Time / Area Diagram

Total Area (ha) = 0.138

Time	(mins)	Area
from:	to:	(ha)
0	4	0.138

104 Yorkshire St
Rochdale
Lancashire OL16 1JY

attenuation 100yr+40%
treck group
stocksbridge car park

Date april 2021 - revision 0
File CALC-T~4.SRC

Designed By ds
Checked By



Micro Drainage

Source Control W.10.4

Tank/Pond Details

Invert Level (m) 195.340 Ground Level (m) 196.500

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.00	105.0	0.60	105.0	1.20	105.0	1.80	105.0	2.40	105.0
0.10	105.0	0.70	105.0	1.30	105.0	1.90	105.0	2.50	105.0
0.20	105.0	0.80	105.0	1.40	105.0	2.00	105.0		
0.30	105.0	0.90	105.0	1.50	105.0	2.10	105.0		
0.40	105.0	1.00	105.0	1.60	105.0	2.20	105.0		
0.50	105.0	1.10	105.0	1.70	105.0	2.30	105.0		

Depth / Flow Outflow Control

Invert Level of Control 195.330

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.10	3.9	0.80	5.9	2.00	9.2	4.00	13.1	7.00	17.3
0.20	5.0	1.00	6.5	2.20	9.7	4.50	13.9	7.50	17.9
0.30	4.8	1.20	7.2	2.40	10.1	5.00	14.6	8.00	18.5
0.40	4.4	1.40	7.7	2.60	10.5	5.50	15.3	8.50	19.1
0.50	4.7	1.60	8.3	3.00	11.3	6.00	16.0	9.00	19.6
0.60	5.2	1.80	8.8	3.50	12.2	6.50	16.7	9.50	20.2

Pipe Overflow Control

Pipe Diameter (m) 0.150 Entry Loss Coef 0.500
Slope (1:x) 100.0 Coef of Contraction 0.600
Length (m) 3.000 Invert Level (m) 195.890
Roughness (mm) 0.600