

iD Civils Design Ltd		Page 1
The Stables Aske Hall, Richmond N Yorkshire DL10 5HG	Brunswick Street Thurnscoe Network 3	
Date 19/08/2019 File 5022 SW Network 3.MDX	Designed by D.Lamb Checked by	
XP Solutions	Network 2018.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for 5022 SW Network 3.sws

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	2	PIMP (%)	100
M5-60 (mm)	19.000	Add Flow / Climate Change (%)	0
Ratio R	0.394	Minimum Backdrop Height (m)	0.000
Maximum Rainfall (mm/hr)	0	Maximum Backdrop Height (m)	0.000
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for 5022 SW Network 3.sws

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.026	4-8	0.001

Total Area Contributing (ha) = 0.027

Total Pipe Volume (m³) = 11.228

Network Design Table for 5022 SW Network 3.sws

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	8.196	0.400	20.5	0.027	4.00	0.0	0.600	o	150	Pipe/Conduit	
1.001	11.000	0.050	220.0	0.000	0.00	0.0	0.600	[]	-1	Pipe/Conduit	
1.002	2.000	0.150	13.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.003	2.722	0.030	90.7	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	4.06	64.100	0.027	0.0	0.0	0.0	2.24	39.5	0.0
1.001	0.00	4.16	63.700	0.027	0.0	0.0	0.0	1.79	1786.8	0.0
1.002	0.00	4.18	63.650	0.027	0.0	0.0	0.0	2.77	49.0	0.0
1.003	0.00	4.22	63.500	0.027	0.0	0.0	0.0	1.06	18.7	0.0

iD Civils Design Ltd		Page 2
The Stables Aske Hall, Richmond N Yorkshire DL10 5HG	Brunswick Street Thurnscoe Network 3	
Date 19/08/2019 File 5022 SW Network 3.MDX	Designed by D.Lamb Checked by	
XP Solutions	Network 2018.1	

Conduit Sections for 5022 SW Network 3.sws

NOTE: Diameters less than 66 refer to section numbers of hydraulic conduits. These conduits are marked by the symbols:- [] box culvert, \ / open channel, oo dual pipe, ooo triple pipe, 0 egg.

Section numbers < 0 are taken from user conduit table

Section Number	Conduit Type	Major Dimn. (mm)	Minor Dimn. (mm)	Side Slope (Deg)	Corner Splay (mm)	4*Hyd Radius (m)	XSect Area (m ²)
-1	[]	2500	400	90.0		0.690	1.000

iD Civils Design Ltd		Page 3
The Stables Aske Hall, Richmond N Yorkshire DL10 5HG		Brunswick Street Thurnscoe Network 3
Date 19/08/2019 File 5022 SW Network 3.MDX		Designed by D.Lamb Checked by
XP Solutions		Network 2018.1



Manhole Schedules for 5022 SW Network 3.sws

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam.,L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S1	64.760	0.660	Open Manhole	450	1.000	64.100	150				
S2	64.740	1.040	Open Manhole	450	1.001	63.700	-1	1.000	63.700	150	
S3	64.570	0.920	Open Manhole	450	1.002	63.650	150	1.001	63.650	-1	
S4	64.490	0.990	Open Manhole	1050	1.003	63.500	150	1.002	63.500	150	
S5	64.510	1.040	Open Manhole	450		OUTFALL		1.003	63.470	150	

Free Flowing Outfall Details for 5022 SW Network 3.sws

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.003	S5	64.510	63.470	1.900	450	0

Simulation Criteria for 5022 SW Network 3.sws

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1

Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0
Number of Online Controls 1 Number of Storage Structures 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	2	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.000	Storm Duration (mins)	30
Ratio R	0.394		

iD Civils Design Ltd		Page 4
The Stables Aske Hall, Richmond N Yorkshire DL10 5HG	Brunswick Street Thurnscoe Network 3	
Date 19/08/2019 File 5022 SW Network 3.MDX	Designed by D.Lamb Checked by	
XP Solutions	Network 2018.1	

Online Controls for 5022 SW Network 3.sws

Orifice Manhole: S4, DS/PN: 1.003, Volume (m³): 0.9

Diameter (m) 0.025 Discharge Coefficient 0.600 Invert Level (m) 63.500

iD Civils Design Ltd		Page 5
The Stables Aske Hall, Richmond N Yorkshire DL10 5HG	Brunswick Street Thurnscoe Network 3	
Date 19/08/2019 File 5022 SW Network 3.MDX	Designed by D.Lamb Checked by	
XP Solutions	Network 2018.1	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for 5022 SW Network 3.sws

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0
Number of Online Controls 1 Number of Storage Structures 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR M5-60 (mm) 19.000 Cv (Summer) 0.750
Region England and Wales Ratio R 0.394 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status ON
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720,
960, 1440, 2160, 2880, 4320, 5760, 7200, 8640,
10080
Return Period(s) (years) 100
Climate Change (%) 30

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)	Surcharged Depth (m)
1.000	S1	15 Winter	100	+30%					64.171	-0.079
1.001	S2	120 Winter	100	+30%					64.011	-0.089
1.002	S3	120 Winter	100	+30%	100/15 Summer				64.011	0.211
1.003	S4	120 Winter	100	+30%	100/15 Summer				64.011	0.361

PN	US/MH Name	Flooded Volume (m ³)	Flow / Cap. (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	S1	0.000	0.46	15.7	OK	
1.001	S2	0.000	0.00	4.7	OK	
1.002	S3	0.000	0.04	1.0	SURCHARGED	
1.003	S4	0.000	0.08	0.9	SURCHARGED	