



YorkshireWater

**Head of Planning and Transportation
Service
Barnsley Metropolitan Borough Council
PO Box 604
Barnsley
S70 9FE**

**Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY**

Tel: 0345 120 8482

**Email:
planningconsultation@yorkshirewater.co.uk**

**Your Ref: 2026/0480
Our Ref: B/01838**

9th July 2026

Dear Sir/Madam,

66 Longley Street, Barugh Green, Barnsley, S75 1NT - (BARNs) - Erection of a detached bungalow and associated works including subdivision of residential garden and alterations to parking arrangements (Custom/Self-Build)

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Yorkshire Water objects to the application due to lack of submitted proposed drainage details.

Foul Water

As our powers under the Water Industry Act are limited it is important to ensure explicit control over the approach to foul water disposal in any planning permission.

Development of the site should take place with separate systems for foul and surface water drainage. The separate systems should extend to the points of discharge to be agreed.





YorkshireWater

Surface Water

YWS encourages sustainable development, which includes ensuring appropriate surface water disposal to prevent unnecessary hydraulic loading. Volume arising from surface water flows can be many times greater than the foul flows from the same development. As a result they have the potential to use up a significant hydraulic capacity in our infrastructure. If we can minimise surface water flows entering the public sewer, we are able to significantly manage the impact of development on wastewater infrastructure and minimise the risk of flooding.

The National Planning Policy Framework (NPPF) sets out the principle of sustainable drainage, while the National Planning Practice Guidance (NPPG) and National Standards for Sustainable Drainage Systems (SuDS) establish a hierarchy for surface water disposal. This hierarchy prioritises 1. Rainwater harvesting (non-potable use) 2. Infiltration to ground 3. Discharge to above ground SW body 4. Discharge to SW sewer 5. Discharge to combined sewer. YWS seeks to promote this hierarchy in collaboration with Local Planning Authorities and developers to improve water quality and reduce flood risk.

The developer is proposing to discharge surface water to public sewer however, sustainable development requires appropriate surface water disposal.

Yorkshire Water promote the surface water disposal hierarchy, and the developer must provide evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical before considering disposal to public sewer.

The developer and LPA are strongly advised to seek comments on surface water disposal from other drainage bodies as further restrictions may be imposed.

As the proposal site is currently undeveloped, no positive surface water is known to have previously discharged to the public sewer network. Surface water discharge to the existing public sewer network must only be as a last resort and the developer is required to eliminate other means of surface water disposal.

As a last resort, and upon receipt of satisfactory evidence to confirm the reasons for rejection of other methods of surface water disposal, curtilage surface water may discharge to public sewer at a restricted rate not to exceed 3.5 litres per second.

Yours faithfully

Reuben Thornton
Town Planning Team

