



**Units 2, 3, 4 Rockingham Phase 1 Site
Land North of Dearne Valley Parkway
Barnsley**

15% CARBON REDUCTION REPORT

December 2014

Draft v2.0



Introduction

This report has been prepared by Award Energy Consultants on behalf of Harworth Estates to support the planning application for the proposed development at Dearne Valley Parkway. This report considers and evaluates the renewable technology measures utilised in order to reduce the predicted carbon emissions of the site by 15% as per Barnsley Metropolitan Borough Council's development policies for sites submitted up to 2015.

Policy Context


The following documents were considered:

Building Regulations 2013 –Part L2A sets minimum standards for fabric and energy efficiency for new build non-domestic buildings.

National Planning Policy Framework 2012 – strengthens the emphasis on sustainable development, and requires new developments to secure the highest viable resource and energy efficiency and reduction in emissions by considering Governments and other national standards.

Barnsley Metropolitan Borough Council's Policy CSP 5 – requires that all development (either new build or conversions) of 10 or more dwellings or 1000m² of non-residential floorspace will be expected to incorporate decentralised, renewable or low carbon energy sources and other appropriate design measures sufficient to reduce the development's carbon dioxide emissions by at least 15% for applications submitted up to 2015, rising to 20% for applications submitted thereafter subject to such measures being practicable and not unacceptably prejudicing the viability of the development.

Site Layout



Carbon Reduction Calculations

A set of BRUKL calculations showing compliance with Part L2a of the 2013 Building Regulations were undertaken on the design of the thermal elements and building services of each unit, using approved SBEM software.

The predicted carbon emissions produced by the proposed development were then calculated using approved SBEM software. Data was entered in line with the design team's construction specification and drawings, as per Table 1 below.

The resulting BRUKL calculations were then used to calculate the total predicted carbon emissions from the site as 84.10 KgCO₂/m²/Year. SBEM software was then used to calculate the amount of photovoltaic (PV) power required to reduce the site's carbon emissions by a minimum of 15%. It was established that the installation of 5 kWp of PV panels to appropriate roof-space will reduce carbon emissions by **16.29%**, as shown in Table 2.

Table 1

Element	2013 Building Regulations Limiting Fabric Parameters* (u-values)	Proposed Specification BER<TER (u-values)
Wall	0.35 w/m ² k	0.30 w/m ² k
Floor	0.25 w/m ² k	0.20 w/m ² k
Roof	0.25 w/m ² k	0.16 w/m ² k
Windows- Average U-value	2.2 w/m ² k	1.7 w/m ² k
Air permeability	10 m ³ /hm ²	5 m ³ /hm ²

* For U-values: See Approved Document L2a 2013 Building Regulations

Table 2

	Proposed Specification Part L2a 2013 Total Carbon Emissions (KgCO ₂ /m ² /Year)	Total Carbon Emissions with added PV (KgCO ₂ /m ² /Year)	Amount of PV (kWp)	% reduction in Carbon Emissions
Unit 2	29.4	24.8	0.75	15.65%
Unit 3	27.6	23.0	1.75	16.66%
Unit 4	27.1	22.6	2.5	16.60%
TOTAL	84.10	70.40	5	16.29%

*BRUKL documentation available on request

Carbon Reduction Measures

The following summarises the proposed carbon reduction and energy efficiency strategies that have been incorporated into the development at Dearne Valley Parkway.

- High levels of insulation across all thermal elements within the build
- High levels of air tightness to be achieved within the construction of the dwelling to reduce unnecessary heat loss
- 100% dedicated low energy lighting with photocell controls to offices and glazed stairwells/circulation areas and Passive Infra-Red controls in toilets and kitchen
- All external light fittings will be provided with energy efficient light bulbs with appropriate control systems for efficient usage
- Automatic controls to taps, low flush WCs and waterless urinals
- Materials with low Ozone Depleting Potential and Global Warming Potential are proposed compared to those with higher environmental impacts

Conclusion

This report therefore demonstrates that site-wide carbon emissions been reduced by **16.29%** through the application of 5 kWp of photovoltaics to the roofs of the proposed development. This exceeds the 15% carbon reduction requirement of Barnsley Metropolitan Borough Council's planning policy CSP5.

CAVEAT

This document has been prepared for the titled project, or named part thereof, and should not be relied upon or used for any other project or part as the case may be, without an independent check being made on it. Award Energy shall not be liable for the consequences of using this document other than for the purpose for which it was commissioned, and any user and any other person using or relying on this document for such other purpose, agrees and will be such use or reliance be taken to confirm this agreement to indemnify Award Energy for all loss of damage resulting therefrom