



PLANNING CONSULTATION RESPONSE

Application No	2025/1092
Proposal	Demolition of existing non-motorised user (NMU) bridge, and construction of replacement NMU bridge
Address	Non-motorised user (NMU) bridge over A633 Grange Lane (A633), Stairfoot, Barnsley
Date of Consultation Reply	18/08/2026
Consultee	Highway Drainage

Consultation Assessment and Justification

There are proposed drainage details shown on the FRA submitted, with the application form describing surface water discharging to "Mains", Whilst this is not very helpful in allowing me to make constructive comments, due to the limited scope of the works and the fact that the area well served by sewers, I consider that a conditional approval is appropriate in this case.

H4 - No development shall take place unless and until full surface water drainage details, have been submitted to and approved in writing by the Local Planning Authority. Thereafter no part of the development shall be occupied or brought into use until the approved scheme has been fully implemented. The scheme shall be retained throughout the life of the development unless otherwise agreed in writing with the Local Planning Authority. @ To ensure the proper drainage of the area

OBJECTION*

Defer for amends/further information*

*Delete as applicable

Consultation Suggested Conditions:

Consultation Informative(s):



BARNSLEY

Metropolitan Borough Council
