



- R1 Re-site existing column
- 'xx'A New column location
10m Galvanised steel column
with Philips City Soul Gen2
20Klm Led lantern complete with
electronic PEC
- EX'x' Replace existing column with
10m Galvanised steel column
with Philips City Soul Gen2
20Klm Led lantern complete with
electronic PEC
- 125mm Ø ducting to NPG
requirements with 600mm cover.
Sand surround and NPG duct
tape cover.

All material to comply fully with current BMBC Street lighting specification.

All lighting columns are to be provided with an inmetered single phase electrical supply via the REC cable network.
It is expected that the contractor will coordinate with the REC regarding the installation of any cable ducts they may require.

This map is reproduced from Ordnance Survey material with the permission of Ordnance Survey on behalf of the Controller of Her Majesty's Stationery Office © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. 100022264 (2009).

Rev.	By	Amendments	Date
A	NL	Kerbline amended	11/20

BARNLSLEY
Metropolitan Borough Council

Project
Market Gate Bridge Project

Drawing title
Highways Work - Midland Street Street Lighting

Scale 1:500	Drawn NL	Checked	Date Apr 2020
Drawing No. BGW2_BMB_PB_xx_PN_C_G100_0502		File	

Paul Castle Service Director, Place Directorate
Environment & Transportation (Business Unit 6)
P.O. Box 601, Westgate Plaza One, Westgate
Barnsley S70 9FA
Tel. (01226) 770770 Fax. (01226) 772222