



FLOW CONTROL DETAILS

Hydrobrake control
 SHE-0113-5500-0800-5500
 800mm head
 5.5 l/s pass on flow

TENDER

Rev	Details	Date	Drwn	Chk.
Barnsley MBC				
Cooperative Street Goldthorpe				
Flow control manhole 2				
Dwg No. : STE/24/10/06/02				
Date : 19-7-24				
Scale : Not to scale Copyright © Shaun Tonge Engineering				

**SHAUN TONGE
ENGINEERING**

11 Broomhead Road, Wombwell, Barnsley, S73 0SA.
 Mobile 07528 278070 . Email shauntongengineering@yahoo.co.uk