Contractor to check all sizes, angles, levels & dimensions on site prior to commencement of work and to report all discrepancies.

Ordinance Survey reproduction under Licence No. 40012326

line of 760 ø culvert under motorway

track

1800h TREATED CLOSE BOARDED FENCING

control kiosk

sample chamber *

150ø

80mm (NB) HD/MDPE PUMPING MAIN

1500 ø x 2500 deep DUPLEX CRUDE SEWAGE PUMPING STATION

gas tank

lamp post

KEE 1400 NuDISC outlet 800 below g.l.

750 / 2537 / 750 / 4037

3000

750 | 10.095 | 750

11.595

150ø

*exist septic tank retained as emergency storage (approx 2000g)

new MH

high level overflow

chan.

underground gas supply

rg

gi

svp

rwp

wp

wp x2

FREE ESC.

wm

SMH

chan.

rwp

DH TV

re

NOTES

1) THE CONTROL PANELS FOR THE PUMP STATION & NUDISC ARE TO BE INSTALLED AT LEAST 5.00 METRES FROM THE GAS STORAGE TANK.

2) COVERS SHOWN * TO BE FITTED WITH DOUBLE SEAL, SCREW DOWN, AIR TIGHT COVERS & FRAMES.

N

Peter Matthews and Associates
Drainage & Waste Water Engineers & Consultants

Title ENTERPRISE INNS PLC
THE OLD POST OFFICE HAIGH
PROPOSED DRAINAGE

Drawing No: P31200/U—40

Revisions: C – JUL 10 D – AUG 10 A – JUN 10 B JUL 10

Scale for A3: 1 : 200

Date: JUN 2010

Metres: 5 10 15

14 Belcombe Place, Bradford on Avon, Wiltshire, BA15 1NA
Tel: (01225) 864312 Fax: (01225) 865515
e-mail: peter@petermatthews.fsnet.co.uk