



SWS NETWORK NORTH - CATCHMENT 1						
AUTHORITY	PIPE	IMPERMEABLE AREA m2			TOTALS	
		CARRIAGEWAY / OTHER	SHARED DRIVE	HOUSE/DRIVE	AREA m2	AREA Ha
	C1	UC 10%				
YW	1.001	313	57	693	1132.3	0.113
YW	1.002	251	53	236	563.6	0.056
YW	1.003	665	203	955	1918.5	0.192
YW	1.004	331	234	796	1440.6	0.144
YW	1.005	310		832	915.2	0.123
YW	1.006	116		122	134.2	0.025
YW	1.007	150	177	280	308	0.064
YW	1.008			64	70.4	0.007
YW	1.008			0	0	0.000
YW	1.010	2157			2157	0.216
YW	2.000	552	217	805	885.5	0.165
YW	2.001	543		847	931.7	0.147
YW	2.002	140			0	0.014
YW	3.000	490	147	601	661.1	0.130
YW	3.001	132			0	0.013
YW	4.000	145		110	121	0.027
YW	4.001	376	199	604	664.4	0.124
TOTAL					1560	

DO NOT SCALE FROM THIS DRAWING

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER HBL DRAWINGS ISSUED FOR THIS PROJECT

ADOPTABLE DRAINAGE NOTES:

- THIS DRAWING IS SUBJECT TO APPROVAL BY LOCAL AUTHORITY, BUILDING CONTROL AND / OR SEWERAGE UNDERTAKER. ANY WORKS UNDERTAKEN PRIOR TO THE GRANTING OF THESE APPROVALS IS CARRIED OUT AT RISK TO OTHERS.
- PRIOR TO COMMENCING WORK ON THE DRAINAGE, ALL EXISTING DRAINS, SEWERS MANHOLES AND OUTFALLS TO REMAIN SHALL BE LOCATED, IDENTIFIED AND A CCTV CONDITION SURVEY CARRIED OUT, WHERE NECESSARY, PROTECTION TO THE EXISTING DRAINAGE INFRASTRUCTURE SHALL BE PROVIDED.
- ALL EXISTING SEWERS AND MANHOLES ABANDONED DUE TO THE PROPOSED WORKS ARE TO BE EITHER REMOVED, AND SUITABLY BACKFILLED OR GROUTED UP.
- ALL MANHOLE COVERS TO COMPLY WITH BS EN 124, AND BE KITEMARKED.
- COVER LEVELS FOR MANHOLES ARE APPROXIMATE ONLY AND SHOULD BE ADJUSTED TO MATCH SURROUNDING LEVELS.
- IN BLOCK PAVED AREAS 'INFILL' TYPE COVERS SHOULD NOT BE USED, AND FRAMES MUST BE 150MM DEEP.
- ALL MANHOLE AND DRAINAGE COVERS SHALL COMPLY WITH BS EN124, BS EN13598-1 AND HA10409. COVER STRENGTHS TO BE:-
CLASS E600 IN AREAS OF HEAVY LOADING.
CLASS D400 IN ALL TRAFFICED AREAS (ROADS, HARD SHOULDER, PARKING AREAS AND SERVICES YARDS). MANHOLE COVERS ON FOUL ONLY SEWERS SHALL BE OF LOW LEAKAGE TYPES IN ORDER TO PREVENT EXCESSIVE SURFACE WATER INGRESS.
- DRAINAGE PIPES 100MM Ø UNLESS STATED OTHERWISE. PIPES TO BE - VITRIFIED CLAY TO BS EN 295 OR CONCRETE TO BS 5911 OR UPVC PIPES TO BS EN 1452 OR THERMOPLASTIC STRUCTURED WALL PIPES COMPLYING WITH WIS 4-35-01, BSI KITEMARKED, CLASS 8KMM NOMINAL SHORT TERM RING STIFFNESS.
- ALL SEWER PIPES 300MM DIAMETER OR LARGER, TO BE CONCRETE PIPES, TO BS 5911, UNLESS NOTED OTHERWISE.
- ALL PIPES TO BE LAID WITH SOFFITS LEVEL, UNLESS NOTED OTHERWISE.
- WHERE COVER TO PIPES IS LESS THAN 1200MM UNDER CARRIAGEWAY - CONCRETE BED AND SURROUND OR CONCRETE PROTECTION SLAB IS REQUIRED.
- ALL CONCRETE TO DRAINAGE, MANHOLES BASES, SURROUNDS ETC TO BE IN ACCORDANCE WITH THE BRE SPECIAL DIGEST 1 - CONCRETE IN AGGRESSIVE GROUND, REFER TO SITE INVESTIGATION REPORT FOR SULPHATE REQUIREMENTS.
- ALL MANHOLES, PIPE TRENCHES ETC. TO BE BACKFILLED WITH IMPORTED GRANULAR FILL TO CLASS 6/4 (5% CAPPING MATERIAL) TO (SHW) TABLE 6/1 & COMPACTED IN ACCORDANCE WITH TABLE 6/4.
- ALL PIPELINES SHALL BE TESTED BOTH BEFORE AND AFTER BACKFILLING, USING EITHER AIR TEST OR WATER TEST, IN ACCORDANCE WITH BS EN 1610.
- UPON COMPLETION OF THE DRAINAGE WORKS ALL DRAINS SHALL BE FLUSHED OUT AND CCTV SURVEYED AND SHOWN TO BE FREE OF ALL SILT AND DEBRIS AND TO HAVE NO JOINT DISPLACEMENTS OR OTHER DEFECTS. A COPY OF THE WRITTEN REPORT AND VIDEO IS TO BE FORWARDED TO THE ENGINEERS FOR COMMENT. ANY DEFECTS SHALL BE ATTRIBUTABLE TO THE CONTRACTOR FOR RECTIFICATION UNLESS INDICATED OTHERWISE BY THE CCTV REPORT AND AGREED WITH THE ENGINEERS.
- ADOPTABLE DEMARCATION MANHOLES AND LATERAL DRAINS NEED TO BE CONSTRUCTED IN ACCORDANCE WITH THE CURRENT WATER UKWRC 'SEWERAGE SECTOR GUIDANCE - APPENDIX C'.
- ALL WORKS TO SEWERS/MANHOLES BEING OFFERED FOR ADOPTION OR ON EXISTING PUBLIC SEWERS SHOULD BE IN ACCORDANCE WITH 'SEWERAGE SECTOR GUIDANCE - APPENDIX C' AND THE ADOPTING WATER AUTHORITIES RECOMMENDATIONS.

KEY - PLAN

- S104 BOUNDARY
- SITE BOUNDARY
- PROPOSED S104 STORM DRAINAGE
- PROPOSED S104 COMBINED DRAINAGE

S104 DRAINAGE TO FOLLOW DESIGN AND CONSTRUCTION GUIDANCE FOR FOUL AND SURFACE WATER SEWERS OFFERED FOR ADOPTION. DETAILS PROVIDED BY WATER UK, SUBJECT TO ADOPTING AUTHORITY TECHNICAL APPROVAL.
CP = CATCHPIT
FCG = FLOW CONTROL CHAMBER

- EXISTING ASSUMED WATERCOURSE
- EXISTING HIGHWAY DRAIN ASSUMED ROUTE
- EXISTING COMBINED SEWER
- EXISTING FOUL SEWER
- EXISTING FOUL RISING MAIN

BASIN STORAGE EXTENTS, ACCESS AND MAINTENANCE ROUTE DENOTE EXTENTS OF ADOPTING AUTHORITY ADOPTION FOR BASINS

- PROPOSED CONTOURS 0.25m INTERVALS
- EARTHWORKS TIE IN POINT TO EXISTING
- IMPERMEABLE AREA - CARRIAGEWAY
- IMPERMEABLE AREA - SHARED DRIVE
- IMPERMEABLE AREA - HOUSE / DRIVE 10% URBAN CREEP APPLIED
- IMPERMEABLE AREA - ATTENUATION BASIN

PO1	06.03.26	SP	ISSUED FOR TECHNICAL APPROVAL	AC	RJ
REV.	DATE	DRAWN	DESCRIPTION	CHKD	APPRD
STATUS DESCRIPTION					STATUS
FOR TECHNICAL APPROVAL					S4

HBL Craig House, 33 Ballbrook Avenue, Manchester M20 3JG +44 (0)161 432 9977 | www.hbl.tld Consulting Civil & Structural Engineers

PROJECT: WOOLLEY COLLIERY

DRAWING TITLE: SECTION 104 CONTRIBUTING AREAS PLAN NORTH CATCHMENT

CLIENT: MJ GLEESON

HBL REF.	DATE	SCALE(S)	A1
10701	OCT 25	1:500	
DRAWN	CHECKED	APPROVED	
RJ	RJ	RJ	

DRAWING No. 10701-HBL-XX-XX-DR-C-5505 REV. P01