



YorkshireWater

Capita Property and Infrastructure
Omnia One Queen Street
Sheffield
S1 2DU

FAO Jonathon Lloyd

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0845 120 8482
Fax: (01274) 372 834

Email:
Technical.Sewerage@yorkshirewater.co.uk

Your Ref:
Our Ref: Q009820

For telephone enquiries ring:
Kashif Khan on (0845)120 8482

1st July 2014

Dear Sir,

Carrington Avenue, Barnsley - Pre-Planning Sewerage Enquiry on P455000

Thank you for your recent enquiry and remittance. Our official VAT receipt has been sent to you under separate cover. Please find enclosed a complimentary extract from the Statutory Sewer Map which indicates the recorded position of the public sewers. Please note that as of October 2011 and the private to public sewer transfer, there are many uncharted Yorkshire Water assets currently not shown on our records.

The following comments reflect our view, with regard to the public sewer network only, based on a 'desk top' study of the site and are valid for a maximum period of twelve months:

The local Waste Water Treatment Works (WWTW) is Lundwood. It is understood that this WWTW may only have limited spare capacity, if any, available. We have contacted the respective treatment team for more information regarding the impact of proposed development and will contact you when an assessment has been made.

Development of the site should take place with separate systems for foul and surface water drainage. The separate systems should extend to the points of discharge to be agreed.

Foul water domestic waste should discharge to the 375 mm diameter public combined sewer recorded in Honeywell Lane, at a point adjacent to the site.

The developer's attention is drawn to Requirement H3 of the Building Regulations 2000. This establishes a preferred hierarchy for surface water disposal. Consideration should firstly be given to discharge to soakaway, infiltration system and watercourse in that priority order.

Sustainable Drainage Systems (SuDS), for example the use of soakaways and/or permeable hardstanding etc, may be a suitable solution for surface water disposal appropriate in this situation. You are advised to seek comments on the suitability of SuDS in this instance from the appropriate authorities.

As a last resort and subject to providing evidence as to why the other methods of surface water disposal have been discounted, curtilage surface water may discharge to the 450 mm diameter public surface water sewer recorded in Honeywell Lane, at a point adjacent to the site.

The surface water discharge from the site to be restricted to not greater than 5 (five) litres/second.

Please note further restrictions on surface water disposal from the site may be imposed by other parties. You are strongly advised to seek advice/comments from the Environment Agency/Land Drainage Authority, with regard to surface water disposal from the site.

Prospectively adoptable sewers and pumping stations must be designed and constructed in accordance with the WRc publication "Sewers for Adoption - a design and construction guide for developers" 6th Edition as supplemented by Yorkshire Water's requirements, pursuant to an agreement under Section 104 of the Water Industry Act 1991. An application to enter into a Section 104 agreement must be made in writing prior to any works commencing on site. Please contact our Developer Services Team (telephone 0845 120 84 82) for further information.


The public sewer network is for domestic sewage purposes. This generally means foul water for domestic purposes and, where a suitable surface water or combined sewer is available, surface water from the roofs of buildings together with surface water from paved areas of land appurtenant to those buildings. Land and highway drainage have no right of connection to the public sewer network. No land drainage to be connected/discharged to public sewer.

There are no properties on the DG5 (sewer flooding) Register in the vicinity of the site and there is no record of sewer flooding in the area on our operational systems.

Any new connection to an existing public sewer will require the prior approval of Yorkshire Water. You may obtain an application form from our website (www.yorkshirewater.com) or by telephoning 0845 120 84 82.

All the above comments are based upon the information and records available at the present time. The information contained in this letter together with that shown on any extract from the Statutory Sewer Map that may be enclosed is believed to be correct and is supplied in good faith. Please note that capacity in the public sewer network is not reserved for specific future development. It is used up on a 'first come, first served' basis. You should visit the site and establish the line and level of any public sewers affecting your proposals before the commencement of any design work.

Yours faithfully



Developer Services Team