


- Key**
- 1 Standard scaffold poles
  - 2 Heavy gauge 2 m tall galvanized tube and welded mesh infill panels
  - 3 Panels secured to uprights and cross-members with wire ties
  - 4 Ground level
  - 5 Uprights driven into the ground until secure (minimum depth 0.6 m)
  - 6 Standard scaffold clamps

An example of default protective fencing, in line with BS 5837:2012, that should be used on this site. Further details can be found within the submitted AIA Ref: AR-7641-02, paragraphs 4-7.



**Brooks Ecological**  
Grounded advice

Email: vb@brooks-ecological.co.uk  
Tel No: 01943 884 451  
www.brooks-ecological.co.uk

---






**DR-7641-02 TREE PROTECTION PLAN**

Site: Land at Goldthorpe, Barnsley.

---

Paper Size: A3      Scale: 1:1000

---

	TREE TO BE RETAINED
	TREE TO BE REMOVED
	Protective fencing in with BS 5837:2012 default
	ROOT PROTECTION AREA
	TREE STEM

**Please note:**  
The plan is for guidance only and should not be scaled from.

The original of this drawing was produced in colour - a monochrome copy should not be relied upon.

