

Yorkshire Water Consultation - No objections

Ian – see below.

Kindest Regards

Andy Dyson
Director


T: 01423 522293

D: 01423 752172

M: 07725 481902

E: andyd@topping-engineers.com

W: www.topping-engineers.com



Registered Office: Topping Engineers Ltd, Aire House, 12 Victoria Avenue, Harrogate, HG1 1ED

Company Registration Number: 06246420

Confidentially: This email and its attachments are intended for the above named only and may be confidential. If they have come to you in error you must take no action based on them, nor must you copy or show them to anyone; please reply to this email and highlight the error. Viruses: Although we have taken steps to ensure that this email and attachments are free from any virus, we advise that in keeping with good computing practice, the recipient should ensure they are actually virus free.

P Before printing, think about the environment - save paper.

From: Chris Roberts <Chris.Roberts@yorkshirewater.co.uk>

Sent: 25 September 2020 12:44

To: Andy Dyson <andyd@topping-engineers.com>

Cc: Technical Sewerage <technical.sewerage@yorkshirewater.co.uk>

Subject: RE: Barnsley - Planning Ref T020352

Hi Andy,

I would have no objection to the sites surface discharge increasing to a maximum rate of 21.9 l/s in public combined sewer.

New plans should be submitted to LPA who in turn should come to YW Formal Planning for approval of the new plans.

For future reference if the site has just gone through formal planning you need to send it to - planningconsultation@yorkshirewater.co.uk

Kind Regards



Chris Roberts
Pre-Development Technician
Developer Services
Tel: 0345 1 20 84 82

***** Please note, all correspondence must be sent to
technical.sewerage@yorkshirewater.co.uk *****

Yorkshire Water plays a key role in protecting public health and we're doing everything we can to continue to provide essential water and waste water services to customers during the Covid-19 outbreak. As a result we have decided to scale back some of our developer services activity. This is to allow colleagues from our developer services team to support frontline colleagues in delivering our core services to customers. This will mean we aren't able to respond as quickly as usual. Thank you for your patience, we will keep you updated as the situation progresses.