

THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES (EXEMPTION) (ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

Details of Applicant

Name: Northern Powergrid (Northeast) Ltd

Contact Person: Michael Chambers

Address: Adas UK Ltd
1 Haddon Street
Sherwood, Nottingham
NG5 2HN

Telephone No: 7808643320

Applicant's Ref: YC15168-MC

Date: 09/03/2015

To: The Chief Executive, Barnsley Council

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:


LOCATION: Ingbirchworth, Penistone, Sheffield

Particulars of proposed development to be completed by Applicant:

As part of reinforcement works to the existing overhead electrical network at the above; Northern Powergrid are required to carry out essential rebuild works. The works involve the renewal/rebuild of the 11kV overhead main line in situ (utilising existing pole positions) as detailed on attached plans: C1039524, C1039523 & C1039532. The newly rebuild 11kV line (red) will be reconstructed on wood poles and re-strung with new aluminium conductors (life time successors) along with works to the existing low voltage network (detailed blue) to be renewed with new ABC line (Aerial Bundled Conductor). These works are deemed as minor by The Department of Energy and Climate Change and therefore fall within the exemption regulations. ** (note this exemption does not include proposals at V1506/poles 4-8 for which separate form B consultation will be submitted or proposed underground cable along length of Bridleway/High Lane)**

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours Faithfully



For and on behalf of the Applicant