



19	LV CABLE BOX 6000 A
18	OIL LEVEL INDICATOR WITH CONTACTS
17	BUCHHOLZ COMEM BR50-2 CE N.O.
16	DEHYDRATING BREAKER COMEM EM2DB
15	CONSERVATOR
14	PLUG-IN RESIN BUSHING PP5 36/400A INTERFACE "P" ENB0180
13	MV CABLE BOX
12	NEUTRAL EARTH LINK
11	CONSERVATORE DRAIN VALVE 1" 6
10	FILLING CAP
9	PIOCH COPPER BUSHING N°44 AS 250 20 843
8	DRAIN VALVE DN15 PN10 1/2" 6
7	LIFTING LUGS
6	JACKING PADS
5	EARTHING TERMINALS FLAT TYPE Ø14
4	RATING PLATE
3	RADIATORS
2	OFF-LOAD TAP CHANGER
1	POCKET WELL 1" 6

POS	DESCRIPTION	UNIT	QTY
10100	10100 kg	2020 kg	
A2	+5 -10 % tolerance		
1:14	DYN11		
LAYOUT 4000 KVA			
EB3036.4000			
A13709			
113691			

SCALE	1:20 @ A1															
DATE	09/09/16															
DRAWN	MM															
CHECKED	SO															
APPROVED	GJ															
BARNSELEY (GRID REFERENCE : SE319081)																
33KV TRANSFORMER																
PLANNING APPLICATION NO																
ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	ISSUE	DATE	
Peak Power Connections Limited												G000237-1013-A_D12				

