



PLANNING CONSULTATION RESPONSE

Application No	2025/1095
Proposal	Air Handling Unit at Emergency Dept
Address	Barnsley Hospital
Date of Consultation Reply	14 th July 2026
Consultee	James Gardham – Pollution Control

Consultation Assessment and Justification

The applicant has submitted a noise impact assessment which has assessed the proposed sound from the air handling units.
The assessment has been carried out in accordance with BS4142:2019 and the impact has been assessed as very low.
The proposed sound levels from the air handling units are low and appear to be below current background sound levels.
Therefor Pollution Control have no objections to the application

*Delete as applicable

Consultation Suggested Conditions:

N/A

Consultation Informative(s):

N/A

Planning Obligations required:

N/A