



YorkshireWater

Head of Planning and Transportation Service
Barnsley Metropolitan Borough Council
PO Box 604
Barnsley
S70 9FE

Yorkshire Water Services
Land and Property
Western House
Western Way
Halifax Road
Bradford
BD6 2SZ

Your Ref: 2026/0579
Our Ref: B/02393

Tel:
Fax:

E-mail:
planningconsultation@yorkshirewater.co.uk

For telephone enquiries ring :
Jim McGlade on [REDACTED]

7th August 2026

Dear Sir/Madam,

Wentworth Station, 3 - 4 Station Cottages, Sheffield Road, Hoyland, Barnsley, S74 0ED - (BARNs)
Installation of domestic sewage treatment plant

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

This proposal is in an area not served by the public sewerage network. In this instance, the application should be referred to the Environment Agency and the Local Authority's Environmental Health Section for comment on private treatment facilities.

Noted that surface water disposal is to watercourse, any discharge rate to be approved by LLFA.

Yours faithfully

Jim McGlade
Town Planning Co-ordinator