

Shaun

From: Technical Sewerage <technical.sewerage@yorkshirewater.co.uk>
Sent: 17 August 2023 10:38
To: Shaun Tongue
Subject: RE: Co-operative Street, Goldthorpe, Barnsley, S63 9HN - Pre-planning Enquiry V187328

Hi Shaun,

Thank you for the additional information.

Blue Area

Agreed 4.4 l/s max to the unmapped combined sewer in Victoria Street.

Pink/Lilac Area

Agreed 5.5 l/s max to the 150 mm surface water sewer in Co-Operative Street.

Green Area

Agreed 3 l/s max to the 150 mm surface water sewer in Co-Operative Street.


Kind Regards



Chris Roberts
Pre-Development Technician
Developer Services
Tel: 0345 1 20 84 82

*******Please note we have 10 working days to respond to email enquiries*******

Did I WOW you today?
If you were happy with your service, please nominate me for a WOW! Award.



[CLICK HERE](#)