



DESIGN REVIEW

Design review by:	**	Checked by:	**
-------------------	----	-------------	----

Residual hazards:

Health, Safety & Environmental Notes

NOTES

1. Do not scale this drawing.

2. Slab Specification:
150mm thick concrete slab, RC 28/35 + 5% AEA, reinforced with 1 layer of A252 mesh in top, 50mm cover, 250mm laps to mesh. Slab on Visqueen 1200g slip membrane on 30mm compacted make up.

3. For external slab details refer to drawing 0110.

Key:

Isolation Joint

Restrained Transverse Contraction Joint

Free Transverse Contraction Joint

Restrained Longitudinal Joint

Debonded Longitudinal Joint

DWG 0111

DWG 0112

DWG 0113

DWG 0114

29.10.20	Updated slab joint layout	MM	WD	P2
30.09.20	Initial Issue	MM	WD	P1

Date	Description	By	Chk	Rev
------	-------------	----	-----	-----

ADEPT

CIVIL AND STRUCTURAL CONSULTING ENGINEERS

Web: www.adeptcsce.com

Email: inbox@adeptcsce.com

Tel: 0113 239 4518 (Leeds)

Tel: 0161 974 3620 (Manchester)

Originating Office

Project

The Glassworks
Barnsley

Title

External Slab Joint
Layout - Sheet 3 of 4

Client

Henry Boot

CONSTRUCTION

Scale @ A1	Initial author	Initial checker	Approver	Initial Date
1:100	MM	WD	PW	Sept '20

Status	Purpose	Information
S2		

Project Number	Originator	Volume	Level	Type	Role	Class	Dwg. No.	Rev.
BGW2-ACE-ZZ-ZZ-DR-C-G700-0113								P2