



Key

- Denotes 7no. - Proposed Lantern Swap for Urbis Axia 3.1 Type 'D' lantern and electronic PECU 25.8 Watts
- Denotes 4no. - Proposed 6 metre hinged steel column with Urbis Axia 3.1 Type 'E' lantern and electronic PECU 10.8 Watts
- Denotes 4no. - Proposed Lantern Swap for Urbis Axia 3.1 Type 'E' lantern and electronic PECU 8.3 Watts
- Denotes existing Columns

Notes

The Developer/Contractor is responsible for arranging the installation of any new LV mains with the DNO or a IDNO of choice

All setting out and exact positions to be agreed on site by Barnsley Council Street Lighting Design Engineer prior to start. Allow at least 2 clear working days notice to attend site. Contact via email: streetlightingdesign@barnsley.gov.uk

A double pole cut-out with 6A LST fuse must be installed into each column on the incoming supply. Any other requirements must be confirmed and accepted before the road can be adopted

New Street Lighting Columns are to be installed when the Footway / Verge is up to either Sub Base or Binder Course layers and all Edgings (Pin Kerbs) and Road Kerbs MUST be installed to establish line and level of any new Installations.

Two weeks Notice and 3 columns minimum is required for column installations.

Rev.	By	Amendments	Date

BARNLSLEY
Metropolitan Borough Council

Project

S278_GOLDTHORPE HOUSING_SCHEME

Drawing title

STREET_LIGHTING PROPOSALS

Scale	Drawn	Checked	Date
NTS	LC		APRIL_24

Drawing No.	File
SL20/117/1300	SL20-117

Paul Castle

Service Director, Environment & Transport.

Place Directorate.

Westgate Plaza, Barnsley, S70 2DR.

Tel. (01226) 773555 Fax. (01226) 772110

Based upon Ordnance Survey Digital Mapping.
With permission of the Controller of
Her Majesty's Stationery Office.
CROWN COPYRIGHT RESERVED
Unauthorised reproduction infringes
Crown Copyright and may lead to
prosecution or Civil Proceedings.
Licence No. 100022264

**PURPOSE FOR ISSUE:
DESIGN PROPOSAL**

**NOT YET ISSUED FOR
CONSTRUCTION**