

GRILLE SCHEDULE					
REF.	SIZE	TYPE	FINISH	m ³ /sec.	LOCATION
S01	450x450	2W FBD	WHITE	0,372	RETAL
S02	450x450	2W FBD	WHITE	0,372	RETAL
S03	450x450	4W FBD	WHITE	0,372	RETAL
S04	450x450	4W FBD	WHITE	0,372	RETAL
S05	450x450	4W FBD	WHITE	0,372	RETAL
S06	450x450	4W FBD	WHITE	0,372	RETAL
S07	450x450	4W FBD	WHITE	0,372	RETAL
S08	450x450	4W FBD	WHITE	0,372	RETAL
S09	450x450	4W FBD	WHITE	0,372	RETAL
S10	450x450	4W FBD	WHITE	0,372	RETAL
S11	450x450	4W FBD	WHITE	0,372	RETAL
S12	450x450	4W FBD	WHITE	0,372	RETAL
S13	450x450	4W FBD	WHITE	0,372	RETAL
S14	450x450	4W FBD	WHITE	0,372	RETAL
S15	450x450	4W FBD	WHITE	0,372	RETAL
S16	450x450	4W FBD	WHITE	0,372	RETAL
S17	228x225	4W FBD	WHITE	0,042	OFFICE
R01	595x595	EC CORE	WHITE	0,75	RETAL
R02	595x595	EC CORE	WHITE	0,75	RETAL
R03	595x595	EC CORE	WHITE	0,75	RETAL
R04	595x595	EC CORE	WHITE	0,75	RETAL
R05	595x595	EC CORE	WHITE	0,75	RETAL
R06	150x150	EDD	WHITE	0,02	BOY SCOUT
R07	150x150	EDD	WHITE	0,02	BOY SCOUT
R08	150x150	EDD	WHITE	0,02	BOY SCOUT
R09	150x150	EDD	WHITE	0,02	BOY SCOUT
R10	150x150	EDD	WHITE	0,02	BOY SCOUT
R11	150x150	EDD	WHITE	0,02	BOY SCOUT
R12	150x150	EDD	WHITE	0,02	BOY SCOUT
R13	150x150	EDD	WHITE	0,02	BOY SCOUT
R14	150x150	EDD	WHITE	0,02	BOY SCOUT
R15	150x150	EDD	WHITE	0,02	BOY SCOUT
R16	150x150	EDD	WHITE	0,02	BOY SCOUT
R17	200x200	EDD	WHITE	0,1	STAFFROOM

REF.	TYPE	MODEL	DUTY	LOCATION
H1	DIMPLEX	T360W	0.36kW	CLOAKS
H2	DIMPLEX	PLX750NC	0.75kW	WC
H3	DIMPLEX	PLX750NC	0.75kW	WC
H4	DIMPLEX	PLX2000NC	2kW	STAFFROOM

ALL HEATERS SUPPLIED, FITTED & WIRED TO ANCILLARY PANEL BY SITE ELECTRICIAN.

ELECTRICAL

ELECTRICAL

- 1) MAINS POWER REQUIRED TO WEATHERITE UNIT.
- 2) MAINS POWER REQUIRED TO MILK CHILLER CONDENSING UNIT
- 3) MAINS POWER REQUIRED TO COLDSTORE REFRIGERATION EQUIPMENT.
- 4) MAINS POWER REQUIRED TO ANCUILLARY PANEL
- 5) ALL HEATERS, THERMOSTATS FOR STAFF AREAS AND OFFICE EXTRACT FAN TO BE SPECIFIED, FITTED & WIRED TO ANCUILLARY PANEL BY SITE ELECTRICIAN.
- 6) LIGHTS AND ECO SOCKETS REQUIRED TO FIRST FLOOR PLANT AREA AND EXTERNAL PLANT AREA.
- 7) FIRE ALARM INTERLINK TO WEATHERITE BY SPECIALIST.

FOR BUILDERSWORK DETAILS PLEASE REFER TO CCN DRAWING
REF: D932-2

FOR ELEVATIONS PLEASE REFER TO CCN DRAWING REF:
D932-2

2)	A	ELEGATION "A" - "A" & "B" - "B" AMENDED TO SHOW EXTERNAL PLANT CASE.	10.10.12 A.S.
	LETTER	REVISION	DATE

CLIENT	ICELAND FROZEN FOOD PLC.
PRODUCT	ICELAND – ATHERSLEY
TITLE	PROPOSED AC LAYOUT FOR THE NEW ICELAND STORE AT ATHERS LANE, ATHERSLEY, S71 3AA.
GROUND FLOOR SALES AREA	

SHOPFITTERS DWG FILE

CCN
UK

Service Users,
Manufacturers,
Leads, LSH, SHE,
Tf: 0113 236 0033
Fax: 0113 236 0069
Email: info@ccn.co.uk
www.ccn.co.uk

**for Conditioning, Heating, Ventilation, Design, Installation
Networks & Conditioning Mechanical Services**

BES
BRIEFING & ESTIMATION
SPECIALIST

MEMBER OF THE ASSOCIATION OF
BUILDING SERVICES CONTRACTORS