

BARNESLEY COLLEGE, CHURCH STREET CAMPUS

Plant Noise Assessment



Document History

Project Document Reference: 1700866-RP-PNA-0001.

Rev	Date	Comment	Author	Checked
0	28 th August 2024	First Issue	RC	AH

Contents

1	Introduction	3
2	Site Description	4
2.1	Existing Site Location and Environment.....	4
2.2	Nearest Noise Sensitive Receptors (NSRs)	4
3	Assessment Guidance	5
3.1	Local Authority Criteria	5
3.2	BS 4142:2014 Methods For Rating and Assessing Industrial and Commercial Sound	5
4	Baseline Environmental Noise Survey	7
4.1	Measurement Location	7
4.2	Weather Conditions.....	7
4.3	Equipment	7
4.4	Measurement Results	8
5	Noise Emission Limits	9
5.1	Plant Noise Emission Limits.....	9
6	Plant Noise Assessment.....	10
6.1	Proposed Rooftop Mechanical Plant.....	10
6.1.1	Noise Impact Assessment.....	11
6.1.1	Attenuator Pressure Drops	13
7	Conclusion	14
Appendices		15
Appendix A – Glossary of Acoustic Terminology.....		16
Appendix B – Equipment Used in Environmental Noise Survey.....		19
Appendix C – Baseline Noise Survey Data		20

1 INTRODUCTION

MZA Acoustics has been appointed by G F Tomlinson & Sons Ltd on behalf of Barnsley College (the Client) to undertake a noise impact assessment due to the alterations of the rooftop mechanical plant located at Barnsley College, 49 Church Street, Barnsley, S70 2AX.

This report has been prepared to support a retrospective planning application to be submitted to Barnsley Metropolitan Borough Council (BMBC).

A baseline environmental noise survey has been undertaken at a location representative of the nearest noise sensitive receivers to the site in order to establish the prevailing background and ambient noise levels.

This report occasionally employs technical terminology. To assist the reader, a glossary of terms is presented in Appendix A.

2 SITE DESCRIPTION

2.1 Existing Site Location and Environment

Barnsley College, 49 Church Street, Barnsley, S70 2AX, hereby referred to as 'The Site', is an existing further education premises.

It is proposed to undertake renovation works to the site in order to develop new Institute of Technology (IOT) teaching spaces.

Renovation works will also be carried out on the central atrium space, removing the existing atrium ceiling, and creating three additional mezzanine floors to cater for new learning resource centre (LRC) space and café at ground floor level.

The locations of the proposed site in relation to its surroundings is presented in Figure 1.




Figure 1 – Site location and its surroundings

2.2 Nearest Noise Sensitive Receptors (NSRs)

The nearest noise sensitive premises to has been identified as Flats 1-4 33, Church Street, Barnsley, South Yorkshire, S70 2AH, residential dwelling located approximately 15 metres (at the closest point) to the east of the Site.

The other noise sensitive premises identified is the St Mary's Church, located approximately 30 metres (at the closest point) to the north of the Site.

3 ASSESSMENT GUIDANCE

3.1 Local Authority Criteria

The site is located within the local authority of Barnsley Metropolitan Borough Council (BMBC). It is understood that the BMBC assess each application on its own merit in terms of plan noise emissions near to residential or noise sensitive receptors (NSRs).

In absence of any specific planning criteria, a review of similar assessment on the BMBC planning portal shows that typically the plant noise limits are set in accordance with BS4142:2014 with the target of 5dB below the prevailing typical background noise levels.

Based on the above, the cumulative rating noise level ($L_{Ar,Tr}$) from the proposed plant shall be 5dB below the measured daytime and night-time typical background noise level ($L_{AF90,15minute}$) when measured 1m from nearest façade of the NSRs.

3.2 BS 4142:2014 Methods For Rating and Assessing Industrial and Commercial Sound

BS 4142 provides a methodology for rating and assessing sound associated with both industrial and commercial premises. The purpose of the Standard is clearly outlined in the opening section where it states that the method is appropriate for the consideration of:

- Sound from industrial and manufacturing processes;
- Sound from fixed installations which comprise mechanical and electrical plant and equipment;
- Sound from the loading and unloading of goods and materials at industrial and/or commercial premises; and
- Sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes, such as that from forklift trucks, or that from train movements on or around an industrial and/or commercial site.

The Standard is based around the premise that the significance of the noise impact of an industrial/commercial facility can be derived from the numerical subtraction of the background noise level (not necessarily the lowest background level measured, but the typical background of the receptor) from the measured/calculated rating level of the specific sound under consideration. This comparison will enable the impact of the specific sound to be concluded based upon the premise that typically “the greater this difference, the greater the magnitude of the impact”. This difference is then considered as follows:

- A difference of around +10 dB or more is likely to be an indication of a **significant adverse impact**, depending on the context.
- A difference of around +5 dB is likely to be an indication of an **adverse impact**, depending on the context.
- The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the

background sound level, this is an indication of the specific sound source having a **low impact**, depending on the context."

BS 4142 further states that "where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact" again depending upon the specific context of the site. The Standard further qualifies the assessment protocol by outlining conditions to the comparative assessment and stating that "not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact", thus implying that all sites should be assessed on their own merits and specifics.

The Standard quantifies the typical reference periods to be used in the assessment of noise, namely:

- Typical Daytime 07:00 – 23:00 1-hr assessment period
- Typical Night-time 23:00 – 07:00 15-min assessment period

The Standard also outlines methods for defining appropriate "character corrections" within the rating levels to account for tonal qualities, impulsive qualities, other sound characteristics and/or intermittency. These are:

- a. the Subjective Method,
- b. the Objective Methods for tonality; and,
- c. the Reference Method.

It is noted by the Standard that where multiple features are present the corrections should be added in a linear fashion to the specific level.

Table 1 – BS 4142 Subjective Method Rating Correction

Level of Perceptibility	Tonal Correction dB	Impulsivity Correction dB	Correction for 'other sound characteristics' dB	Intermittency Correction dB
No Perceptibility	+0	+0	Where neither tonal nor impulsive but clearly identifiable +3	If intermittency is readily identifiable +3
Just Perceptible	+2	+3		
Clearly perceptible	+4	+6		
Highly perceptible	+6	+9		

4 BASELINE ENVIRONMENTAL NOISE SURVEY

4.1 Measurement Location

Continuous unattended monitoring was undertaken between 12:00 hours on Saturday 12th November to 12:00 Tuesday 15th November 2023 to establish the prevailing noise levels during the daytime and night-time (shown as LT1 in Figure 1 below).




Figure 2 – Monitoring location and noise sensitive receptors.

At the monitoring position the microphone was mounted to a pole out of an upper floor window. As a result, the position is considered not to be in a free-field position (i.e. free of reflections from nearby surfaces). Therefore, a -3dB correction has been applied to the measurement data.

Throughout the monitoring survey, the noise climate was dominated by distant road traffic noise from the surrounding road network.

For robustness, although the NSR1 is located slightly closer to the site, the microphone was positioned to the rear of the building, overlooking the church, as the traffic along St Mary's Gate is lower and would likely experience lower background noise levels.

4.2 Weather Conditions

Weather throughout the survey was appropriate for the measurement of environmental noise, i.e. dry with windspeeds generally below 5 m/s.

4.3 Equipment

Microphones and sound level meters have been calibrated at UKAS accredited laboratories within the preceding two years, whilst field calibrators have been laboratory calibrated within the preceding 12 months.

The equipment was field calibrated prior to, and on completion of, measurement and no significant drift (<0.5 dB) in calibration was detected.

4.4 Measurement Results

The free-field unattended measured monitoring results are presented in Table 2. The long-term measurement data is presented in graphical format in Appendix C.

Table 2 – Unattended survey results (free-field, dB)

Location	Period	Equivalent Continuous Sound Level (Free-field, dB L _{Aeq,T})	Typical Background Sound Level (Free-field, dB L _{AF90,T}) ¹
LT1	Daytime (07:00 – 23:00)	57	43
	Night-time (23:00 – 07:00)	49	31
¹ The typical background noise level has been determined by analysing the measured data and selecting the lowest modal value, in accordance with the guidance in BS 4142:2014.			

5 NOISE EMISSION LIMITS

5.1 Plant Noise Emission Limits

The nearest noise sensitive premises to the plant location has been identified as Flats 1-4 33, Church Street, Barnsley, South Yorkshire, S70 2AH, residential dwellings located approximately 15 metres (at the closest point) to the east of the Site. The other noise sensitive premises identified is the St Mary's Church, located approximately 30 metres (at the closest point) to the north of the Site.

As discussed in Section 3, the cumulative rating noise level ($L_{Ar,Tr}$) from any proposed plant shall be 5dB below the measured daytime and night-time typical background noise level ($L_{AF90,15minute}$) when measured 1m from nearest façade of the NSRs.

Calculations have been undertaken to set the noise emission limits from the proposed scheme as shown in Table 3.

Table 3 – Maximum noise emissions from proposed scheme

Calculation Step	Parameter	
	Daytime (07:00 – 23:00)	Night-time (23:00 – 07:00)
Measured Typical background noise level at LT1	43 dB $L_{AF90,T}$	31 dB $L_{AF90,T}$
Correction for local authority requirement of 5dB below background	- 5 dB	- 5 dB
Façade correction	+ 3 dB	+ 3 dB
Maximum noise rating level at 1m from the façade of the noise sensitive receptor	41 dB $L_{Ar,Tr}^1$	29 dB $L_{Ar,Tr}^1$
¹ Maximum noise rating level at 1m from NSR façade should include penalties for any tonal, intermittent & impulsive plant noise characteristics in accordance with BS4142:2014.		

6 PLANT NOISE ASSESSMENT

6.1 Proposed Rooftop Mechanical Plant

The proposed and existing plant with associated noise data is presented in Table 4.

Table 4 – Proposed rooftop mechanical plant and manufacturer noise data

Plant Item		Manufacture r	Location Served	No. of items	A-weighted Sound Level [1]
PURYP600YSNW (VRF Heat Pump)		Mitsubishi	GF North / L02 North	2	70 dB L _{pA} 1m
PURYP500YNW (VRF Heat Pump)		Mitsubishi	L03 North / L02 South	2	65 dB L _{pA} 1m
PURYP550YNW (VRF Heat Pump)		Mitsubishi	L01 South	1	65 dB L _{pA} 1m
PURYP450YNW (VRF Heat Pump)		Mitsubishi	GF South / L01 North / L03 South	3	70 dB L _{pA} 1m
HRU 01	Intake	Nuaire	2 nd floor WC	1	36 dB L _{WA}
	Discharge				44 dB L _{WA}
HRU 02	Intake	Nuaire	WC Areas	1	51 dB L _{WA}
	Discharge				61 dB L _{WA}
EF 01 (Extract Fan)		Nuaire	Dishwasher Canopy	1	70 dB L _{WA}
EF 02 (Extract Fan)		Nuaire	Comms & Server Rooms	1	69 dB L _{WA}
AHU 03	Intake	Fre-sh-air	Atrium	1	82 dB L _{WA}
	Discharge				91 dB L _{WA}
AHU 04	Intake	Fre-sh-air	Teaching Spaces	1	75 dB L _{WA}
	Discharge				85 dB L _{WA}
PUHZ-ZRP250YKA3 (DX Condenser)		Mitsubishi	AHU 01 / AHU03	7	62 dB L _{pA} 1m
PUHZ-ZRP200YKA3 (DX Condenser)		Mitsubishi	AHU 02 / AHU04	5	62 dB L _{pA} 1m
PUZ-ZM50VKA2 (DX Condenser)		Mitsubishi	Server Rooms	4	46 dB L _{pA} , 1m
LGH-50RVX-E (Lossnay Unit)	Intake	Mitsubishi	Third Floor Meeting Room / LRC Office	2	34 dB L _{pA} 1.5m
	Discharge				34 dB L _{pA} 1.5m
[1] Level stated is per item.					

6.1.1 Noise Impact Assessment

New plant is to be installed on the roof of the Site in order to provide ventilation within the classrooms, atrium, offices and toilet facilities.

It is understood that the VRF located on the roof will only operate during daytime hours (07:00 – 23:00). The AHU's may run during the night (23:00 – 07:00) on a night purge routine, but this will occur without the additional condenser units. The existing condensers could operate at any time, depending on the temperature of the server rooms.

Due to the location of the plant and the presence of a boundary wall, it is assumed there will be no direct line-of-sight. Due to this, a minimum of 10 dB reduction is applied to all items of plant. In the case where there is a significant path difference the attenuation due to the barrier effect may be higher, up to a maximum of 20dB. The path difference calculation has been used to determine a more accurate barrier attenuation for noisier items of plant, so as to determine a more accurate representation of the associated noise emissions.

The nature of the plant suggests that any tonality, impulsivity or intermittency, so as to draw additional attention to the plant, is unlikely. Therefore, no noise characteristic penalties have been applied.

The cumulative noise impact of the proposed roof top plant during the daytime and night-time is presented in Table 11 and Table 12, respectively.

Table 5 – Noise impact assessment of mechanical plant to be installed on the roof (daytime).

Plant Item	Distance to NSR1 (m)	Distance to NSR2 (m)	SPL at NSR1 (L _{Ar,Tr} , dB)	SPL at NSR2 (L _{Ar,Tr} , dB)
PURYP600YSNW - 1	25	55	32	25
PURYP600YSNW - 2	25	55	32	25
PURYP500YNW - 1	25	55	27	20
PURYP500YNW - 2	25	55	27	20
PURYP550YNW	25	55	27	20
PURYP450YNW - 1	25	55	32	25
PURYP450YNW - 2	25	55	32	25
PURYP450YNW - 3	25	55	32	25
PUZ-ZM50VKA2 - 1	35	60	5	1
PUZ-ZM50VKA2 - 2	35	60	5	1
PUZ-ZM50VKA2 - 3	35	60	5	1
PUZ-ZM50VKA2 - 4	35	60	5	1
HRU01 Intake	60	67	0	0
HRU01 Discharge	60	67	0	0
HRU02 Intake	30	62	4	0
HRU02 Discharge	30	62	14	8
EF01	40	45	13	12
EF02	25	55	23	16
AHU03 Intake	25	50	17	11
AHU03 Discharge	20	40	13	7
AHU 04 Intake	35	35	10	10

Plant Item	Distance to NSR1 (m)	Distance to NSR2 (m)	SPL at NSR1 (L _{Ar,Tr} , dB)	SPL at NSR2 (L _{Ar,Tr} , dB)
AHU 04 Discharge	30	35	22	21
PUHZ-ZRP250YKA3 – 1	60	65	16	16
PUHZ-ZRP250YKA3 – 2	60	65	16	16
PUHZ-ZRP250YKA3 – 3	60	65	16	16
PUHZ-ZRP250YKA3 – 4	25	55	24	17
PUHZ-ZRP250YKA3 – 5	25	55	24	17
PUHZ-ZRP250YKA3 – 6	25	55	24	17
PUHZ-ZRP250YKA3 – 7	25	55	24	17
PUHZ-ZRP200YKA3 – 1	60	65	16	16
PUHZ-ZRP200YKA3 – 2	60	65	16	16
PUHZ-ZRP200YKA3 – 3	60	65	16	16
PUHZ-ZRP200YKA3 – 4	35	35	21	21
PUHZ-ZRP200YKA3 – 5	35	35	21	21
LGH-50RVX-E – 1	30	35	0	0
LGH-50RVX-E – 2	30	35	0	0
Cumulative Sound Pressure Level 1m from the Façade of the NSRs			41	35

Table 11 shows that the cumulative noise level at both receptors will be below the criterion of 41 dB during the daytime.

Table 12 – Noise impact assessment of mechanical plant to be installed on the roof (night time).

Plant Item	Distance to NSR1 (m)	Distance to NSR2 (m)	SPL at NSR1 (L _{Ar,Tr} , dB)	SPL at NSR2 (L _{Ar,Tr} , dB)
PUZ-ZM50VKA2 - 1	35	60	5	1
PUZ-ZM50VKA2 - 2	35	6	5	1
PUZ-ZM50VKA2 - 3	35	6	5	1
PUZ-ZM50VKA2 - 4	35	60	5	1
HRU01 Intake	60	67	0	0
HRU01 Discharge	60	67	0	0
HRU02 Intake	30	6	4	0
HRU02 Discharge	30	62	14	8
EF01	40	45	13	12
EF02	25	55	23	16
AHU03 Intake	25	50	17	11
AHU03 Discharge	20	40	13	7
AHU 04 Intake	35	35	10	10
AHU 04 Discharge	30	35	22	21
LGH-50RVX-E – 1	30	35	0	0
LGH-50RVX-E – 2	30	35	0	0
Cumulative Sound Pressure Level 1m from the Façade of the NSRs			27	24

Tables 11 and 12 show that the daytime and night time criteria for NSR1 and NSR2 are achieved (41 dB for daytime and 29 dB night time). It should be noted that these are based on the proposed layout, plant noise levels as presented in data from the design team, and proposed insertion losses for specified in-line acoustic attenuators. If any of

these details are to change then this assessment will need to be revisited. The attenuator schedule as currently proposed can be seen in Table 13.

Table 6 – Attenuator schedule for atmosphere-side noise emissions

Plant		Length (mm)	PD (Pa)	Dynamic Insertion Loss (dB)							
				63	125	250	500	1000	2000	4000	8000
AHU 03	Inlet	1200	30	5	9	17	25	30	23	18	11
	Discharge	1200	30	5	9	17	25	30	23	18	11
AHU 04	Inlet	900	30	6	9	15	18	25	15	11	8
	Discharge	900	30	6	9	14	17	23	13	10	7
HRU 01	Inlet	600	5	1	2	6	16	23	19	17	12
	Discharge	600	5	1	2	6	16	23	19	17	12
HRU 02	Inlet	600	26	1	3	6	15	25	21	19	11
	Discharge	600	5	1	2	6	15	20	15	14	10
EF 01	Discharge	900	29	3	7	13	26	37	30	26	16
EF 02	Discharge	600	5	1	2	6	16	23	19	17	12

6.1.1 Attenuator Pressure Drops

The pressure drop caused by the presence of an attenuator has the potential to produce regenerated noise, which can have an adverse impact on the overall noise level generated if not controlled.

The table shows that all atmosphere-side attenuators have a pressure drop of below 35Pa and as such will not cause any significant regenerated noise. Note that these are based on the data presented in the Allaway Acoustics attenuator schedule 95611-11295611Q2. Any changes to these may require revisiting the assessment to ensure acoustic criteria are met.

7 **CONCLUSION**

MZA Acoustics has been appointed by G F Tomlinson & Sons Ltd on behalf of Barnsley College (the Client) to undertake a noise impact assessment due to the alterations of the rooftop mechanical plant located at Barnsley College, 49 Church Street, Barnsley, S70 2AX.

This report presents to the findings of the noise impact assessment associated with mechanical plant serving the development.

Based on the data presented herein, the development will satisfy the acoustic criteria applicable to nearby noise sensitive receptors, as outlined by the local planning authority, outlined in Section 3.1.

Appendices

Appendix A – Glossary of Acoustic Terminology

Acoustics is the branch of physics concerned with the properties of sound, including ultrasound, infrasound and vibration. A scientist or engineer who works in the field of acoustics is an acoustician or acoustic engineer.

Sound can be measured by a sound level meter or other measuring system. Noise is related to a human response, and is routinely described as unwanted sound, or sound that is considered undesirable or disruptive. Care has been taken in this document to use the most relevant of these terms (whereby 'sound' is used predominantly); however, in most reference documents, and, indeed, generally, 'sound' and 'noise' are used interchangeably. Consequently, just because the term 'noise' is used doesn't necessarily mean a negative effect exists or will occur, and the context of the accompanying text should be taken into account.

Human hearing is able to respond to sound in the frequency range 20 Hz (deep bass) to 20,000 Hz (high treble), and over the audible range of 0 dB (the threshold of perception) to 140 dB (the threshold of pain).

The ear does not respond equally to different frequencies of the same magnitude, but is more responsive to mid-frequencies than to lower or higher frequencies. To quantify sound in a manner that approximates the response of the human ear, a weighting mechanism is used, which reduces the importance of lower and higher frequencies in a similar manner to human hearing.

The weighting mechanism that best corresponds to the response of the human ear (though not necessarily perfectly) is the 'A'-weighting scale. This is widely used for environmental sound measurement, and the levels are denoted as dBA, dB(A) or L_{Aeq} , L_{A90} etc. according to the metric being measured or determined (see the Definitions over leaf).

The decibel scale is logarithmic rather than linear, and hence a 3 dB increase in sound level represents a doubling of the sound energy present. Judgement of sound is subjective, but as a general guide a 10 dB increase can be taken to represent a doubling of loudness, whilst an increase in the order of 3 dB is generally regarded as the minimum difference needed to perceive a change under normal listening conditions. Where other changes occur (associated with the change in sound level), such as additional vehicle movements on a road, which can be seen, then these may result in changes in sound level being more noticeable than they might otherwise be.

Further to such visual clues, and any other non-acoustical factors that affect people's response (such as personal characteristics, and social, residential, or environmental factors), the subjective response to a sound is dependent not only upon the sound pressure level and component frequencies, but also its intermittency. Consequently, various metrics have been developed to try and correlate people's attitudes to different sounds with the sound level and its fluctuations. The metrics used in this document, as per the relevant guidance, are defined overleaf.

Ambient Sound	Sound from all sources at any given time, from both near and far. Usually measured in terms of L_{Aeq} .
A-Weighting	The unit of sound level, weighted according to the A-scale, which takes into account the increased sensitivity of the human ear at some frequencies.
Background Sound Level	The A-weighted sound pressure level that can be considered the baseline in the absence of any noise from a specific source of sound under assessment. Measured in terms of $L_{A90, T}$.
Calibration	The measurement system/ chain should be periodically calibrated, within a laboratory, against traceable calibration instrumentation, to either National Standards or as UKAS-Accredited, as required. The calibration of the system should also be checked in the field using a portable calibrator before and after each short-term measurements, and periodically for longer term monitoring.
Class 1	The Class of a sound level meter describes its accuracy as defined by the relevant international standards – Class 1 is more accurate than Class 2. The older standard IEC 60651 referred to the grade as "Type", whereas the new standard IEC 61672 refers to it as the "Class". The most accurate meters used in the field (as opposed to a laboratory) are Class 1. Class 2 meters can be used in some instances; however, MZA Acoustics use Class 1 (or Type 1) meters by default, as required by BS 4142:2014, for example.
Decibel	A scale for comparing the ratios of two quantities, including sound pressure and sound power. The difference in level between two sounds (s_1 and s_2) is given by $20 \log_{10} (s_1/s_2)$. The decibel can also be used to measure absolute quantities by specifying a reference value that fixes one point on the scale. For sound pressure, the reference value is 20 Pa.
Fast time Weighting (F)	Averaging time used in sound level meters. Defined in BS EN 61672-2:2013 Electroacoustics. Sound level meters. Pattern evaluation tests.
Free-field / Façade	Far from the presence of sound reflecting objects (except the ground), usually taken to mean at least 3.5 m away.
$L_{AF90, T}$	The A-weighted sound pressure level that is exceeded by the residual sound at the assessment location for 90% of a given time interval, T, measured using time fast time-weighting (F). Generally used to describe the 'background' sound conditions.
L_{AFmax}	The maximum A-weighted sound pressure level during a given time period. L_{max} is sometimes used for the assessment of occasional loud sounds, which may have little effect on the overall L_{eq} noise level, but could still affect the sound environment. Unless described otherwise, it is measured using the fast time-weighting (F).
$L_{eq, T}$	A sound level index called the equivalent continuous sound level over the time period T. This is the level of a notional steady sound that would contain the same amount of sound energy as the actual, possibly fluctuating, sound that was recorded. Where the value is A-weighted, it will be presented ' $L_{Aeq, T}$ ' or ' $dB A L_{eq, T}$ ', otherwise it should be an un-weighted (or linear) value.
L_p	See Sound Pressure Level.
Noise	Related to human response to sound. Unwanted sound, or sound that is considered undesirable or disruptive.
Octave Band	Frequency ranges in which the upper limit of each band is twice the lower limit. Octave bands are identified by their geometric mean frequency, or centre frequency.

Sound Power

In a specified frequency band, the rate at which acoustic energy is radiated from a source. In general, the rate of flow of sound energy, whether from a source, through an area, or into an absorber.

Sound Power Level

Of airborne sound, ten times the common logarithm of the ratio of the sound power under consideration of the standard reference power of 1 pW. Expressed in decibels.

Sound Pressure

Sound, or sound pressure, is a fluctuation in air pressure over the static ambient pressure.


Sound Pressure Level

The sound level is the sound pressure relative to a standard reference pressure of 20 Pa (20×10^{-6} Pascals) on a decibel scale.

Appendix B – Equipment Used in Environmental Noise Survey

Equipment Ref	Equipment	Type	Serial Number	Calibration Due Date
Kit E	Sound Level Meter	01dB Metravib FUSION	11703	01/07/2026
	Pre-amplifier	01dB Metravib PRE22	2138123	
	Microphone	GRAS 40CD 1/2" Pre-polarised free-field	470866	
	Calibrator	01dB Metravib CAL31	82793	30/06/2025

Appendix C – Baseline Noise Survey Data



Robbie Christie
Senior Acoustic Engineer
4th Floor, 10 Philpot Lane,
London, EC3M 8AA

M: +44 (0)7508 632019
rchristie@mzaconsult.co.uk