



Ref: MDR/J5861a

19th March 2025

KRS Steel Services Ltd

Unit 6 Meadway Industrial Estate

429 Meadway

Kitts Green

Birmingham

B33 0DX

For the attention of Mr A Marsh

Dear Sirs

Re: Pepes, 32 Peel Street, Barnsley, S70 2RE - Proposed Kitchen Supply & Extract Ventilation Systems - External Noise Assessment

Further to the receipt of your ventilation design information, we are pleased to forward our noise assessment for the proposed kitchen supply & extract ventilation systems as follows:-

We visited the site on 17/3/25 to inspect the proposed location for the proposed ventilation systems. The nearest residential windows to the proposed supply intake and extract discharge positions are the 1st & 2nd floor windows on the rear of the building. The supply intake will be approximately 1m from a 1st floor window and extract discharges will be approximately 2m from the 2nd floor window. The intended operation times for the site are assumed to be 11.00hrs to 23.00hrs. At 22.00hrs in the yard area at the of the site, behind the rear of the building, the background noise level was 47.0dB LA90 60min, a level created by road traffic in the locality.



Ref: MDR/J5861a

The instrumentation used for the noise measurements was a Rion NL-52 precision grade real time analysing sound level meter, serial number 00586905. The instrument was calibration checked before and after the measurements and seen to be calibrated correctly. Please see the attached current certificate of calibration. The noise measurements were undertaken in satisfactory weather condition, with no significant wind or precipitation.

The design criteria we advise to be applied to the proposed ventilation systems external noise to be measured at 2m distance from the extract discharge and 1m distance from the supply intake, is to be at least 10dB below the prevailing background $LA_{90\text{ t}}$ values measured on 13/3/25, equating to no more than 37dBA at the nearest windows. BS4142:2014 assessment methodology compares the background noise level with a plant rating noise level. For this site, the noise- controlled ventilation systems will have no distinct tonal characteristics or intermittency which would require correction to the plant source noise to derive a rating level. Controlling the proposed plant noise sources to be at least 10dBA below background ensures no adverse addition to the background noise level outside the nearest residential windows.

For the proposed kitchen extract ventilation system, the fan discharge silencer advised would be a splitter silencer, 20% free area, typically 1000mm wide x 850mm high x 1800mm long. The silencer should reduce the radiated discharge noise to approximately 35dBA at 2m distance.

For the proposed kitchen supply air ventilation system, the fan intake silencer would be a circular silencer with pod, typically 355mm i/d x 505mm o/d x 1065mm long. The silencer should reduce the radiated intake noise to 31dBA at 1m distance.

In addition, the fans and ductwork systems should be supported off the building structure using anti-vibration mounts/hangers to avoid vibration transmission into the structure.



Ref: MDR/J5861a

We have attached our noise level design calculation sheets and supporting information for your reference.

We trust the noise assessment meets with your approval and we remain.

Yours faithfully

A handwritten signature in black ink, appearing to read 'M D Randall', written in a cursive style.

M D Randall BSc(Eng) CEng MCIBSE MIOA





CERTIFICATE OF CALIBRATION



0653

Date of Issue: 13 November 2024

Certificate Number: UCRT24/2530

Calibrated at & Certificate issued by:

ANV Measurement Systems

Beaufort Court

17 Roebuck Way

Milton Keynes MK5 8HL

Telephone 01908 642846 Fax 01908 642814

E-Mail: info@noise-and-vibration.co.uk

Web: www.noise-and-vibration.co.uk

Acoustics Noise and Vibration Ltd trading as ANV Measurement Systems

Page 1 of 2 Pages
Approved Signatory
B. Bogdan

Customer ANV Measurement Systems
 Beaufort Court
 17 Roebuck Way
 Milton Keynes
 MK5 8HL

Order No. ANV MS HIRE
 Description Sound Level Meter / Pre-amp / Microphone / Associated Calibrator
 Identification

Manufacturer	Instrument	Type	Serial No. / Version
Rion	Sound Level Meter	NL-52	00586905
Rion	Firmware		2.0
Rion	Pre Amplifier	NH-25	87024
Rion	Microphone	UC-59	19107
Rion	Calibrator	NC-75	34334830
	Calibrator adaptor type if applicable		NC-75-022

Performance Class 1
 Test Procedure TP 10. SLM 61672-3:2013
Procedures from IEC 61672-3:2013 were used to perform the periodic tests.
 Type Approved to IEC 61672-1:2013 Yes
If YES above there is public evidence that the SLM has successfully completed the applicable pattern evaluation tests of IEC 61672-2:2013

Date Received 12 November 2024 ANV Job No. UKAS24/11824
 Date Calibrated 13 November 2024

The sound level meter submitted for testing has successfully completed the periodic tests of IEC 61672-3:2013, for the environmental conditions under which the tests were performed. As evidence was publicly available, from an independent testing organisation responsible for approving the results of pattern-evaluation tests performed in accordance with IEC 61672-2:2013, to demonstrate that the model of sound level meter fully conformed to the class 1 specifications in IEC 61672-1:2013, the sound level meter submitted for testing conforms to the class 1 specifications of IEC 61672-1:2013.

Previous Certificate	Dated	Certificate No.	Laboratory
	30 May 2023	UCRT23/1722	0653

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.



CERTIFICATE OF CALIBRATION	Certificate Number
	UCRT24/2530
UKAS Accredited Calibration Laboratory No. 0653	Page 2 of 2 Pages

Sound Level Meter Instruction manual and data used to adjust the sound levels indicated.

SLM instruction manual title	NL-52/NL-42 Description for IEC 61672-1		
SLM instruction manual ref / issue	No. 56034 21-03	Source	Rion
Date provided or internet download date	19 March 2021		
Uncertainties provided	Case Corrections Yes	Wind Shield Corrections Yes	Mic Pressure to Free Field Corrections Yes
Total expanded uncertainties within the requirements of IEC 61672-1:2013	YES		
Specified or equivalent Calibrator	Specified		
Customer or Lab Calibrator	Lab Calibrator		
Calibrator adaptor type if applicable	NC-75-022		
Calibrator cal. date	22 October 2024		
Calibrator cert. number	UCRT24/2394		
Calibrator cal cert issued by Lab	0653		
Calibrator SPL @ STP	94.02	dB	Calibration reference sound pressure level
Calibrator frequency	1000.00	Hz	Calibration check frequency
Reference level range	Single	dB	
Accessories used or corrected for during calibration -	Extension Cable & Wind Shield WS-15		
Note - The Extension Cable was used between the SLM and the pre-amp for this calibration.			

Environmental conditions during tests	Start	End	
Temperature	23.29	22.96	± 0.30 °C
Humidity	45.7	44.9	± 3.00 %RH
Ambient Pressure	102.60	102.55	± 0.03 kPa

Indication at the Calibration Check Frequency			
Initial indicated level	94.1	dB	Adjusted indicated level 94.0 dB
Uncertainty of calibrator used for Indication at the Calibration Check Frequency ±	0.10 dB		
Self Generated Noise			
Microphone installed -	Less Than	18.1	dB A Weighting
Microphone replaced with electrical input device -	UR = Under Range indicated		
Weighting	A	C	Z
	11.6 dB UR	15.7 dB UR	22.9 dB UR

Self Generated Noise reported for information only and not used to assess conformance to a requirement


The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Additional Comments The results on this certificate only relate to the items calibrated as identified above.

None

..... END


Calibrated by: B. Bogdan R 2




Lot: W02/K58 G1



Siliconcon 1000 x 850 x 1800 Length



Ref: MDR/15861



Ref: M02/5801



Design Sheet ①

32 Pool Street, BARNSLBY - KITCHEN EXTRACT DISCHARGE

L/A	63	125	250	500	1k	2k	4k	8k
EXTRACT FAN FRONT-WOODS								
63MM Fan COMPACT SWL	92	104	102	101	99	96	94	91
14m x 500p Dia	1	1	1	1	2	2	2	2
3x SCUP RAO BONAS	0	0	0	3	6	9	9	9
DISCHARGE LUCIF 0.125m ² BA	10	6	2	0	0	0	0	0
SWL @ DISCHARGE	81	97	99	97	91	85	83	80
SWL → SPL @ 2m	17	17	17	17	17	17	17	17
SPHERICAL RADIATION								
SPL @ 2m	64	80	82	80	74	68	67	63
A-WEIGHTING	-26	-16	-9	-3	0	+1	+1	-1
	38	64	73	77	74	69	68	62
		64		78		75		69
			78				76	
						80dBA		
SILICONER REQUIRED								
RDS 20/50/1800 SPLITTER	15	30	51	55	55	55	55	55
SILICONER, 20% FA, 1000mm WIDS	23	34	22	22	19	14	13	7
x 850mm HIGH x 1800mm LONG		34		25		20		14
ΔP @ 100 Pa @ 2.1m ³ /s				35			21	
* RESULTANT SPL @ 2m WITH SILICONER 35dBA *								

Ref: W07/15801



DESIGN SHEET ②

32 POOL STREET, BARNSLBY - KITCHEN SUPPLY INTAKE

	L/A	63	125	250	500	1k	2k	4k	8k
SUPPLY FROM BLTA SGL									
3SS/2-10L SWL	/		47	64	70	75	76	71	64
FILTER	/		3	3	3	3	3	3	3
1m x 3SS Ø DUCT	/		0	0	0	0	0	0	0
1 x 3SS Ø RAO BAND	/		0	0	1	2	3	3	3
INTAKE 60x60 0.36m ² GR	/		3	0	0	0	0	0	0
SWL @ INTAKE	/		41	61	66	70	69	65	58
SWL → SPL @ 1m	/		8	8	8	8	8	8	8
HOMOSPHERICAL PROPAGATION									
SPL @ 1m	/		53	53	58	62	60	57	50
'A'-WEIGHTING	/		-16	-9	-3	0	+1	+1	-1
	/		16	44	55	62	61	58	49
				44		63		63	49
					63			63	
SILENCER REQUIRED									
CPS 3SS-30 CIRCULAR	/		13	21	33	37	35	37	27
SILENCER WITH POP, 3SSmm ² /o			3	23	22	25	26	21	22
x 905mm ² /o x 1065mm Leng				23		27		27	22
					28			28	
★ RESONANT SPL _n @ 1m WITH SILENCER									

1/10/15



Fläkt Woods Limited
Technical Data Sheet
Maxfan Compac

NFAN

Quotation Number		Project Code	
Project Name		Customer	
Item Reference		Date	Wednesday, May 31, 2023
Fan Code	63 Maxfan Compac	Performance data has been derived from tests carried out in a Fläkt Woods laboratory in accordance with ISO 5801 and is specifically applicable for ducted installations. When an electronic controller is incorporated, enhanced noise noise can occur - particularly when the operating speed is well below maximum. FWL therefore recommend using an auto transformer speed controller for noise sensitive applications. If fluctuating air flow is expected when used continuously at >100%. They are not for use in the IEA at lower temperatures.	
Fan Diameter / Size	630 Size / mm	The Maxfan Compac includes a pre-programmed inverter drive to operate via 3 phase supply, offering full speed control and optimised performance.	
Fan Speed	2900 rpm	Acoustic data has been derived from tests carried out in a Fläkt Woods laboratory in accordance with BS 6841 Pt 2: 1985 / BS 6841: 1933 under ducted conditions. The single figure provided is the overall inlet sound pressure level at the specified distance under spherical, free field conditions.	
Velocity	9.6 m/s	Acoustic figures for adjusted running speeds have been interpolated and are for reference only.	
Burst Angle	12°	This offer is made subject to the latest version of our A10029 Terms and Conditions, a copy of which can be made available on request. Our lead times will be reconfirmed on receipt of manufacturing release and may be subject to change.	
Installation Type / Form of Running	C / AB (Vertical)		
Fan Casing	Long		
Required Duty	2.1m³/s @ 725 Pa (static)		
Actual Duty	2.06m³/s @ 695 Pa (static)		
Outlet Dynamic Pressure	26 Pa		
Duty Shaft Power	2.53 kW		
Max Shaft Power	2.58 kW		
Total Efficiency	56.7 %		
Motor Frame	90L (Class F)		
Motor Rating	2.94 kW (IE2)		
Fan Load Current	9.36 A		
Starting Current	52.8 A		
Motor Mounting	Flange		
Electrical Supply	230/240 Volts 50 Hz 1 Phase		
Start Type	DOL		
Motor Winding	Standard		
Enclosure	Standard All		
IP Rating	IP 57 (IEP Compliant 2015)		
IP Target	IP 50		
IMFEG Base Angle (Range)	0° / 0° - 0°		
Measurement Category	C (Static)		
VSD	N		
Fan Motor Efficiency	48.9% (2.6 m³/s @ 841 Pa)		
Motor Input Power (EIP)	3.14 kW		
SEF Value	1.48 (1.00) @ Actual Duty		
Power from mains	4.05 kW		
Energy Consumption	9150 kWh (4000 h/year)		
Running Cost / Year	£1098		
Ax Centre	1.2 kg/m / 2.20 C / 0 mm / 50% R		
Smoke Venting	Non Smoke Venting		
Product Number	F923236		

Sound Spectrum (Hz)	Overall
63 125 250 500 1k 2k 4k 8k 16k	1pA @ 1m**
91 101 100 101 99 96 92 89	107 83
Outlet* 92 104 102 101 99 96 94 91	108 83
Breakout* 87 83 76 76 74 68 75 67	87 60
Low dB re 10 ⁻¹² W	** dB(A) re 10 ⁻¹² Pa

Sound data at actual duty.

Description	Qty
Fan	
F923236 - 63 Maxfan Compac	1
Accessories	
Inverter	1
Thermistors	1

Extract from 63 Maxfan Compac

Ref: M02/J5861

Unit 1 Drocon Industrial Estate
 Birmingham, B65 9BY
 Tel: 0121 796 2112 Fax: 0121 796 2113
 Printed on: 31 May 2023

Website:
 Email: sales@nfan.co.uk
 Copyright Fläkt Group 2003 - 2020
 Selection Engine: 3.1.3.51p



Multiflow SEL

Sound Data

SINGLE Phase - 220V to 240V - 50Hz

Product Code	Sound Power Level (dB) @ Octave Band Hz								Total (dB)
	40Hz	100Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
SEL250 2-1AC									
SEL150B-1AC									
SEL315 2A-1AC									
SEL355-1AC									
SEL355-1AC									
SEL100-1-1AC									
SEL150-1-1AC									
SEL300-1-1AC									
SEL360-1-1AC									
SEL330-1-1AC									

SUPPLY FAN
SEL 355 / 2-1AC

Ref: MW/JS861