



PLANNING CONSULTATION RESPONSE

Application No	2026/0054
Proposal	Installation of a modular banking cabin
Address	LOCATION: Tesco Stores, Market Lane, Penistone, Sheffield, S36 6TS
Date of Consultation Reply	04/02/2026
Consultee	SYMAS

Consultation Assessment and Justification

The proposed development is located within a Mining Remediation Authority High Risk Planning Referral area.

The applicant has provided a Coal Mining Risk Assessment Report, dated 13th Jan 2026 by Arbtech.

In summary the report concludes mining legacy risks are low and the proposal can proceed with the adoption of suitable foundation solutions to mitigate residual risks.
SYMAS concurs with this approach and has no objection to planning approval.

If planning permission is granted it is recommended that the Mining Remediation informative note is attached to the decision notice.

NO OBJECTION

Consultation Informative(s):

Informative Note

The proposed development lies within an area that has been defined by the Mining Remediation Authority as containing coal mining features at surface or shallow depth. These features may include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and former surface mining sites. Although such features are seldom readily visible, they can often be present and problems can occur, particularly as a result of new development taking place.

Any form of development over or within the influencing distance of a mine entry can be dangerous and raises significant land stability and public safety risks. As a general precautionary principle, the Mining Remediation Authority considers that the building over or within the influencing distance of a mine entry should be avoided. In exceptional circumstance where this is unavoidable, expert advice must be sought to ensure a suitable engineering design which takes account of all relevant safety and environmental risk factors, including mine gas and mine-water. Your attention is drawn to the Mining Remediation Authority Policy in relation to new development and mine entries available at:

Building on or within the influencing distance of mine entries - GOV.UK

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Mining Remediation Authority Permit. Such activities could include site investigation boreholes, excavations for foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Application forms for Mining Remediation Authority permission and further guidance can be obtained from The Mining Remediation Authority's website at: www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property



BARNSLEY

Metropolitan Borough Council

What is a permit and how to get one? - GOV.UK (www.gov.uk)

In areas where shallow coal seams are present caution should be taken when carrying out any on site burning or heat focused activities.

If any future development has the potential to encounter coal seams which require excavating, for example excavation of building foundations, service trenches, development platforms, earthworks, non-coal mineral operations, an Incidental Coal Agreement will be required. Further information regarding Incidental Coal Agreements can be found here -

<https://www.gov.uk/government/publications/incidental-coal-agreement/guidance-notes-for-applicants-for-incidental-coal-agreements>

If any coal mining features are unexpectedly encountered during development, this should be reported immediately to the Mining Remediation Authority on 0800 288 4242. Further information is available on the Mining Remediation Authority website at: Mining Remediation Authority - GOV.UK

Planning Obligations required:

N/A