Warehouse

Beever Street

MELTONFIELD

SHAFTON GATE

Ward Bdy

Dismantled Railway

RETAINING WALL ON DEEP FILL ASSUMED. TRIAL PIT REQUIRED PLUS STRUCTURAL DESIGN

WALL BUILT ON MADE GROUND. CONSIDER BATTERS?

Move Back to lift plot ?

Kerb alignment poor. May require some alteration to existing kerb?

Pipe ends to be accurately located

Private SW and FW sewers not used

Proximity of road end to embankment pulls plots 67,72 down. Road end should not be raised above existing levels.

Geotechnical consultant to verify stability of existing embankment due to proximity of road.

Batter slope to be agreed with highways and Geotechnical consultant due to possible issues with imposing loads to top of slope.

Pipe ends to be accurately located. Private pipes to be subject to S102 agreement or rebuild sewers to include in S104.

HEAD OF S104 SYSTEM

Downstream section 104 system will need to be adopted prior to Countryside site adoption

Ex MH CL 45.35 IL ?

Ex MH CL 44.72 IL ?

Ex MH CL 48.76 IL 47.03

Ex MH CL 48.76 IL 45.54

Ex MH CL 48.79 IL 47.25

Ex MH CL 48.72 IL 45.32

Ex MH CL 48.57 IL 46.79

Ex MH CL 48.58 IL 43.86

Ex MH CL 47.61 IL 45.66

Ex MH CL 42.13 IL 44.89

Ex MH CL 45.06 IL 40.86

Ex MH CL 45.07 IL 42.70

Ex MH CL 45.05 IL 42.02

CL 48.96 IL 46.10

CL 49.20 IL 45.90

CL 48.50 IL 47.00

CL 48.96 IL 46.58

CL 49.20 IL 45.25

CL 48.75 IL 47.10

CL 48.27 IL 46.60

CL 49.67 IL 47.08

CL 49.65 IL 48.05

CL 46.50 IL 44.60

CL 46.50 IL 44.20

CL 45.20 IL 43.32

CL 45.20 IL 42.65

CL 44.60 IL 43.20

CL 45.00 IL 42.75?

CL 44.70 IL 42.80?

CL 44.70 IL 41.20?

1 7 10 2 12 2 10 12 15 11 19

Health and Safety Notes/CDM Regulations 2007

In line with the above regulations we are obliged to inform the Contractor of the abnormal risks that may be encountered in the construction of these works. In addition to these risks the Contractor is solely responsible to carry out full consideration and these are observed within the designs viewed on this document. Although considerable effort is undertaken to eliminate risks, the very nature of the project gives rise to some hazards and risks.

Significant risks that cannot be eliminated by design and could not be foreseen by a competent contractor are noted in the risk assessment boxes on the drawings.

LEGEND

- Proposed foul water manhole and sewer.
- Proposed surface water manhole and sewer.
- Proposed surface water lateral drain.
- Proposed foul water lateral drain.
- Proposed retaining wall.
- Proposed additional facing bricks below DPC.
- [13.35] Proposed D.P.C. level.
- +00.00 Proposed ground level.
- Existing ground level.
- Proposed street lighting.
- Construction/Commercial/Design Risk
- +0.45 Underbuild (difference between existing and proposed GL).
- -0.45 Cut (difference between existing and proposed GL).

Rev	Description	By	Date

Client:

Countryside Properties

Project Title:

Goldthorpe

Drawing Title:

Engineering Feasibility
External Works sheet 2

Scale	Date
1:250 @ A0	August 2019
Drawing No	Revision / Status
5003-C-D10-03	0 / Draft

iD Civils Design Consulting Engineers

Geo Structures Civils

North East & Yorkshire:
Aske Stables, Aske, Richmond, North Yorkshire, DL10 5NG
t: 01748 889015
f: 01565 740263

North West & Midlands:
Caledonian House, Talton Street, Knutsford, Cheshire, WA16 6AG
t: 01565 755557
f: 01565 740263