Piletec Geotechnical Ltd

Unit 3 Bramley Way, Hellaby Ind Est, Hellaby, Rotherham, South Yorkshire, S66 8QB
T: 01709 730873 F: 01709 730637 W: PILETECGEOTECHNICAL.COM

Mr Adam Slater
25 Clough Road
Hoyland
Barnsley
S74 9EA

24th October 2019

For the attention of Mr A. Slater

Clough Road, Hoyland, Barnsley

Further to your instruction; following the drilling works on your Clough Road project at Hoyland, South Yorkshire, please find attached the following documentation;

- Drilling Log/Indicative Borehole Plan
- Coal Authority Information

We can confirm that the drilling and grouting works have been completed in accordance with the Coal Authority Permit Certificate, numbered 19006.

A water flush medium was used to drill each of the boreholes identified on the borehole plan. The drillers interpretation of the strata can be found on the drillers logs attached to this document. Boreholes across the site were drilled from existing ground level to a maximum depth of thirty metres, borehole one drilled to thirty metres and boreholes two and three drilled to twelve metres.

Gas monitoring was carried out at regular intervals during the works, monitoring was taken both prior to and during the drilling works from ground level at the location of the boreholes. The gas monitor used was a MSA Personal Gas Detector, suitable for monitoring CO, H2S, O2, SO2 and NO2 gases. No gases were recorded during the drilling works.

I trust the works have been completed to your satisfaction, should you have any queries or wish to discuss the content of our report further, please do not hesitate to contact us.

Regards,

For Piletec Geotechnical