



BARNLSLEY
Metropolitan Borough Council

GRANT OF LISTED BUILDING CONSENT

PLANNING (LISTED BUILDINGS AND
CONSERVATION AREAS) ACT 1990

PLANNING (LISTED BUILDINGS AND
CONSERVATION AREAS) REGULATIONS
1990

APPLICATION NO. 2016/0758

To Plincke
Studio 1.22
Waulk Mill
Bengal Street
Manchester
M4 6LN

Proposal: Works within grounds of Cannon Hall including restoration of Deer Shelter, repairing and access works to Ice House, formation of hard standing amendments to forecourt, south terrace and footpaths, restoration and amendment to walled garden including new entrance, removal of cart sheds and wall section, amendment to Stable Yard and Gardener's Cottage, repairs to Pinery, alterations to paths and planting and recreate pond. (Listed Building Consent)


At: Cannon Hall Museum, Bark House Lane, Cawthorne, Barnsley, S75 4AT

Consent is **granted** for the proposals which were the subject of the Application and Plans registered by the Council on 24 June 2016 and described above.

The consent is subject on compliance with the following conditions:-

- 1 The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.
Reason: In order to comply with the provision of Section 91 of the Town and Country Planning Act 1990.
- 2 The development hereby approved shall be carried out strictly in accordance with the amended plans
(Nos. CHP_PLI_S2_DR_LBC_0111 (REV P02)
CHP_PLI_S2_DR_LBC_0225 (REV P02)
CHP_PLI_S2_DR_LC1_0220 (REV P02)

The grant of this consent does not constitute or imply permission, approval or consent by the Local Authority for any other purpose, whatsoever, including planning permission for the development.

Signed 
Head of Planning and Building Control

Dated 09 August 2016

CHP_PLI_S2_DR_LC4_0221 (REV P01)
CHP_PLI_S2_DR_LC4_0222 (REV P01)
CHP_PLI_S2_DR_LC4_0223 (REV P01)
CHP_PLI_S2_DR_SW2_0120 (REV P01)
CHP_PLI_S2_DR_SW1_0150 (REV P04)
CHP_PLI_S2_DR_SW1_0151 (REV P03)
CHP_PLI_S2_DR_SW1_0152 (REV P02)
CHP_PLI_S2_DR_SW4_0310 (REV P02)
CHP_PLI_S2_DR_SW3_0804 (REV P01)
CHP_PLI_S2_DR_SW5_0810 (REV P02)
2577.06

2577.07) and specifications as approved unless required by any other conditions in this permission.

Reason: In the interests of the visual amenities of the locality accordance with Core Strategy Policy CSP 29, Design.

- 3 Construction or remediation work comprising the use of plant, machinery or equipment, or deliveries of materials shall only take place between the hours of 0800 to 1800 Monday to Friday and 0900 to 1400 on Saturdays and at no time on Sundays or Bank Holidays.

Reason: In the interests of the amenities of local residents and in accordance with Core Strategy Policy CSP 40, Pollution Control and Protection.

- 4 No development shall take place, including any works of demolition, until a Construction Method Statement has been submitted to, and approved in writing by, the Local Planning Authority. The approved statement shall be adhered to throughout the construction period. The statement shall provide for:-

- The parking of vehicles of site operatives and visitors;
- Means of access for construction traffic;
- Loading and unloading of plant and materials;
- Storage of plant and materials used in constructing the development;
- Measures to prevent mud/debris being deposited on the public highway.
- Details of peak visitor times/events
- Controls for hours of delivery.

Reason: In the interests of highway safety, residential amenity and visual amenity and in accordance with Core Strategy Policy CSP 26, New Development and Highway Improvement, and CSP 29, Design.

- 5 No construction or repair work shall commence until a representative sample of any external material to be used has been submitted to, and approved in writing by, the Local Planning Authority, and the development shall proceed in strict accordance with these details as approved.

Reason: In the interests of the visual amenities of the locality and in accordance with Core Strategy Policy CSP 29, Design.

- 6 Pointing mix for new or repaired structures or sections of wall to be lime (NHL 3.5) : aggregate at a ratio of 1:3. Sand / aggregate should be well graded or river sand. Preparation of the joints will require careful removal of cement or other perished mortar by hand at a depth equal to twice that of the width. Pointing mix to be of the same colour or as close as possible to the original lime and to be finished slightly back from arms of surrounding stonework and brushed off or stippled to remove laitance, aid curing and expose aggregate to a depth of 2 or 3 mm.

Reason: In the interests of the visual amenities of the locality and in accordance with Core Strategy Policy CSP 29, Design.

- 7 All new doors (e.g. entrance to walled garden) to be used in the course of alterations shall be constructed in timber with frames mounted in at least 75mm in the reveal. Full details of their design, construction and finish (including details of surrounds and furniture) shall be submitted to and approved in writing by the local planning authority before the commencement of the relevant site works. The details shall include an elevation at 1:20 scale of each door or window type and 1:5 scale cross-sections. Development shall be carried out in accordance with the approved details.
Reason: In the interests of the visual amenities of the locality and in accordance with Core Strategy Policy CSP 29, Design.
- 8 Windows shall be repaired in situ using traditional materials and techniques and retained with all original glazing where possible. Where any new windows (e.g. cottages) are proposed details of their design, construction and finish (including details of surrounds and furniture) shall be submitted to and approved in writing by the local planning authority before the commencement of the relevant site works. The details shall include an elevation at 1:20 scale of each door or window type and 1:5 scale cross-sections. Development shall be carried out in accordance with the approved details.
Reason: In the interests of the visual amenities of the locality and in accordance with Core Strategy Policy CSP 29, Design.
- 9 All works shall proceed strictly in accordance with the recommendations, including mitigation measures set out in the Biodiversity Summary, Phase 1 Habitat survey, dated February 2016 and the Bat and Newt Survey Reports Prepared by Brooks Ecological and Access Ecology.
Reason: To ensure the works minimise impact on protected species in accordance with Policy CSP 36 of the Core Strategy.

Informative(s)

Pursuant to article 31(1)(cc) of the Town and Country Planning (Development Management Procedure) Order 2010 (as amended), the Local Planning Authority have, where possible, made a pre-application advice service available, complied with our Planning Service Charter for Business and otherwise actively engaged with the applicant in dealing with the application.

1	<p>The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to The Coal Authority on 0345 762 6848. It should also be noted that this site may lie in an area where a current licence exists for underground coal mining.</p> <p>Further information is also available on The Coal Authority website at: www.gov.uk/government/organisations/the-coal-authority</p> <p>Property specific summary information on past, current and future coal mining activity can be obtained from: www.groundstability.com</p>
2	<p>The granting of planning permission does not in any way infer that consent of the landowner is given. Therefore the consent of all relevant landowners is required before proceeding with any development including that of the Council as landowner.</p> <p>If it should transpire that the applicant does not own any of the land included in this consent then it is the responsibility of the applicant to seek all necessary consents and approvals of the landowner.</p>

NOTES:-

1. If the applicant is aggrieved by the decision of the local planning authority to refuse listed building consent for the proposed works, or to grant consent subject to conditions, he may appeal to the Secretary of State for the Environment, Transport and Regions in accordance with Sections 20 and 21 of the Planning (Listed Buildings and Conservation Areas) Act 1990 within six months of receipt of this notice. (Appeals must be made on a form which is obtainable from The Planning Inspectorate, Room 3/24 Hawk Wing, Temple Quay, 2 The Square, Temple Quay, Bristol, BS1 6PN). The Secretary of State has power to allow a longer period for the giving of a notice of appeal, but he will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of appeal.
2. If listed building consent is refused or granted subject to conditions, whether by the local planning authority or the Secretary of State for the Environment, Transport and Regions and the owner of the land claims that the land has become incapable of reasonably beneficial use in its existing state and cannot be rendered capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted, he may serve on the Council of the district a purchase notice requiring that Council to purchase his interest in the land in accordance with the provisions of Section 32 of the Planning (Listed Buildings and Conservation Areas) Act 1990.
3. In certain circumstances a claim may be made against the Local Planning Authority for compensation where permission is refused or granted subject to conditions by the Secretary of State on appeal or on a reference of the application to him. These circumstances in which such compensation is payable are set out in Section 27 of the Planning (Listed Buildings and Conservation Areas) Act 1990.

Extract from Planning (Listed Buildings and Conservation Areas) Regulations 1990.