
Demex Ltd
Risk Assessment For: Refuelling Plant and Equipment.

Demolition Risk Assessments					**REF: C600/742**		
Address Bungalow & Outbuildings, 29a Cemetery Rd, Hemmingfield, Barnsley, S73 0PU					Assessor / Author: Lee Rowbotham / Calum Hunter	Client: ETON Construction	
General RA's for works.	Reviewed by:	Lee Rowbotham		Date:	19 th-Jan-2022	Signed By:	
L = Likelihood	HP = Potential severity		R = Risk Rating	5 = High	1 = Low based on a 5 x 5 matrix.	The higher the figure the greater the severity.	

Task	**Hazard**	**Who might be harmed?**	**Initial Risk**			**Control Measure**	**Residual Risk**		
			L	**HP**	**R**		**L**	**HP**	**R**
Refuelling Vehicle/Plant and Equipment	High Temperature or Fire	Employees/Third parties or Environment.	4	5	20	Operator/end user must shut down the engine of the vehicle/plant and equipment prior to refuelling. Refuelling must take place in a well ventilated area. Ensure there are no naked flames in the area. DO NOT SMOKE. Avoid spilling the fuel and clean up any fuel run off using a spill kit. Fire extinguishers in place. Warning signs posted.	1	5	5
	Skin/Eye contact with fuel	Employees	4	3	12	Wear appropriate PPE i.e. Protective gloves, Eye protection. Adhere too COSHH assessment (section 4 of site file) Please refer to Refuelling procedures	2	3	6