



PLANNING CONSULTATION RESPONSE

Application No	2026/0420
Proposal	Erection of 10no. 2 and 3 storey detached dwellings
Address	Land west of Sheffield Road, Birdwell, Barnsley
Date of Consultation Reply	05/08/2026
Consultee	Highway Drainage

Consultation Assessment and Justification

I refer to your memo dated 5th August and would inform you I have now examined the proposals submitted by White Agus Ltd, with respect to temporary and permanent drainage of this site.

I am concerned with the location of the proposed soakaways above the motorway banking, can these be relocated within the site

OBJECTION*	Defer for amends/further information*	
-------------------	--	--

*Delete as applicable

Consultation Suggested Conditions:

Consultation Informative(s):

Planning Obligations required: