BCM Ltd
8th Floor, Portland Tower, Portland Street,
Manchester M1 3LF
Tel: 0161 228 7913 Fax: 0161 228 1788

BCM SUSTAINABLE BUILDING SERVICES DESIGN

SUSTAINABILITY STATEMENT – ATHERSLEY

The building will be modeled utilizing a Dynamic Simulation software package to demonstrate simultaneous compliance with the requirements of Part L (energy conservation) and Part F (ventilation).

The building will surpass the requirements of Part L sufficient to be awarded a minimum of 6 BREEAM points for Energy.

The design shall incorporate Heating and Cooling (where appropriate) via sustainable 'Air to Air' heat pump technology and be fully mechanically ventilated complete with highly efficient heat recovery units.