



Thornley & Lumb
Partnership Ltd.

Premier Inn Sheffield Barnsley Bedroom Extension Energy Strategy

C8826-TLP-00-XX-XX-BP-100 P01 – Energy Strategy

Project

Premier Inn Sheffield Barnsley - Bedroom Extension

Document

Energy Strategy

Client

Premier Inn Hotels Ltd.

Author

Imogen Mealy

TLP Project Reference

C8826



Thornley & Lumb Partnership Ltd.

Building Services Consultant Engineers

Century House

257 Cutler Heights Lane

Bradford

BD4 9JG

Tel: +44 (0) 1274 687 755

Email: imogen.mealy@thornleylumb.co.uk

Website: www.thornleylumb.co.uk



Document Control

Document	Energy Strategy
Project	Premier Inn Sheffield Barnsley Bedroom Extension
Client	Premier Inn Hotels Ltd.
Job Number	C8826
File Ref	C8826-TLP-00-XX-XX-BP-100 P01 – Energy Strategy
Written By	Imogen Mealy
Checked By	Thomas Clark / Martin Thornley
Revised	14.05.2024

File Ref	C8826-TLP-00-XX-XX-BP-100 P01 – Energy Strategy
Written By	Imogen Mealy
Amendments	-
Checked By	Thomas Clark / Martin Thornley
Revised	14.05.2024



Executive Summary

This Energy Strategy produced by Thornley & Lumb on behalf of Premier Inn Hotels details aspects of sustainable building design relating to energy and carbon emissions of the proposed Premier Inn Sheffield Barnsley Bedroom Extension.

The building fabric first design philosophy and efficient building services analysis are combined with the available Low and Zero Carbon (LZC) technology to provide a methodology for achieving a sustainable low energy use development. This process is illustrated by following the Energy Hierarchy which details the measures included at each stage. The Energy Hierarchy helps qualify the carbon emissions due to various measures by reporting the emission reductions at each stage.

	List of Measures Included	Regulated CO ₂ TPA	Cumulative % Reduction
Baseline	Heat pumps with notional Part L NCM efficiency Space heating = 2.64, Hot Water Services = 2.86	7.20	0.00
Be Lean	Low external envelope U-values Low air permeability Low energy LED lighting with lighting controls Mechanical ventilation with passive heat recovery (MVHR)	7.11	1.26
Be Clean	None	7.11	1.26
Be Green	Air Source Heat Pump (ASHP) hot water services (HWS) ASHP space heating to bedrooms	6.65	7.61

This Energy Strategy proposes an all-electric building services strategy due to the adverse effect on local air quality proposed by decentralised or on-site combustion building services. This will ensure lower carbon emission at present and in addition, increasingly reduced carbon emissions as the electricity grid decarbonises. Accordingly, this Energy Strategy confirms that the overall development's carbon emissions will be reduced to 6.65 CO₂ TPA which is a reduction of 7.61% below the Part L 2021 baseline.

The energy hierarchy carbon reduction methodology has minimised energy usage and carbon emissions of the proposed Premier Inn Sheffield Barnsley Bedroom Extension to provide a sustainable low energy building.




Chart to show the overall carbon reductions of the proposed extension

As Designed

Carbon Dioxide Emissions Per Annum for non-domestic Buildings

	Regulated CO ₂ TPA	Savings CO ₂ TPA	Reduction %	Cumulative Savings CO ₂ TPA	Cumulative % Reduction	Unregulated CO ₂ TPA	Unregulated Energy kWh/m ²
Baseline Part L (2021)	7.20	0.00	0.00	0.00	0.00	1.17	24.8
Including Be Lean Measures	7.11	0.09	1.26	0.09	1.26	1.17	24.8
Including Be Clean Measures	7.11	0.00	0.00	0.09	1.26	1.17	24.8
Including Be Green Measures	6.65	0.46	6.44	0.55	7.61	1.17	24.8

TPA – Tonnes Per annum

Table 6.1 - As Designed Carbon emissions of the proposed developmentAs Designed

Regulated Carbon Dioxide Savings Per Annum for non-domestic Buildings

	Tonnes CO ₂ per annum	Percentage Reduction %
Savings from Be Lean Measures	0.09	1.26
Savings from Be Clean Measures	0.00	0.00
Savings from Be Green Measures	0.46	6.44
Reduction Compared to Baseline	0.55	7.61

Table 6.2 - As Designed Carbon emission reductions of the proposed development



Contents

Document Control	3
Executive Summary.....	4
1.0 Introduction.....	7
1.1 Sustainable Low-Carbon Design.....	8
2.0 Design Considerations.....	9
2.1 Design Methodology	9
2.1.1 Energy Modelling Software	9
2.1.2 Carbon Emissions Calculations.....	9
2.2 National Planning Policy	10
2.2.1 Economic.....	10
2.2.2 Social.....	10
2.2.3 Environmental.....	10
2.2.4 Planning for Climate Change.....	10
2.3 Local Planning Policy.....	11
2.3.1 Policy CC2 – Sustainable Design and Construction	11
2.3.2 Policy RE1 – Low Carbon and Renewable Energy	11
3.0 Be Lean: Reducing Energy Demand.....	12
3.1 Building Envelope and Fabric	12
3.1.1 Thermal Properties of Building Fabric.....	12
3.1.2 Thermal Bridging.....	12
3.1.3 Proposed Fabric.....	12
3.1.4 Airtightness of Structure	13
3.1.5 Proposed Air Permeability.....	13
3.1.6 Mechanical Ventilation	14

3.1.7 Proposed Ventilation SFPs.....	14
3.1.8 Low Energy Lighting & Control	15
3.1.9 Proposed Lighting Efficiency	15
4.0 Be Clean: Analysis of Decentralised Energy	16
4.1 Heat Distribution Network	16
5.0 Be Green: Analysis of Renewable Technology.....	17
5.1 Analysis of Available Renewable Technology	17
6.0 Carbon Emissions Reductions Energy	19
6.1 Low Energy Building Design and Energy Hierarchy	19
6.2 Establishing Baseline Emissions.....	20
6.3 Be Lean	21
6.4 Be Clean.....	22
6.5 Be Green	23
6.6 Overall Carbon Reductions	24
7.0 Conclusion.....	25
Appendices.....	26
Appendix 1 Part L BRUKL report 2021 Baseline/Be Lean	26
Appendix 2 Part L BRUKL report 2021 Be Green.....	26
Appendix 3 Draft EPC.....	26
Appendix 4 Building Energy Input Datasheet	26



1.0 Introduction

The proposed Premier Inn Sheffield Barnsley bedroom extension will consist of a two-storey extension for hotel use. The extension will involve 19 bedrooms with associated plant room and linen stores at ground level.

The proposed development will be designed with sustainability as the principal design metric and accordingly this Energy Strategy will detail how energy usage and carbon emissions have been minimised using the energy hierarchy Be Lean Be Clean Be Green as developed by the Greater London Authority (GLA).

The Energy Strategy considers future electricity grid decarbonisation and uses this to influence the proposed design principles.

With the update of building regulations, Part L 2021, the decarbonisation of the Electricity Grid is now reflected in current carbon emissions calculations for Part L within accredited software, and hence grid decarbonisation will be considered when developing this Energy Strategy.

The carbon reductions detailed in this Energy Strategy have been calculated using Part L accredited compliance dynamic simulation modelling (DSM) software IES VE Compliance DSM. This ensures that the proposed development's carbon emissions have been calculated using a more sophisticated carbon calculations methodology, as opposed to the more simplistic standard SBEM methodology.

Accordingly, this Energy Strategy will detail how the proposed development will be a low carbon sustainable development by following the four energy strategy design principles as detailed in Section 1.1 Sustainable Low Carbon Design.




Figure 1.0 - The proposed development building energy model



1.1 Sustainable Low-Carbon Design

Thornley and Lumb will consider the sustainability of the proposed development and the building's energy usage throughout the design process by developing an energy strategy design philosophy. This will consist of four underlying design principles which will be implemented to ensure the sustainability of the proposed development. The principles used to develop the energy strategy are:

- Reduce demand
- Meet demand efficiently
- Supply from low carbon sources
- Supply from renewables.

Energy Strategy Design Principles

Reduce Demand

The energy demand of the building is intrinsically linked to the design of the building envelope and its services. Therefore, ensuring a thermally efficient and relatively air-tight building envelope will enable reduction in energy usage.

Meet Demand Efficiently

The application of building services which improve upon the minimum efficiencies detailed in the government's document the Non-Domestic Building Services Compliance Guide (NDBSCG), will ensure that where energy is used for servicing the building, it is used efficiently with minimal wastage.

Supply from Low Carbon Sources

Where energy is used to service the building, the carbon emissions of the source will be considered as part of the design process. This involves using carbon factors of energy sources to calculate potential carbon emissions.

Supply from Renewable Sources

The further reduction of carbon emissions will be met with energy supply from renewable sources. These are zero carbon energy sources which provide servicing for the building without increasing the carbon emissions of the building.





2.0 Design Considerations

This section discusses the design considerations for the proposed Premier Inn Sheffield Barnsley Bedroom Extension. It will detail the design methodology and detail the planning criteria established by national and local policy.

2.1 Design Methodology

The energy usage figures used in this Energy Strategy have all been calculated using industry recognised software. The geometry of the building is modelled in the software and then all fixed building service efficiencies are integrated with the model to provide energy usage figures.

2.1.1 Energy Modelling Software

The IES VE software is a dynamic building simulation modelling (DSM) application which includes industry standard thermal modelling and Part L compliance software.

The dynamic simulation model utilises partial differential equations which are based on first-principles models of conductive, convective, and radiative heat transfer. The equations used in the software are then driven by real weather data, using local climate and weather data for the specific locations. This information is then combined with the proposed building geometry and fixed building services efficiencies to calculate an hourly annual analysis of the building's energy usage.

This dynamic simulation modelling of the building allows the operational energy to be predicted at design stage. Carbon factors are then used to convert this annual operational energy into future carbon emissions of the building.

2.1.2 Carbon Emissions Calculations

Following annual energy rate calculations, the carbon factors for each fuel type then allow for a prediction of the annual carbon emission of the development. This Energy Strategy uses variable carbon factors from Part L 2021, which references Table 29 / Table 30 and Table 31 of the NCM Modelling Guide 2021 edition for Part L 2021 and is detailed in Table 2.0.

	Carbon Factor kgCO ₂ .kWh ⁻¹	Primary Energy kWhPE.kWh ⁻¹
January	0.163	1.602
February	0.160	1.593
March	0.153	1.568
April	0.143	1.53
May	0.132	1.487
June	0.120	1.441
July	0.111	1.410
August	0.112	1.410
September	0.112	1.413
October	0.136	1.449
November	0.151	1.504
December	0.163	1.558

Table 2.0 - Carbon Factor / Primary Energy Table

The carbon factors have changed in recent years due to the increasing amount of zero carbon and renewables generation used to provide grid electricity. In 2022, low and zero carbon electricity generation was 56.1% of total grid electricity.

https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/1174283/UK_Energy_in_Brief_2023.pdf



2.2 National Planning Policy

The National Planning Policy Framework (NPPF) was revised on 20th December 2023. The document details that “the purpose of the planning system is to contribute to the achievement of sustainable development”. Applications for planning permission are determined in accordance with the development plan and local planning policy. Achieving sustainable development means that the planning system has three overarching objectives, which are independent and need to be pursued in mutually supportive ways.

2.2.1 Economic

Contributing to help building a strong, responsive, and competitive economy, by ensuring that sufficient land of the right type is available in the right places and at the right time to support growth, innovation, and improved productivity; and by identifying and coordinating the provision of infrastructure.

2.2.2 Social

Supporting strong, vibrant, and healthy communities, by ensuring that a sufficient number and range of homes can be provided to meet the needs of present and future generations; and by fostering a well-designed and safe built environment, with accessible services and open spaces that reflect current and future needs and support communities' health, social and cultural well-being.

2.2.3 Environmental

Contributing to protecting and enhancing our natural, built and historic environment; including making effective use of land, helping to improve biodiversity, using natural resources prudently, minimising waste and pollution, and mitigating and adapting to climate change, including moving to a low carbon economy.

2.2.4 Planning for Climate Change

As well as the three overarching objectives above the National Planning Policy Framework includes a section entitled 'Planning for Climate Change' which states 'Plans should take a proactive approach to mitigating and adapting to climate change...'. New development should be planned for in ways that avoid increased vulnerability to the range of impacts arising from climate change and can help reduce greenhouse gas emissions.

In determining planning applications, local planning authorities should expect new development to comply with any development plan policies on local requirements for decentralised energy supply unless

it can be demonstrated by the applicant that this is not feasible and take account of landform, layout, building orientation, massing, and landscaping to minimise energy consumption.

Local planning authorities should give significant weight to the need to support energy efficiency and low carbon heating improvements to existing buildings, both domestic and non-domestic.



Department for Levelling Up,
Housing & Communities

National Planning Policy Framework

December 2023



2.3 Local Planning Policy

Sheffield Barnsley Borough Council adopted the Local Plan in January 2019. The document sets out a vision for Sheffield Barnsley up to 2033 with the foremost objective of the Plan being 'to improve the economic prosperity and quality of life for all its residents and those who work here.' Within the Government's Framework (NPPF) Barnsley plans to have 3 key roles: 'economic, social and environmental, and will deliver sustainable development.'


2.3.1 Policy CC2 – Sustainable Design and Construction

This policy states that a minimum standard of BREEAM 'Very Good' is expected for all non-residential developments. Using a rough BREEAM credit calculator the energy usage from the as design brukl, the Part L Compliance Calculations input summary document, shows the development is currently achieving 3 BREEAM Credits and a BREEAM Rating of Very Good.

The policy also outlines the Council's expectation that development proposals will 'minimise resource and energy consumption through the inclusion of sustainable design and construction features, where this is technically feasible and viable'.

2.3.2 Policy RE1 – Low Carbon and Renewable Energy

Policy RE1 requires that after appropriate design measures have been taken, developments are expected to incorporate 'decentralised, renewable or low carbon energy sources in order to reduce carbon dioxide emissions and should at least achieve the appropriate carbon compliance targets as defined in the Building Regulations.' As shown in the section 6.2, a Part L Building Regulation baseline has been established for the development using the London Plan 2021 methodology. Low Zero Carbon Technology Air Source Heat Pumps have been specified to provide hot water services and space heating/cooling for the development, this energy strategy includes details regarding the efficiency of this technology depending on the end use.





3.0 Be Lean: Reducing Energy Demand

Consideration of energy usage is an integral part of any proposed development, and each aspect of the Low Energy Building Design includes methods for conserving energy and promoting sustainability. This section of the Energy Strategy looks at how demand has been reduced by the minimum required efficiency defined by building regulations, known as the 'limiting parameter'. This minimum efficiency or limiting parameter is then compared with the Low Energy Building Design to assess the energy use of the proposed Premier Inn Sheffield Barnsley Bedroom Extension.

3.1 Building Envelope and Fabric

The energy usage of a building is intrinsically linked to the efficiency of the building envelope design, accordingly this section details how energy use is minimised by limiting conductive heat loss through following energy strategy design principles in Section 1.1 and using a Passivhaus influenced fabric first design philosophy.

The reduction of conductive heat loss through the building fabric is the most effective method of passively reducing energy usage. This can be achieved by increasing the insulation in floors, walls and roofs whilst also specifying glazing which has a high thermal resistance and by proxy a low U-value.

Building services will be replaced multiple times over the life of the building but it is less likely that the building fabric will be upgraded. Building fabric could potentially remain as built for over sixty years and as such these measures will likely payback multiple times whereas building services will generally need to be replaced much more frequently. Therefore, the reduction of U-values and the adoption of the Passivhaus design philosophy is the most effective method of reducing energy usage and carbon emissions over the full life cycle of the building.

3.1.1 Thermal Properties of Building Fabric

The energy usage of the building services associated with controlling the space temperature is dependent on the building envelope. The efficiency of the building envelope significantly affects energy usage as this is essentially a measure of how efficiently the internal building environment is thermally isolated from the external environment. The more efficient the isolation of internal from external environment, the less energy will be required for use in servicing the internal environment to meet optimum comfort levels.

3.1.2 Thermal Bridging

The proposed development has been designed to use construction details which will limit thermal bridging or cold bridges which have less resistance to heat transfer than the surrounding building envelope. Cold bridges can be the result of interruptions to the insulation in the building envelope. Where these specifically relate to windows and doors etc they are known as non-repeating or linear thermal bridges. A reduction in cold bridges through construction detailing can significantly reduce conductive heat loss through the building envelope.

3.1.3 Proposed Fabric

For this development we propose the following U Values as detailed below in Table 3.1

	Limiting Fabric Parameters W m ⁻² K ⁻¹	Proposed Low Energy Design Parameters W m ⁻² K ⁻¹	Percentage Improvement %
External Walls	0.26	0.15	42
Ground Floor	0.18	0.10	44
Roof	0.18	0.10	44
External Glazing	1.60	1.10	31

Table 3.1 Comparing the limiting fabric from Part L of the 2021 building regulations with the proposed Low Energy Design



3.1.4 Airtightness of Structure

The energy usage of the building services associated with controlling internal environment are heavily dependent on the airtightness of the building, which is essentially a measure of how efficient the building envelope is at resisting ingress of air from the external environment.

All buildings experience external air entering the building due to infiltration which is mainly due to the stack effect resulting for internal air buoyancy or external wind. These phenomena create a pressure differential over the building fabric which can result in infiltration or exfiltration through the building fabric, infiltration of external air can lead to exfiltration of internal conditioned air at another point in the building fabric reducing the ability of the building envelope to retain heat.

Ingress of air from the external environment will need to be conditioned by the building services to ensure the internal environment stays at the optimum level of comfort. Poor air tightness can result in higher operational energy costs and poor thermal comfort. Passivhaus standards specifically target very low air leakage rates associated with air-tight building to ensure operational energy is lowered and thermal comfort is improved.


Accordingly, the reduction in air permeability and thereby external air ingress will reduce the demand upon the building services conditioning the area and proportionally reduce energy usage.

3.1.5 Proposed Air Permeability

For this development we propose the following U Values as detailed below in Table 3.2

	Limiting Air Permeability $\text{m}^3 \text{ hr}^{-1} \text{ m}^{-2}$	Proposed Low Energy Design Permeability $\text{m}^3 \text{ hr}^{-1} \text{ m}^{-2}$	Percentage Improvement %
Air Permeability	8.0	4.0	50

Table 3.2 Comparing the limiting air permeability from Part L 2021 with the proposed design.



- Junctions between walls and other walls and floors
- Junctions between window frames and wall
- Electrical equipment
- Access doors and other penetrations

Common air leakage pathways indicated on a typical residential development



3.1.6 Mechanical Ventilation

Premier Inn bedrooms will use the Vectaire heat recovery ventilation unit, which ensures the heat remains in the building internal environment, despite bringing in external atmospheric 'fresh' air to improve indoor air quality for the occupants.

The heat recovery unit uses an air-to-air heat exchanger to transfer heat from the internal spaces to the incoming external air. The air paths do not cross and there is no mixing of the air. The heat exchanger enables heat recovery between air streams thereby passively warming the external air and reducing the need for mechanical heating services to use energy to increase the temperature. This can reduce the heating energy required for the building by 80%, reducing waste by ensuring less energy demand is placed on the space heating system. Air handling units use a thermal wheel (also known as a rotary heat exchanger) as an air-to-air heat exchanger. A thermal wheel consists of a circular honeycomb-like matrix of heat-absorbing material, which is rotated within the supply and exhaust streams of an air handling unit.


The Specific Fan Power (SFP) of the heat recovery ventilation unit is a measure of how efficiently the unit can supply air to the space. This consists of a ratio of electrical absorbed power to volumetric airflow rate, creating the specific fan power metric in which a lower number is more efficient.

3.1.7 Proposed Ventilation SFPs

For this development we propose the following SFPs as detailed below in Table 3.3

	Part L Limiting Values	Low Energy Design	Percentage Improvement %
Specific Fan Power (SFP) $\text{W l}^{-1} \text{s}^{-1}$	1.90	1.10	42
Heat Recovery Efficiency %	50	80	60

Table 3.3 Comparing the limiting ventilation efficiencies with the proposed Design.



A standard bedroom combined with a heat recovery ventilation unit.



3.1.8 Low Energy Lighting & Control

The energy required to illuminate the spaces of the development can be minimised by using low energy LED light fittings. These will minimise the energy and carbon emission used in artificial lighting. The artificial lighting has also been designed to incorporate lighting controls which will ensure that no electricity used for artificial lighting is wasted. This will ensure that carbon emissions are not created unnecessarily and that the building is a sustainable development.

The lighting controls

- Bedroom bathrooms – on / off control / bedroom keycard
- Circulation – Auto on / off control
- Plant – Keycard
- Store – Auto on / off control

3.1.9 Proposed Lighting Efficiency

For this development we propose the following lighting efficiency as detailed below in Table 3.4

	Limiting Lumens per Circuit Watt Lm.W^{-1}	Low Energy Design Value Lm.W^{-1}	Percentage Improvement %
Lighting Efficiency	95	110	16

Table 3.4 Comparing the limiting lighting efficiency with the proposed Low Energy Design Value





4.0 Be Clean: Analysis of Decentralised Energy

Decentralising the energy supply is important for high density developments, where the per flat or apartment application of renewable and LZC technology may have practical restrictions or offer poor lifecycle costs. The annual carbon emissions are dependent on the energy sources of the district energy scheme and each development's annual carbon emissions calculations are required to determine whether decentralised energy or grid electricity would produce lower carbon emissions.

4.1 Heat Distribution Network

Figure 4.1 shows the location of the site in relation to proposed and existing heat networks on the Heat Networks Planning Database Interactive Map. The Premier Inn Sheffield Barnsley Bedroom Extension development is located between Barnsley and Sheffield at coordinates 53°29'18"N 1°29'55"W, situated on the roundabout where the A616 meets the A61.

The location of the development is encircled in blue on Figure 4.1, roughly 6 miles from the nearest proposed heat network denoted by the orange dot northwest of Silkstone. This is the proposed CHP & Biomass Boiler network operated by Northern Powergrid Northeast Limited. Roughly 14 miles away is the other proposed heat networks in the area, the blue dot denotes a Biomass Incinerator at Badsely Moor Lane Hospital within Rotherham. The statuses of the CHP Boiler and Biomass Incinerator networks are 'Application Submitted' and 'Awaiting Construction' respectively.

Figure 4.1 illustrates that the Premier Inn Sheffield Barnsley Bedroom Extension is too far away from any proposed heat networks to viably facilitate a connection in the future. There is a wide range of choice between the proposed heat networks, the energy types of the three networks being a Gas Fired CHP Boiler and a Biomass incinerator.

The feasibility of any connection in the future should give the appropriate weight to the 'energy types' of the heat networks in question, with particular thought given to the NOx emissions caused by CHP.




Figure 4.1 Location of the development on the Heat Networks Planning Database Interactive Map



5.0 Be Green: Analysis of Renewable Technology

5.1 Analysis of Available Renewable Technology

The available renewable technology which will be considered for the proposed Premier Inn Sheffield Barnsley Bedroom Extension is detailed in the table below, along with potential benefits and any foreseeable issues. This table (Table 5.1) is provided to give a visual overview of the appropriate renewable technology and hence determine suitable renewable technology.

Technology Type	Description of Technology	Potential Benefits	Potential Issues	Valid for Application
PV Panels (Photovoltaic)	Photovoltaic solar arrays use solar radiation to create electricity, using a similar process to photosynthesis. Electrons are freed from atoms and the subsequent flow of electrons results in electric current.	Zero carbon emissions, 100% renewable technology Potential income via the SEG scheme Relatively maintenance free as no moving parts Visual impact can be low as can be placed out of sight. Noise free operation	Panels should face south and have sufficient angle to maximise capture Shadowing and detritus can lower performance over time Structure must be able to accommodate the weight of the panels. Roof access required for cleaning panels	Yes (Valid but not required)
Wind Turbine Generation	Wind turbines installed on or around the building can generate renewable electricity. This process utilises the kinetic energy of the wind to drive electricity generating alternators.	Zero carbon emissions, 100% renewable technology Potential income via the SEG scheme	Visual impact potentially high due to ideal location of installation Potential planning issues Air turbulence generates a significant amount of noise May require an impact assessment for feasibility	No (Not valid for development)
Solar Thermal Solar water heating	Solar thermal installations use solar radiation to heat water. Evacuated tubes are installed in an area of maximum solar radiation. The heat is then transferred to the water and the heated water is then used to supplement the hot water requirement of the building.	Zero carbon emissions, 100% renewable technology Relatively low maintenance as few moving parts Visual impact can be low as can be placed out of sight. Noise free operation	Tubes should face south and have sufficient angle to maximise capture Shadowing can affect energy generation performance The structure of the building must be able to accommodate the weight of the filled tubes. More benefit seen during the summer months	Yes (Valid but not recommended)
Air Source Heat Pump (ASHP) Hot Water Heating	Air source heat pumps transfer low grade thermal energy in the atmosphere for use in heating spaces or water heating.	Efficient operation utilising the low-grade heat in the atmosphere. Proven and reliable technology	Potential for leak of refrigerant with high GWP relative to CO ₂ Specialist maintained due to refrigerant handling laws External condenser fans create noise.	Yes (Valid and recommended)



Technology Type	Description of Technology	Potential Benefits	Potential Issues	Valid for Application
Air Source Heat Pump (ASHP) Space Heating	Air source heat pumps transfer low grade thermal energy in the atmosphere for use in heating spaces or water heating.	Efficient operation utilising the low-grade heat in the atmosphere. Proven and reliable technology	Potential for leak of refrigerant with high GWP relative to CO ₂ Specialist maintained due to refrigerant handling laws External condenser fans create noise.	Yes (Valid and recommended)
Ground Source Heat Pump (GSHP) Hot Water and Space Heating	Ground source heat pumps use the Earth as a heat sink and transfer low grade thermal energy from the ground for use in the building. This energy can then be used for space heating/cooling or water heating.	Efficient operation utilising low grade heat in the ground Noise free operation	Ground survey required to determine feasibility of installation.	No (Not valid for this site)
(C)CHP (Cogeneration)	A cogeneration plant is a combustion engine using natural gas or biogas fuel to drive an alternator which produces electricity. The combustion process is cooled using water as a refrigerant. Trigeneration, or combined cooling, heat and power (CCHP), is the process by which waste heat produced by the cogeneration plant is used to generate chilled water for air conditioning or refrigeration, using an absorption chiller to provide this functionality.	Efficient generation of energy, minimising losses. Potential income via the SEG scheme	Need to have sufficient, constant heat, cooling and electrical load Needs to operate for a majority percentage of the year	Yes (Valid but not recommended due carbon factor of grid electricity being significantly lower than gas fired CHP electricity generation and the NOx emissions negative impact on air quality)

Table 5.1 Detailing the Low and Zero carbon technology options available for the proposed development



6.0 Carbon Emissions Reductions Energy

6.1 Low Energy Building Design and Energy Hierarchy

The Low Energy Building Design building and services design process uses the design principles outlined in Section 1.1 to ensure the energy use of the proposed development is as low as possible and that where energy is used, as little as possible is wasted.

The design concepts used in the Low Energy Building Design has taken elements of the Passivhaus fabric first approach to the building design process. This approach significantly lowers the energy demand before the building services are considered in the design process by applying passive zero energy usage measures.

Once the energy use of the building is sufficiently minimised, low energy building services and LZC technology are then utilised in the design. This ensures the carbon targets can be met and that energy needed to provide services and control the building internal environment is minimised.

The energy strategy has shown passive and active carbon reduction measures as part of the low energy building design. The carbon reductions for these measures will now be illustrated using the Energy Hierarchy. The energy hierarchy has been developed by the GLA for The London Plan and helps illustrate carbon reductions throughout each step of the low energy building design process.

The sustainability principles outlined in Section 1.1 are used to drive the low energy design philosophy. The energy hierarchy is used to present and visualise carbon reductions. This is a carbon reduction methodology consisting of three main stages: Be Lean, Be Clean, Be Green which highlight carbon emissions from passive measures through to LZC technology.

Be Lean

The first stage in the energy hierarchy is 'Be Lean' which includes demand reduction measures designed to reduce energy usage passively.

Be Clean

The second stage in the energy hierarchy is 'Be Clean' assessment of clean energy sources district heating and CHP.

Be Green

The third and final stage is the application of renewable energy technologies.





6.2 Establishing Baseline Emissions

The baseline carbon emissions are determined by assessing the proposed development against the building regulations Part L compliance software. The regulated carbon emissions for this project have been calculated using Part L compliance software IES VE 2021 VE Compliance DSM.

This software uses the design information for the proposed development to create a notional 'target building'. The carbon emissions for the notional building are then compared with the actual building's carbon emissions. Accordingly, a compliant development is then deemed to be one which the actual emissions BER is less than or equal to the notional 'target building' carbon emissions TER.

The notional building uses standard building fabric and typical efficiency building services as detailed in the non-domestic building services compliance guide and further details in the national calculation methodology NCM for energy assessment.

The regulated carbon emissions are calculated for Part L compliance while unregulated carbon emissions for small power items like laptops, televisions and chargers are not currently assessed for Part L building regulations compliance. However, for new buildings with a total useful floor area over 1,000m² information handed over to the building owner should include a forecast of the actual energy use of the building. The energy forecast should include all metered energy uses, including unregulated loads.

The baseline carbon emissions are qualified by multiplying the TER generated using Part L compliance software and the floor area of the development. The TER has been calculated using a notional baseline development which includes heating provided by heat pumps. This will provide the baseline metric, for which all additional carbon emissions reductions are calculated against.

The baseline emissions for this building are detailed within Figure 6.1

The proposed baseline carbon emissions

The baseline carbon emission are 7.20 tonnes per annum and detailed in Figure 6.1 below and taken from Table 6.1




Figure 6.1 The baseline carbon emissions of the proposed development

The red line shows the baseline building carbon emissions TER



6.3 Be Lean

The carbon emissions baseline has been calculated as detailed in Figure 6.1. The Demand reduction phase of the energy hierarchy now uses the measures discussed in Section 3.0 to illustrate the passive measures which have enabled the development to reduce carbon emissions.

The passive measures used in the proposed development are designed to reduce energy demand without using fuel in the process. Passive measures are applied before building services or low and zero carbon technology or renewable energy are applied.

These include passive architectural design measures such as low u-value external element building fabric and low air permeability to reduce air ingress.

Passive heat recovery ventilation can keep heat in the building by recovering heat from the external air using a plate heat exchanger. This heat can then be transferred to the incoming air without mixing of air streams or increase in energy usage of the building.

Low energy LED lighting can reduce energy usage and lighting controls can further reduce energy wastage by only utilising energy for the lighting services when they are needed.

The **Passive Measures** included in the development design are summarised below and detailed in Figure 6.2

- Low external envelope U-values
- Low air permeability
- Low energy LED lighting with lighting controls
- Mechanical ventilation with passive heat recovery (MVHR)

The carbon reductions due to the Be Lean measures

The **Be Lean** measures achieve a carbon reduction emission to **7.11** tonnes per annum a reduction of **1.26%** detailed in Figure 6.2 below and taken from Table 6.1




Figure 6.2 The Be Lean carbon emissions reductions of the proposed development

The **red** line shows the baseline building carbon emissions TER

The **green** line shows the actual building carbon emissions BER



6.4 Be Clean

The analysis presented in Section 4.0 detailed the availability of heat networks which are currently in the vicinity of the proposed Premier Inn Sheffield Barnsley Bedroom Extension.

The feasibility of utilising CHP for providing the hot water services in the proposed development has been assessed at part of the preliminary building services design. CHP can facilitate energy and cost saving by generating heat and power on site in one simultaneous process. The hotel would have a sufficient simultaneous demand for both heating for hot water services HWS and electricity demand of electrical baseload and given the low cost of natural fossil gas, this could provide low running costs. However, UK Electricity Grid decarbonisation is reducing the carbon emissions which previously would be gained from applying CHP as LZC technology.

Utilising on site CHP for reducing carbon emissions was not deemed to be the most appropriate method of meeting the carbon reduction targets, due to minimal carbon reductions and the adverse effect on NOx emissions and hence air quality in the area.

The application of a district heating network will have no effect on local air quality if the development could connect to an existing local network, it is feasible that the hot water services design could be provided by a district heat network. However, the hotel is not situated close enough to an existing heat network which would make connection unfeasible.

There are therefore no carbon reductions between the Be Lean and Be Clean stages of the energy hierarchy and the Energy Strategy will focus on on-site renewable energy generation to facilitate further carbon reductions for the proposed development ie Be Green

The **Be Clean** measures included in the development design are summarised below and detailed in Figure 6.2

- None

The carbon reductions due to the Be Clean measures

As there are no **Be Clean** measures employed there will be 0.0% improvement in the carbon emissions reduction, therefore the carbon reduction emission for Be Clean & Be Clean will remain at 7.11 tonnes per annum a reduction of 1.26% as detailed in Figure 6.3 below and taken from Table 6.1




Figure 6.3 The Be Clean carbon emissions reductions of the proposed development

The **red** line shows the baseline building carbon emissions TER
The **green** line shows the actual building carbon emissions BER





6.5 Be Green

The final stage of the energy hierarchy utilises renewable technology to further lower the carbon emissions of the development. Given that the measures in the Be Clean stage are unfeasible or would have an adverse effect on the air quality in the area, the carbon emissions reductions have been achieved using measures detailed as part of the Be Green stage of the energy hierarchy.

The building services design for the proposed Premier Inn Sheffield Barnsley Bedroom Extension enables a significant reduction in carbon emissions by utilising Heat pumps for HWS and space heating of bedrooms and communal areas.

The application of space heating air source heat pumps (ASHP) will allow space heating system to have efficiencies of 330%, meaning that for every kWh of electricity used, 3.3 kWh of heat energy will be transferred from the external atmosphere into the building for use as space heating. The space heating air source heat pumps will be heat recovery heat pumps which can transfer energy between indoor units. This allows the air source heat pumps to transfer heat to other areas of the building, rather than constantly rejecting it into the external atmosphere. The use of heat recovery ASHP will allow heat transfer between areas of the building which have different activities and or solar gains lowering energy demand.

An air source heat pump ASHP is to provide 100% of the hot water services, this enables a seasonal efficiency 330% using bin weather data. The high seasonal efficiency 3.3 SCOP of the heat pumps ensure that these are the lowest carbon method of providing hot water services. The high efficiency of the air source heat pumps reduces the energy demand for the hot water services, grid electricity usage and operational energy.

The energy mix of the UK Electricity Grid is currently made up by low carbon sources which supply over 50% of annual electricity generation. Over the lifecycle of the building carbon emissions are expected to be reduced further than detailed in this Energy Strategy as the electricity grid continues to be decarbonised towards a fully net zero carbon UK Electricity Grid which is proposed for 2035. The Be Green stage of the Energy Hierarchy enables the development to meet the carbon targets and as such provides a low carbon development.

The **Be Green** measures included in the development design are summarised below and detailed in Figure 6.4 below and taken from Table 6.1

- ASHP Heating
- ASHP Hot Water

The carbon reductions due to the Be Green measures

The **Be Green** measures achieve a further carbon reduction emission to **6.65 tonnes per annum** a further reduction of **7.61%** and detailed in Figure 6.4 below and taken from Table 6.1




Figure 6.4 The Be Green carbon emissions reductions of the proposed development

The **red** line shows the baseline building carbon emissions TER

The **green** line shows the actual building carbon emissions BER



6.6 Overall Carbon Reductions

As Designed

Carbon Dioxide Emissions Per Annum for non-domestic Buildings

	Regulated CO ₂ TPA	Savings CO ₂ TPA	Reduction %	Cumulative Savings CO ₂ TPA	Cumulative % Reduction	Unregulated CO ₂ TPA	Unregulated Energy kWh/m ²
Baseline Part L (2021)	7.20	0.00	0.00	0.00	0.00	1.17	24.8
Including Be Lean Measures	7.11	0.09	1.26	0.09	1.26	1.17	24.8
Including Be Clean Measures	7.11	0.00	0.00	0.09	1.26	1.17	24.8
Including Be Green Measures	6.65	0.46	6.44	0.55	7.61	1.17	24.8

TPA – Tonnes Per annum

Table 6.1 - As Designed Carbon emissions of the proposed development

As Designed

Regulated Carbon Dioxide Savings Per Annum for non-domestic Buildings

	Tonnes CO ₂ per annum	Percentage Reduction %
Savings from Be Lean Measures	0.09	1.26
Savings from Be Clean Measures	0.00	0.00
Savings from Be Green Measures	0.46	6.44
Reduction Compared to Baseline	0.55	7.61

Table 6.2 - As Designed Carbon emission reductions of the proposed development



7.0 Conclusion

The proposed Premier Inn Sheffield Barnsley Bedroom Extension has followed the GLA's energy hierarchy to qualify the carbon emissions reduction targets have been met. This process has involved calculation of carbon emissions at each stage of the hierarchy using building simulation software.

The carbon reductions detailed in this Energy Strategy have been calculated using Part L accredited compliance dynamic simulation modelling software IES VE Compliance DSM. This ensures that the proposed development's carbon emissions have been calculated using a more sophisticated carbon calculations methodology, as opposed to the more simplistic SBEM methodology.

	List of Measures Included	Regulated CO ₂ TPA	Cumulative % Reduction
Baseline	Heat pumps with notional Part L NCM efficiency Space heating = 2.64, Hot Water Services = 2.86	7.20	0.00
Be Lean	Low external envelope U-values Low air permeability Low energy LED lighting with lighting controls	7.11	1.26
Be Clean	Mechanical ventilation with passive heat recovery (MVHR)	7.11	1.26
Be Green	Air Source Heat Pump (ASHP) hot water services (HWS) ASHP space heating to bedrooms	6.65	7.61

This Energy Strategy proposes an all-electric building services strategy due to the adverse effect on local air quality proposed by decentralised or on-site combustion building services. This will ensure lower carbon emission at present and in addition, increasingly reduced carbon emissions as the electricity grid decarbonises. Accordingly, this Energy Strategy confirms that the overall development's carbon emissions will be reduced to **6.65 CO₂ TPA** which is a reduction of **7.61%** below the Part L 2021 baseline.

The energy hierarchy carbon reduction methodology has minimised energy usage and carbon emissions of the proposed Premier Inn Sheffield Barnsley Bedroom Extension to provide a sustainable low energy building.




Figure 6.5 As designed carbon emissions reductions of the proposed development



Appendices

Appendix 1 Part L BRUKL report 2021 Baseline/Be Lean

Appendix 2 Part L BRUKL report 2021 Be Green

Appendix 3 Draft EPC

Appendix 4 Building Energy Input Datasheet

Project name

C8826 PI Sheffield Barnsley**As designed****Date:** Tue May 14 13:52:50 2024

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name**Telephone number:** Phone**Address:** Street Address, City, Postcode

Certification tool

Calculation engine: Apache**Calculation engine version:** 7.0.24**Interface to calculation engine:** IES Virtual Environment**Interface to calculation engine version:** 7.0.24**BRUKL compliance module version:** v6.1.e.1**Foundation area [m²]:** 189.15The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	13.53
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	13.36
Target primary energy rate (TPER), kWh _{PE} /m ² annum	146.44
Building primary energy rate (BPER), kWh _{PE} /m ² annum	144.9
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER BPER ≤ TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.15	0.15	SH00000F:Surf[1]
Floors	0.18	0.1	0.1	SH00000F:Surf[0]
Pitched roofs	0.16	0.1	0.1	RF000005:Surf[0]
Flat roofs	0.18	-	-	No flat roofs in building
Windows** and roof windows	1.6	1.1	1.1	SH00000F:Surf[2]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors^	1.6	1.3	1.3	SH000013:Surf[1]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check.

*** Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	4

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	<0.9

1- xBe Lean System - ASHP VRF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	2.64	6.08	0	1.1	0.8
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

1- xBe Lean HWS - ASHP

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	2.86	-
Standard value	2*	N/A
* Standard shown is for all types except absorption and gas engine heat pumps.		

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

General lighting and display lighting	General luminaire	Display light source	
Zone name	Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
Standard value	95	80	0.3
0F Stairs	51	-	-
0F Bedroom 1	56	-	-
0F Bedroom 2	56	-	-
0F Bedroom 3	56	-	-
0F Bedroom 4	56	-	-
0F Linen Store	89	-	-
0F Plant Room	89	-	-
0F Foyer	59	-	-
1F Stairs	51	-	-
1F Bedroom 1	56	-	-
1F Bedroom 2	56	-	-
1F Bedroom 3	56	-	-
1F Bedroom 4	56	-	-
1F Bedroom 5	56	-	-
1F Linen Store	89	-	-
1F Foyer	59	-	-
0F Corridor	64	-	-
0F Bedroom 5	56	-	-
0F Bedroom 6	56	-	-
0F Bedroom 7	56	-	-
0F Bedroom 8	56	-	-
0F Bedroom 9	56	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
1F Corridor		64	-	-
1F Bedroom 6		56	-	-
1F Bedroom 7		56	-	-
1F Bedroom 8		56	-	-
1F Bedroom 9		56	-	-
1F Bedroom 10		56	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
0F Bedroom 1	NO (-83.9%)	NO
0F Bedroom 2	NO (-55%)	NO
0F Bedroom 3	NO (-54.6%)	NO
0F Bedroom 4	NO (-55.4%)	NO
1F Bedroom 1	NO (-84%)	NO
1F Bedroom 2	NO (-55%)	NO
1F Bedroom 3	NO (-54.8%)	NO
1F Bedroom 4	NO (-55.2%)	NO
1F Bedroom 5	NO (-55.5%)	NO
0F Bedroom 5	NO (-88.9%)	NO
0F Bedroom 6	NO (-68.8%)	NO
0F Bedroom 7	NO (-68.5%)	NO
0F Bedroom 8	NO (-68.4%)	NO
0F Bedroom 9	NO (-68.9%)	NO
1F Bedroom 6	NO (-68.7%)	NO
1F Bedroom 7	NO (-68.7%)	NO
1F Bedroom 8	NO (-68.3%)	NO
1F Bedroom 9	NO (-68.5%)	NO
1F Bedroom 10	NO (-88.9%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	532.3	532.3
External area [m ²]	967.8	967.8
Weather	LEE	LEE
Infiltration [m ³ /hm ² @ 50Pa]	4	3
Average conductance [W/K]	166.05	314.92
Average U-value [W/m ² K]	0.17	0.33
Alpha value* [%]	30.74	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

Retail/Financial and Professional Services
 Restaurants and Cafes/Drinking Establishments/Takeaways
 Offices and Workshop Businesses
 General Industrial and Special Industrial Groups
 Storage or Distribution

100 Hotels

Residential Institutions: Hospitals and Care Homes
 Residential Institutions: Residential Schools
 Residential Institutions: Universities and Colleges
 Secure Residential Institutions
 Residential Spaces
 Non-residential Institutions: Community/Day Centre
 Non-residential Institutions: Libraries, Museums, and Galleries
 Non-residential Institutions: Education
 Non-residential Institutions: Primary Health Care Building
 Non-residential Institutions: Crown and County Courts
 General Assembly and Leisure, Night Clubs, and Theatres
 Others: Passenger Terminals
 Others: Emergency Services
 Others: Miscellaneous 24hr Activities
 Others: Car Parks 24 hrs
 Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	6.49	9.56
Cooling	0.19	0.34
Auxiliary	6.73	13.31
Lighting	12.97	5.55
Hot water	69.13	70.12
Equipment*	24.78	24.78
TOTAL **	95.5	98.89

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	58.95	101.4
Primary energy [kWh _{PE} /m ²]	144.9	146.44
Total emissions [kg/m ²]	13.36	13.53

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
	Actual	79.1	3.9	9.1	0.3	9.5	2.41	3.92	2.64	6.08
	Notional	134.6	8.1	13.5	0.5	16	2.78	4.63	----	----
[ST] No Heating or Cooling										
	Actual	0	0	0	0	0	0	0	0	0
	Notional	0	0	0	0	0	0	0	----	----

Key to terms

- Heat dem [MJ/m2] = Heating energy demand
- Cool dem [MJ/m2] = Cooling energy demand
- Heat con [kWh/m2] = Heating energy consumption
- Cool con [kWh/m2] = Cooling energy consumption
- Aux con [kWh/m2] = Auxiliary energy consumption
- Heat SSEFF = Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
- Cool SSEER = Cooling system seasonal energy efficiency ratio
- Heat gen SSEFF = Heating generator seasonal efficiency
- Cool gen SSEER = Cooling generator seasonal energy efficiency ratio
- ST = System type
- HS = Heat source
- HFT = Heating fuel type
- CFT = Cooling fuel type

Project name

C8826 PI Sheffield Barnsley**As designed****Date:** Tue May 14 13:55:25 2024

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name**Telephone number:** Phone**Address:** Street Address, City, Postcode

Certification tool

Calculation engine: Apache**Calculation engine version:** 7.0.24**Interface to calculation engine:** IES Virtual Environment**Interface to calculation engine version:** 7.0.24**BRUKL compliance module version:** v6.1.e.1**Foundation area [m²]:** 189.15The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	13.53
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	12.5
Target primary energy rate (TPER), kWh _{PE} /m ² annum	146.44
Building primary energy rate (BPER), kWh _{PE} /m ² annum	135.84
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER BPER ≤ TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.15	0.15	SH00000F:Surf[1]
Floors	0.18	0.1	0.1	SH00000F:Surf[0]
Pitched roofs	0.16	0.1	0.1	RF000005:Surf[0]
Flat roofs	0.18	-	-	No flat roofs in building
Windows** and roof windows	1.6	1.1	1.1	SH00000F:Surf[2]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors^	1.6	1.3	1.3	SH000013:Surf[1]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building
U _{a-Limit} = Limiting area-weighted average U-values [W/(m ² K)] U _{a-Calc} = Calculated area-weighted average U-values [W/(m ² K)] U _{i-Calc} = Calculated maximum individual element U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/m ² K NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	4

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	<0.9

1- System - ASHP VRF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	4.67	6.08	0	1.1	0.8
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

1- HWS - ASHP

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	3.3	0.005
Standard value	2*	N/A
* Standard shown is for all types except absorption and gas engine heat pumps.		

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

General lighting and display lighting	General luminaire	Display light source	
Zone name	Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
Standard value	95	80	0.3
0F Stairs	51	-	-
0F Bedroom 1	56	-	-
0F Bedroom 2	56	-	-
0F Bedroom 3	56	-	-
0F Bedroom 4	56	-	-
0F Linen Store	89	-	-
0F Plant Room	89	-	-
0F Foyer	59	-	-
1F Stairs	51	-	-
1F Bedroom 1	56	-	-
1F Bedroom 2	56	-	-
1F Bedroom 3	56	-	-
1F Bedroom 4	56	-	-
1F Bedroom 5	56	-	-
1F Linen Store	89	-	-
1F Foyer	59	-	-
0F Corridor	64	-	-
0F Bedroom 5	56	-	-
0F Bedroom 6	56	-	-
0F Bedroom 7	56	-	-
0F Bedroom 8	56	-	-
0F Bedroom 9	56	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
1F Corridor		64	-	-
1F Bedroom 6		56	-	-
1F Bedroom 7		56	-	-
1F Bedroom 8		56	-	-
1F Bedroom 9		56	-	-
1F Bedroom 10		56	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
0F Bedroom 1	NO (-83.9%)	NO
0F Bedroom 2	NO (-55%)	NO
0F Bedroom 3	NO (-54.6%)	NO
0F Bedroom 4	NO (-55.4%)	NO
1F Bedroom 1	NO (-84%)	NO
1F Bedroom 2	NO (-55%)	NO
1F Bedroom 3	NO (-54.8%)	NO
1F Bedroom 4	NO (-55.2%)	NO
1F Bedroom 5	NO (-55.5%)	NO
0F Bedroom 5	NO (-88.9%)	NO
0F Bedroom 6	NO (-68.8%)	NO
0F Bedroom 7	NO (-68.5%)	NO
0F Bedroom 8	NO (-68.4%)	NO
0F Bedroom 9	NO (-68.9%)	NO
1F Bedroom 6	NO (-68.7%)	NO
1F Bedroom 7	NO (-68.7%)	NO
1F Bedroom 8	NO (-68.3%)	NO
1F Bedroom 9	NO (-68.5%)	NO
1F Bedroom 10	NO (-88.9%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	532.3	532.3
External area [m ²]	967.8	967.8
Weather	LEE	LEE
Infiltration [m ³ /hm ² @ 50Pa]	4	3
Average conductance [W/K]	166.05	314.92
Average U-value [W/m ² K]	0.17	0.33
Alpha value* [%]	30.74	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

Retail/Financial and Professional Services
 Restaurants and Cafes/Drinking Establishments/Takeaways
 Offices and Workshop Businesses
 General Industrial and Special Industrial Groups
 Storage or Distribution

100 Hotels

Residential Institutions: Hospitals and Care Homes
 Residential Institutions: Residential Schools
 Residential Institutions: Universities and Colleges
 Secure Residential Institutions
 Residential Spaces
 Non-residential Institutions: Community/Day Centre
 Non-residential Institutions: Libraries, Museums, and Galleries
 Non-residential Institutions: Education
 Non-residential Institutions: Primary Health Care Building
 Non-residential Institutions: Crown and County Courts
 General Assembly and Leisure, Night Clubs, and Theatres
 Others: Passenger Terminals
 Others: Emergency Services
 Others: Miscellaneous 24hr Activities
 Others: Car Parks 24 hrs
 Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	3.67	9.56
Cooling	0.19	0.34
Auxiliary	8.37	13.31
Lighting	12.97	5.55
Hot water	64.44	70.12
Equipment*	24.78	24.78
TOTAL **	89.64	98.89

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	58.95	101.4
Primary energy [kWh _{PE} /m ²]	135.84	146.44
Total emissions [kg/m ²]	12.5	13.53

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
	Actual	79.1	3.9	5.2	0.3	9.5	4.26	3.92	4.67	6.08
	Notional	134.6	8.1	13.5	0.5	16	2.78	4.63	----	----
[ST] No Heating or Cooling										
	Actual	0	0	0	0	0	0	0	0	0
	Notional	0	0	0	0	0	0	0	----	----

Key to terms

- Heat dem [MJ/m2] = Heating energy demand
- Cool dem [MJ/m2] = Cooling energy demand
- Heat con [kWh/m2] = Heating energy consumption
- Cool con [kWh/m2] = Cooling energy consumption
- Aux con [kWh/m2] = Auxiliary energy consumption
- Heat SSEFF = Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
- Cool SSEER = Cooling system seasonal energy efficiency ratio
- Heat gen SSEFF = Heating generator seasonal efficiency
- Cool gen SSEER = Cooling generator seasonal energy efficiency ratio
- ST = System type
- HS = Heat source
- HFT = Heating fuel type
- CFT = Cooling fuel type

Energy Performance Certificate

Non-Domestic Building



Address 1

Address 2

Address 3

Address 4

City

Postcode

Certificate Reference Number:

3673-8609-1233-2517-8186


This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information in the guidance document *Energy Performance Certificates for the construction, sale and let of non-dwellings* available on the Government's website at www.gov.uk/government/collections/energy-performance-certificates.

Energy Performance Asset Rating



More energy efficient



Net zero CO₂ emissions



This is how energy efficient the building is.



Less energy efficient

Technical information

Main heating fuel:	Grid Supplied Electricity
Building environment:	Air Conditioning
Total useful floor area (m ²):	532.348
Building complexity:	Level 5
Building emission rate (kgCO ₂ /m ² per year):	12.5
Primary energy use (kWh _{PE} /m ² per year):	135.84

Benchmarks

Buildings similar to this one could have ratings as follows:

8 If newly built

30 If typical of the existing stock

Administrative information

This is an Energy Performance Certificate as defined in the Energy Performance of Buildings Regulations 2012 as amended.

Assessment Software: Virtual Environment v7.0.24 using calculation engine ApacheSim v7.0.24

Property Reference: UPRN-000000000000

Assessor Name: Name

Assessor Number: LCEA196952

Accreditation Scheme: CIBSE Certification Limited

Assessor Qualifications: NOS5

Employer/Trading Name: Trading Name

Employer/Trading Address: Trading Address

Issue Date: 14 May 2024

Valid Until: 13 May 2034 (unless superseded by a later certificate)

Related Party Disclosure: Not related to the owner

Recommendations for improving the energy performance of the building are contained in the associated Recommendation Report: 4524-7814-1873-5158-8435

About this document and the data in it

This document has been produced following an energy assessment undertaken by a qualified Energy Assessor, accredited by CIBSE Certification Limited. You can obtain contact details of the Accreditation Scheme at www.cibsecertification.com.

A copy of this certificate has been lodged on a national register as a requirement under the Energy Performance of Buildings Regulations 2012 as amended. It will be made available via the online search function at www.ndepcregister.com. The certificate (including the building address) and other data about the building collected during the energy assessment but not shown on the certificate, for instance heating system data, will be made publicly available at www.opendatacommunities.org.

This certificate and other data about the building may be shared with other bodies (including government departments and enforcement agencies) for research, statistical and enforcement purposes. For further information about how data about the property are used, please visit www.ndepcregister.com. To opt out of having information about your building made publicly available, please visit www.ndepcregister.com/optout.

There is more information in the guidance document *Energy Performance Certificates for the construction, sale and let of non-dwellings* available on the Government website at: www.gov.uk/government/collections/energy-performance-certificates. It explains the content and use of this document and advises on how to identify the authenticity of a certificate and how to make a complaint.

Opportunity to benefit from a Green Deal on this property

The Green Deal can help you cut your energy bills by making energy efficiency improvements at no upfront costs. Use the Green Deal to find trusted advisors who will come to your property, recommend measures that are right for you and help you access a range of accredited installers. Responsibility for repayments stays with the property - whoever pays the energy bills benefits so they are responsible for the payments.

To find out how you could use Green Deal finance to improve your property please call 0300 123 1234.

C8826 Premier Inn Sheffield Barnsley Bedroom Extension Part L Compliance Sheet

U-Values, Architectural & Building Data

	As Designed Specification – Element Description	Key Variable
Floor - External Floor	IES Default Construction U-value 0.10 W.m ⁻² .K ⁻¹	0.10 W.m ⁻² .K ⁻¹
Wall - External Wall	IES Default Construction U-value 0.15 W.m ⁻² .K ⁻¹	0.15 W.m ⁻² .K ⁻¹
Roof	IES Default Construction U-value 0.10 W.m ⁻² .K ⁻¹	0.10 W.m ⁻² .K ⁻¹
Internal Floor	IES Default Construction	N/A
Internal Wall	IES Default Construction	N/A
Internal Ceiling	IES Default Construction	N/A
Doors – Solid Door	Solid door, U-value 1.30 W.m ⁻² .K ⁻¹	1.30 W.m ⁻² .K ⁻¹
Doors – Glazed Door	Not Included	N/A
Doors – Glazed Entrance Door	Not Included	N/A
Glazing - Window	Double glazing U-value 1.10 W.m ⁻² .K ⁻¹ , G-value 0.40	1.10 W.m ⁻² .K ⁻¹ 0.40
Air Pressure	Maximum allowable Part L 2021 air permeability rate is 3.0 m ³ .h ⁻¹ .m ⁻² @ 50Pa	4.0 m ³ .h ⁻¹ .m ⁻² @ 50Pa
Power Factor Correction	Typical value for new equipment is >0.95. However, the level of information required during a CIBSE audit that justifies inputting >0.95 can be prohibitive. Power Factor Correction may not be allowed for so, PFC of <0.9 is chosen.	<0.90

Mech & Elec.

	As Designed Specification – Element Description	Key Variable
Space Heating System	Bedroom- ASHP – SCOP: 4.67 SEER: 6.08 EER: 5.29 Corridor/Plant Room/Store – None (Based on EP200)	SCOP, SEER, EER
Ventilation	MVHR – 1.1 SFP 0.80 Heat Recovery Efficacy (PREM3 Trickle SFP: 1.13 Boost SFP: 0.98)	SFP & Heat Recovery Rate
Hot Water System	SCOP – 3.3 Storage – 40 litres per bed. 19 beds. 760 litres storage. Storage Losses – (kWh/(l.day)) = 0.0047 Loop (Pipework) Length – 5m a bed. 19 beds. = 95 metres Loop (Pipework) Length Losses – Watts/m ² = 8W/m ² Pump Power - 100W	SCOP, Storage Volume, Storage Losses, Pipework Length, Pipework Losses, Secondary Circulation Pump Power
Lighting	Bedroom: 3.17 Power Density Corridor: 3.6 Power Density (at 100 lux yields 3.6W/m ² . Which is the calculated W/m ² from ID5 lighting calculations) Plant Room/Store – 2.00 Power Density – Estimate	Power Density: W/m ² & Lux
Lighting Control	Bedroom/Plant Room/Store – Switch Corridor – PIR – Auto On/Dimming	Beds: Switch Corridor: PIR Dimming
Lighting Lux Level	Bedroom – 227 lux – Calculated figure Corridor – 100 lux – Calculated figure Store – 150 lux – Estimate Plant Room – 200 lux – Estimate	227 lux in Bedrooms & 100 lux in Corridors
Solar Photovoltaic Panel	None Included	N/A