



FLOW CONTROL DETAILS

Hydrobrake control
 SHE-0194-1890-0095-1890
 950mm head
 18.9 l/s pass on flow

Rev	Details	Date	Drwn	Chk
-----	---------	------	------	-----

Avey Homes Ltd

Royston Working mens club
 Church Street, Royston

Flow control manhole

Dwg No. : STE/25/06/04

Date : 26-3-25

Scale : Not to scale Copyright © Shaun Tonge Engineering

SHAUN TONGE
 ENGINEERING

11 Broomhead Road, Wombwell, Barnsley, S73 0SA.
 Mobile 07528 278070 . Email Shauntongeengineering@yahoo.co.uk