



RISK ASSESSMENT	LEVEL OF RISK	SUGGESTED ACTION
DEEP EXCAVATIONS ASSOCIATED WITH DRAINAGE WORKS	HIGH	SHORE ALL EXCAVATIONS WITH APPROPRIATE FRENCH BRACING
WORKING IN CLOSE PROXIMITY TO EXISTING SERVICES	HIGH	USE CORRECT TYPE OF EQUIPMENT AND POSITIVE CONNECTIONS TO EXISTING SERVICES
CONTACT WITH SERVICES	MED	OPERATIVES TO USE CORRECT EAR PROTECTION/CONNECT PIPE
NOISE	MED	OPERATIVES TO USE CORRECT EAR PROTECTION/CONNECT PIPE
DRAINAGE EXCAVATIONS ADJACENT EXISTING BOUNDARY STRUCTURES	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
DRAINAGE EXCAVATION BY HIGHWAY	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
MANHOLE ACCESS TO ADJACENT PROPERTIES AND OCCUPERS	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
DRAINAGE EXCAVATION NEAR TO EXISTING SERVICES	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
WORKING IN CONFINED SPACES WORKING IN DRENDS AND MANHOLES	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
WORKING IN HIGHWAYS / AREAS FROM VEHICLES AND PLANT	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED
ROAD AND DRAINAGE CONSTRUCTION	HIGH	REMOVE EXISTING SERVICES AND PROTECTIVE STRUCTURES TO BE REMOVED

IT IS ASSUMED THAT WORKS ASSOCIATED WITH THIS DESIGN WILL BE UNDERTAKEN BY A PERSON OR PERSONS WHO ARE COMPETENT AND HAVE THE REQUIRED LEVELS OF SUPERVISION AND CONTROL.

1. ALL ADAPTABLE SEWER WORKS AND MATERIAL TO BE IN ACCORDANCE WITH 'CODES FOR ADOPTION' THE RELEVANT BRITISH/EUROPEAN AND YORKSHIRE WATERS STANDARDS/REQUIREMENTS/ADDENDUM TO THE MECHANICAL AND ELECTRICAL SPECIFICATION AND KITEMARKED.
2. MANHOLE COVERS SHALL HAVE A CLEAR OPENING OF 600mm AND SHALL BE CLASS D400 TO BS EN 124 WITH 150mm DEEP FRAMES IN HIGHWAYS.
3. FILLED GROUND MUST BE FILLED AND CONSOLIDATED UNDER THE SUPERVISION AND TO THE SATISFACTION OF YORKSHIRE WATER BEFORE ANY SEWER WORKS ARE CARRIED OUT.
4. YORKSHIRE WATER IS NOT OBLIGED TO ACCEPT FILTER DRAINLAND DRAINAGE RUNOFF INTO THE PUBLIC SEWER NETWORK OR ADAPTABLE DRAINAGE SYSTEM (DIRECTLY OR INDIRECTLY), AN ALTERNATIVE METHOD OF DISPOSAL OF THE LAND DRAINAGE RUNOFF WILL THEREFORE BE REQUIRED AND YOU WILL HAVE TO LIAISE WITH THE LOCAL AUTHORITY, LAND DRAINAGE SECTION WITH REGARD TO THE DISPOSAL OF THE FILTER DRAINLAND DRAINAGE RUNOFF.
5. COVER SLABS MUST CARRY THE BS KITEMARK OR WILL BE REJECTED BY YORKSHIRE WATER INSPECTOR. WHERE THE CLEAR OPENING OF THE KITEMARKED PRODUCT IS DIFFERENT TO THAT OF THE COVER AND FRAME, A LOADING BEARING SLAB SHOULD BE FITTED ABOVE THE COVER SLAB TO BRING THE SIZE DOWN TO 600x600mm FOR THE YORKSHIRE WATER SPECIFIED COVER SIZE. PLEASE REFER TO CONCRETE PIPE SYSTEMS ASSOCIATION (CPSA), TECHNICAL BULLETIN ISSUED AUTUMN 2004 FOR KITEMARKED COVER SLAB OPENING SIZES.
6. SULPHATE RESISTANT CEMENT (C20/25) AND PRECAST CONCRETE PRODUCTS MUST BE USED OR A LABORATORY REPORT PROVIDED PROVING THAT SUCH PRECAUTIONS ARE NOT NECESSARY.
7. THE ADAPTABLE SEWERS SHOULD BE A MINIMUM OF 1m AND MANHOLES 0.9m FROM KERB FACES AND MARGINS.
8. SEWERS MUST HAVE 5m CLEARANCE FROM TREES AND HEDGES (PLEASE ALSO REFER TO FIGURE 2.3 ON PAGE 33 IN 'CODES FOR ADOPTION' FOR RESTRICTIONS ON TREE PLANTING ADJACENT TO SEWERS).
9. SEWERS TO BE LAID IN CLASS 'F' BEDDING (150mm GRANULAR BED AND SURROUND), WHERE DEPTH OF COVER TO TOP OF THE SEWER IS LESS THAN 1.5m IN HIGHWAYS AND VERGES OR LESS THAN 900mm IN HOME VEHICULAR ACCESS AREAS, THEN A CONCRETE SLAB OVER SEWER SHALL BE PROVIDED ABOVE GRANULAR BED AND SURROUND.
10. BEDDING AND BACKFILL MATERIAL TO CONFORM TO THE REQUIREMENT OF WATER INDUSTRY SPECIFICATION 4:08-02 (TABLE A2).
11. THE CHAMBER SIZE OF MANHOLES WITH MORE THAN ONE CONNECTION IN THEM MAY NEED TO BE INCREASED AN INCREMENT TO ACCOMMODATE THE CONNECTIONS AND SEWES.
12. YORKSHIRE WATER POLICY IS NOT TO ACCEPT TYPE 'C' BRICK MANHOLES AND 1000mm DIAM. MANHOLE RINGS. INSTEAD IT IS PREFERRED THAT YOU USE A TYPE 'F' MANHOLE WITH 1000mm DIAM. OR 1500mm DIAM. RINGS, WITH THE OPENING SIGHTED OVER THE CHANNEL WHERE DEPTH OF COVER TO PIPE SOFFIT IS 1.1-1.5m.
13. ADAPTABLE PLASTIC SEWER PIPES TO BE BS1740 (MARKED CERTIFIED TO BS 4350-1 AND BS EN 13478). ADAPTABLE PLASTIC SEWER PIPES TO BE LAID IN MAXIMUM 3 METRE LENGTHS UNLESS THERE IS A SPECIFIC OPERATIONAL NEED TO LAY LONGER LENGTHS. PLASTIC CHANNEL SECTIONS IN MANHOLES ARE NOT ACCEPTABLE AND YORKSHIRE WATER WOULD PREFER CLAYWARE CHANNELS IN MANHOLES. WE HAVE FOUND THAT PLASTIC CHANNELS ARE DIFFICULT TO SET IN CONCRETE BECAUSE THEY FLAT AND A SATISFACTORY FINISH CANNOT BE OBTAINED ON THE BENCHING.
14. THE MINIMUM CRUSHING STRENGTH FOR CLAY PIPES SHOULD BE AS FOLLOWS: 100mm DIA. 40kN/m<sup>2</sup>, 150mm DIA. 40kN/m<sup>2</sup>, 225mm DIA. 45kN/m<sup>2</sup> AND 300mm DIA. 70kN/m<sup>2</sup>. THE MINIMUM CRUSHING STRENGTH FOR CONCRETE PIPES SHOULD BE: CLASS 120 TO EN 1916/BS EN 12002. PLASTIC PIPES SHOULD CONFORM TO WIS 4-35-01 AND BS EN 13478.
15. IF THERE IS A 5/125 COVER AND FRAME HAS BEEN APPROVED, THIS MUST NOT BE COATED IN PLASTIC AND MUST HAVE ACCEPTABLE LIFTING EYES SUITABLY SIZED TO ACCOMMODATE STANDARD LIFTING KEYS. SCREW DOWN COVERS ARE NOT ACCEPTABLE.
16. ALL HIGHWAY WORKS AND MATERIAL TO CONFORM WITH BARNSLEY MBC SPECIFICATION.
17. GULLY COVER AND FRAMES SHALL BE D400 DUCTILE IRON AND COMPLY WITH EUROPEAN STANDARD BS EN 124. THOSE SIGHTED IN ACCESSWAYS AND MEGS COURTS MUST BE SUITABLE FOR USE IN PEDESTRIAN AREAS.



Rev	Description	Date	Initials
-	-	-	-

**Haigh Huddleston & Associates**  
Civil Structural Engineering Consultants  
Firth Buildings, 99 - 101 Leeds Rd, Dewsbury, WF12 7BU | 01924 464342 | 01924 450662  
e martin@haighhuddleston.co.uk

Client  
**SAUL CONSTRUCTION / KEEPMOAT HOMES**

Project  
**DARFIELD**

Detail  
**ENGINEERING FEASIBILITY - FULL SITE**

Dwg No.	Client	Date	Scale	Dwg No.
JM	MH	FEB'2024	1/1000 @A0	E18/7309/001_03

PRELIMINARY