



YorkshireWater

**Head of Planning and Transportation
Service
Barnsley Metropolitan Borough Council
PO Box 604
Barnsley
S70 9FE**

**Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY**

Tel: 0345 120 8482

**Email:
planningconsultation@yorkshirewater.co.uk**

**Your Ref: 2025/1062
Our Ref: B/00341**

7th April 2026

Dear Sir/Madam,

Land adjacent to 1A West Street, Worsbrough Bridge, Barnsley - (BARN) Demolition of existing domestic garage and formation of new driveway/parking, and outline permission for the erection of 4 houses within the residential garden

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure:

The site shall be developed with separate systems of drainage for foul and surface water on and off site. The separate systems should extend to the points of discharge to be agreed.

(In the interest of satisfactory and sustainable drainage)





YorkshireWater

There shall be no piped discharge of surface water from the development prior to the completion of surface water drainage works, details of which will have been submitted to and approved by the sewerage undertaker. If discharge to public sewer is proposed, the information shall include, but not be exclusive to:-

- a) evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical;**
- b) evidence of existing positive drainage to public sewer and the current points of connection; and**
- c) the means of restricting the discharge to public sewer to the existing rate less a minimum 30% reduction, based on the existing peak discharge rate during a 1 in 1 year storm event, to allow for climate change.**

(To ensure that no surface water discharges take place until proper provision has been made for its disposal and in the interest of sustainable drainage)

1.) The submitted 'Outline Drainage Strategy' is acceptable in principal.

In summary, the report outlines an adequate framework for surface water and foul water disposal, including

- a.) Ruling out alternative means of surface water disposal in line with part H3 of the building regulation.
- b.) Flow control and attenuation to the public sewer network if required.

2.) The developer is proposing to discharge surface water to SUDS but the eventual outfall has not been stated. sustainable development requires appropriate surface water disposal.

- a.) Yorkshire Water promote the surface water disposal hierarchy and the developer must provide evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical before considering disposal to public sewer.
- b.) The developer and LPA are strongly advised to seek comments on surface water disposal from other drainage bodies as further restrictions may be imposed.
- c.) As a last resort, and upon receipt of satisfactory evidence to confirm the reasons for rejection of other methods of surface water disposal, curtilage surface water may discharge to public surface water sewer. Surface water discharges to the public sewer must have a minimum of 30% reduction based on the existing peak discharge rate during a 1 in 1 year storm event.
- d.) The developer will be required to provide evidence of existing positive drainage to a public sewer from the site to the satisfaction of Yorkshire Water and the Local Planning Authority by means of physical investigation. On-site attenuation, taking into account climate change, will be required before any discharge to the public sewer network is permitted.

Yours faithfully

Reuben Thornton
Town Planning Team

