



## PLANNING CONSULTATION RESPONSE

<b>Application No</b>	2025/0915
<b>Proposal</b>	Installation of 2no. liquid oxygen storage vessels with vaporisers for medical gas use with associated security and screen fencing and artwork.
<b>Address</b>	Barnsley District General Hospital, Gawber Road, Old Town, Barnsley, S75 2EP
<b>Date of Consultation Reply</b>	15/01/2026
<b>Consultee</b>	Pollution Control

### Consultation Assessment and Justification

The associated documentation has been reviewed and the location and risks have been assessed and my comments are as follows:

This development has the potential to have an adverse impact on health and quality of life of those living and/or working in the locality.

There is no information provided relating to noise levels. A Noise Impact Assessment is required. The assessment must be carried out by a suitably qualified acoustic consultant/engineer and follow the principles contained in BS 4142:2014 Methods for rating and assessing industrial and commercial sound.

	<b>Defer for amends/further information*</b>	
--	--	--

\*Delete as applicable

#### **Consultation Suggested Conditions:**

n/a

#### **Consultation Informative(s):**

n/a

#### **Planning Obligations required:**

n/a