


outer area



Burntwood Hall Farm
 Briarley ST2-9HE.
 18th DEC 2024.

2024/1027/INVALID

re the letter received today, -

- condition 3 - the original plans + details clearly show matching materials, bonding + details which at application stage was acceptable to Tony Wild, however when the materials are sought details + photographs can be forwarded to you.
- condition 4 - again at application stage Tony Wild was in agreement with a reduction to 1.5m (5ft)
- condition 5 - pointing mix will be lime (NHL 3.5) with aggregate ratio of 1:3, sand + aggregate will be well graded river sand.
 Joints will be hand prepared to 2x the joint width to depth.
 pointing will be colour matched + slightly finished back from the original + brush finished.
- condition 6 - Tony Wild again stated at original application stage that if a reputable window firm, used to this type of work was employed that they could provide the timber details/ designs etc for his approval.
 Heads + cills are again clearly shown on the original approved plans.

I trust that you may now have sought details to allow you to proceed, however I will telephone just to confirm.

yours faithfully
