[redacted]

From: Barnsley Council
Sent: 08 June 2015 07:46
To: Planning Comments
Cc: [redacted]
Subject: Public Comment for Planning Application: 2015/0622

Public Comment For Planning Application	
Application Details	
Application Reference No	2015/0622
Application Type	Full
Site Address	17 Market Hill, Barnsley, S70 2PP
Development Types	New Access
Proposal Description	Installation of a new accessible access route and steps to the front of the existing building to permit disabled pedestrian access.
Comment Till	23 June 2015

Comments	
Comments	1300mm is barely enough for wheelchair access and would appear a bit "tight". Highways minimum standard is 1500mm width to allow for turning manoeuvres, etc.
Title	MISS
First Name	ELIZABETH
Initial	D
Last Name	CAMPBELL
Organization	BARNSLEY MBC
Comment Type	Comment
Address Line 1	DESIGN & INFRASTRUCTURE
Address Line 2	BUSINESS UNIT 6 (PLACE)
Address Line 3	WESTGATE PLAZA ONE
Address Line 4	BARNSLEY
Address Line 5	
Post Code	S70 9FA
Email	
Phone	

Comment Posted	08/06/2015 07:46:24