



YorkshireWater

**Head of Planning and Transportation
Service
Barnsley Metropolitan Borough Council
PO Box 604
Barnsley
S70 9FE**

**Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY**

Tel: 0345 120 8482

**Email:
planningconsultation@yorkshirewater.co.uk**

**Your Ref: 2026/0322
Our Ref: B/01339**

27th May 2026

Dear Sir/Madam,

24 Common Road, Brierley, Barnsley, S72 9ES - (BARN) - Erection of detached residential dwellinghouse

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure:

Foul Water

As our powers under the Water Industry Act are limited it is important to ensure explicit control over the approach to foul water disposal in any planning permission. Development of the site should take place with separate systems for foul and surface water drainage. The separate systems should extend to the points of discharge to be agreed.





YorkshireWater

Surface Water

YWS encourages sustainable development, which includes ensuring appropriate surface water disposal to prevent unnecessary hydraulic loading. Volume arising from surface water flows can be many times greater than the foul flows from the same development. As a result they have the potential to use up a significant hydraulic capacity in our infrastructure. If we can minimise surface water flows entering the public sewer, we are able to significantly manage the impact of development on wastewater infrastructure and minimise the risk of flooding

The National Planning Policy Framework (NPPF) sets out the principle of sustainable drainage, while the National Planning Practice Guidance (NPPG) and National Standards for Sustainable Drainage Systems (SuDS) establish a hierarchy for surface water disposal. This hierarchy prioritises 1. Rainwater harvesting (non-potable use) 2. Infiltration to ground 3. Discharge to above ground SW body 4. Discharge to SW sewer 5. Discharge to combined sewer. YWS seeks to promote this hierarchy in collaboration with Local Planning Authorities and developers to improve water quality and reduce flood risk.

It is noted from the submitted planning application that surface water is proposed to be drained to soakaway – Yorkshire Water full endorses this means of surface water disposal.

The developer should note that further restrictions on surface water disposal from the site may be imposed by other parties. The developer is strongly advised to seek advice/comments from the Environment Agency/Land Drainage Authority/Internal Drainage Board with regard to surface water disposal from the site. The landowners' consent will be required for the construction of a new outfall structure.

As surface water from the site is not proposed to discharge to the public sewer network, no assessment of the capacity of the public sewers to receive surface water has been undertaken. Should the surface water disposal proposals change, further consultation with Yorkshire Water will be required.





YorkshireWater

Recommended conditions: -

The site shall be developed with separate systems of drainage for foul and surface water on and off site. The separate systems should extend to the points of discharge to be agreed.

(In the interest of satisfactory and sustainable drainage)

No piped discharge of surface water from the application site shall take place until works to provide a satisfactory outfall, other than the existing local public sewerage, for surface water have been completed in accordance with details submitted to and approved by the Local Planning Authority.

(To ensure that the site is properly drained and in order to prevent overloading, surface water is not discharged to the public sewer network)

Yours faithfully

Reuben Thornton
Town Planning Team

